

連續自動監測紀錄月報表

中華民國110年5月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.53	67.29	8.51	11.00	1.50	80412.24	15.98	15.69	1.00	168.55	13.70
02	5.78	64.96	7.83	10.85	1.52	81340.78	16.11	15.54	1.01	169.13	13.70
03	5.41	67.54	6.73	10.18	1.54	81801.56	17.19	16.22	1.03	173.70	13.23
04	4.85	64.85	9.67	9.98	1.51	80194.53	17.45	14.96	1.01	178.29	12.90
05	4.95	62.47	9.96	9.99	1.47	81252.85	17.15	15.95	0.98	177.81	13.03
06	4.04	66.12	9.30	10.08	1.51	80716.54	16.87	14.56	1.00	175.40	12.93
07	2.93	64.89	9.13	10.29	1.50	80808.44	17.46	15.38	1.00	174.91	13.28
08	3.67	57.42	8.19	10.13	1.49	81057.42	17.48	15.79	0.99	173.58	13.09
09	3.46	50.83	8.32	10.24	1.50	80391.70	17.26	15.33	1.00	173.66	13.08
10	3.80	59.45	8.41	10.09	1.53	81079.59	17.31	15.79	1.02	173.50	13.02
11	3.31	60.41	8.02	10.05	1.52	81475.57	17.81	15.29	1.01	175.16	13.16
12	3.66	59.87	8.75	9.93	1.51	81436.90	17.47	16.06	1.01	174.63	12.95
13	3.76	59.24	8.13	9.85	1.50	81355.24	17.79	16.35	1.00	175.14	12.90
14	3.31	66.42	7.58	10.64	1.47	80595.63	17.44	15.39	0.98	171.90	13.60
15	3.96	65.18	8.92	10.96	1.44	80950.10	16.98	16.33	0.96	167.80	13.88
16	4.08	61.30	9.42	10.95	1.43	80291.64	17.03	16.13	0.95	167.36	13.75
17	4.23	59.22	8.09	10.72	1.39	81175.70	17.35	16.10	0.92	166.80	13.62
18	3.62	62.35	6.93	10.81	1.38	81415.48	17.63	14.43	0.92	168.08	13.87
19	3.44	63.83	8.00	10.90	1.38	81188.29	16.82	15.81	0.92	167.58	13.81
20	3.78	61.88	7.98	10.83	1.43	81818.07	17.17	16.41	0.95	168.57	13.91
21	3.85	60.74	7.37	10.77	1.42	82026.52	17.46	16.27	0.94	169.42	13.94
22	3.53	60.36	8.16	10.75	1.42	82168.51	17.36	16.22	0.95	168.87	13.89
23	3.27	62.29	8.01	10.77	1.42	81845.48	17.29	15.95	0.95	169.06	13.86
24	3.41	59.76	7.48	10.86	1.36	80937.65	17.13	15.81	0.91	167.50	13.76
25	3.38	61.74	7.85	10.90	1.33	81670.97	16.80	15.21	0.89	167.28	13.88
26	3.08	63.11	8.71	10.84	1.41	82049.69	17.08	16.79	0.94	169.13	13.96
27	2.94	61.71	8.67	10.83	1.44	81583.35	16.88	16.72	0.96	168.86	13.83
28	3.18	56.80	9.50	10.84	1.45	81679.60	17.25	16.69	0.97	170.61	13.97
29	3.55	59.21	9.69	11.00	1.39	80558.21	16.67	16.45	0.93	167.74	13.82
30	3.48	58.06	8.47	11.04	1.36	81126.96	17.16	15.72	0.91	169.53	14.10
31	2.99	63.08	7.61	10.91	1.36	81881.93	16.99	15.17	0.91	168.97	14.01
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.81	61.69	8.37	10.58	1.45	81235.07	17.16	15.82	0.97	170.92	13.56
最大值	5.78	67.54	9.96	11.04	1.54	82168.51	17.81	16.79	1.03	178.29	14.10
發生日期											
最小值	2.93	50.83	6.73	9.85	1.33	80194.53	15.98	14.43	0.89	166.80	12.90
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

