

連續自動監測紀錄月報表

中華民國111年2月28日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.15	62.66	8.75	10.45	1.74	81611.54	15.60	14.91	1.16	179.19	13.44
02	1.94	57.81	6.13	10.30	1.70	81786.96	16.00	14.96	1.13	178.49	13.33
03	1.97	62.15	7.07	10.43	1.69	82430.06	15.99	14.98	1.12	180.01	13.64
04	1.49	62.76	7.28	10.91	1.74	78772.23	15.97	13.06	1.16	179.12	13.62
05	0.86	61.60	7.51	10.60	1.72	82541.41	17.11	13.12	1.15	182.75	14.16
06	0.80	57.76	7.85	10.53	1.75	83204.60	17.50	13.17	1.16	182.58	14.22
07	1.14	50.05	7.89	10.38	1.80	82393.22	17.33	14.14	1.20	181.49	13.83
08	0.84	55.52	8.60	10.40	1.77	83835.09	17.73	13.51	1.18	182.85	14.20
09	0.96	56.68	8.82	10.77	1.77	79510.75	16.83	12.28	1.18	180.72	13.75
10	0.81	56.56	7.74	10.54	1.80	81464.88	16.89	12.98	1.20	180.94	13.78
11	0.80	56.20	9.73	10.41	1.80	81586.68	17.65	13.81	1.20	182.30	13.82
12	0.87	57.30	7.10	10.51	1.78	80371.90	17.29	13.52	1.19	180.92	13.64
13	1.00	54.05	8.43	10.33	1.77	81405.69	17.53	13.75	1.18	180.92	13.62
14	1.04	56.58	7.96	10.34	1.72	82279.19	17.46	14.12	1.14	180.94	13.76
15	0.77	58.26	6.73	10.35	1.73	83225.76	17.70	13.28	1.15	182.49	14.03
16	1.57	55.56	8.55	10.17	1.74	84274.47	17.29	15.03	1.16	181.88	13.88
17	1.97	53.16	8.22	10.23	1.73	83378.71	16.69	14.57	1.15	180.68	13.67
18	1.37	57.60	7.18	10.29	1.72	84034.57	17.36	14.77	1.14	182.02	14.00
19	1.36	55.33	8.13	10.21	1.72	84292.64	17.40	12.83	1.14	181.41	13.93
20	1.71	54.80	7.71	10.40	1.76	83481.89	16.51	13.27	1.17	179.74	13.86
21	1.11	56.75	7.54	10.58	1.76	81791.51	16.77	12.36	1.17	180.02	13.84
22	0.88	56.44	7.15	10.91	1.72	80259.76	16.69	12.45	1.15	181.71	14.08
23	1.50	56.24	8.34	10.79	1.74	81814.09	16.31	14.02	1.16	180.56	14.07
24	1.22	53.49	8.58	10.63	1.77	82444.14	16.77	14.56	1.18	179.59	14.01
25	1.48	56.51	8.76	10.76	1.78	81558.09	16.85	14.48	1.19	180.35	14.08
26	1.84	53.96	8.84	10.70	1.77	81285.11	16.55	14.16	1.18	179.74	13.88
27	2.36	50.31	7.98	10.52	1.81	81761.02	16.56	14.40	1.21	179.22	13.71
28	1.59	53.69	6.18	10.61	1.86	81053.59	16.55	14.48	1.24	179.66	13.71
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	1.34	56.42	7.88	10.50	1.76	82066.06	16.89	13.82	1.17	180.80	13.84
最大值	2.36	62.76	9.73	10.91	1.86	84292.64	17.73	15.03	1.24	182.85	14.22
發生日期											
最小值	0.77	50.05	6.13	10.17	1.69	78772.23	15.60	12.28	1.12	178.49	13.33
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年2月28日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.40	64.50	9.80	11.01	1.68	75636.05	15.33	14.85	1.12	188.13	13.39
02	3.99	63.51	9.24	10.94	1.69	75027.98	15.90	14.99	1.13	187.54	13.24
03	4.06	64.00	7.87	10.93	1.76	75800.21	14.81	14.81	1.18	188.63	13.41
04	3.35	62.93	7.28	11.01	1.74	73932.01	16.39	14.21	1.16	186.43	13.18
05	2.48	63.43	7.43	10.88	1.75	78459.16	17.33	13.00	1.16	193.62	14.20
06	2.41	61.14	7.83	10.93	1.72	79697.60	17.64	13.34	1.14	196.13	14.63
07	2.51	59.75	10.30	11.01	1.72	78383.76	17.29	14.15	1.15	195.18	14.40
08	2.30	59.01	8.13	11.00	1.70	79153.16	17.53	13.56	1.13	196.55	14.61
09	2.53	56.35	7.96	11.08	1.69	78215.14	17.08	13.83	1.13	195.36	14.43
10	1.83	58.28	7.44	11.19	1.67	77480.85	16.77	12.74	1.11	195.95	14.43
11	2.40	59.78	10.22	11.11	1.69	77671.28	17.16	13.89	1.12	196.95	14.42
12	2.69	60.25	7.54	11.09	1.67	77630.72	17.04	14.00	1.11	195.97	14.36
13	2.38	57.27	7.90	10.92	1.65	78153.96	17.69	13.99	1.10	196.12	14.33
14	2.43	57.18	9.90	10.99	1.64	78877.19	17.14	13.40	1.09	196.73	14.49
15	2.43	59.49	9.50	10.88	1.62	79704.77	17.72	13.95	1.08	197.42	14.60
16	4.18	55.86	9.90	10.82	1.60	80058.89	16.92	14.18	1.07	196.47	14.41
17	3.55	53.77	8.89	10.86	1.58	82132.25	16.73	14.49	1.05	195.77	14.79
18	3.46	58.52	6.53	10.90	1.60	82883.95	17.24	14.52	1.07	197.10	15.12
19	2.84	57.03	7.63	10.83	1.59	83451.81	17.19	13.00	1.06	196.82	15.11
20	3.40	60.04	8.65	10.99	1.64	83296.33	16.62	14.28	1.09	195.35	15.13
21	2.10	60.14	8.33	11.03	1.73	82804.82	16.66	12.54	1.16	195.93	15.15
22	2.12	57.90	8.31	11.09	1.74	81967.46	17.16	12.49	1.16	196.03	15.18
23	3.23	58.51	9.53	10.94	1.72	83919.24	16.44	13.96	1.14	195.05	15.17
24	2.72	57.78	7.32	11.00	1.68	83120.05	16.63	14.68	1.12	194.36	15.10
25	3.31	58.75	7.96	11.00	1.70	82873.18	16.90	14.56	1.13	195.43	15.15
26	4.15	57.95	6.53	11.06	1.69	82041.26	16.61	14.41	1.13	194.49	15.01
27	4.74	52.68	9.07	10.73	1.62	83862.68	16.90	14.62	1.08	193.71	14.89
28	3.71	58.03	7.81	11.09	1.65	80940.30	16.38	14.67	1.10	193.30	14.77
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	3.06	59.07	8.39	10.98	1.68	79899.15	16.83	13.97	1.12	194.52	14.54
最大值	4.74	64.50	10.30	11.19	1.76	83919.24	17.72	14.99	1.18	197.42	15.18
發生日期											
最小值	1.83	52.68	6.53	10.73	1.58	73932.01	14.81	12.49	1.05	186.43	13.18
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管