

連續自動監測紀錄月報表

中華民國109年7月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.33	62.78	8.70	9.59	2.16	81935.35	18.40	15.39	0.90	177.71	12.86
02	3.34	63.69	7.17	9.60	2.13	83060.50	18.51	15.84	0.89	179.05	13.10
03	3.07	62.26	5.46	9.79	2.09	81605.93	19.05	14.39	0.87	179.92	13.19
04	3.37	64.52	7.03	9.84	2.10	81738.77	18.54	15.76	0.88	179.14	13.19
05	3.64	63.50	5.70	9.87	2.08	80987.12	18.39	16.20	0.87	178.09	13.05
06	3.43	62.03	7.64	9.77	2.06	80610.51	18.31	15.76	0.86	176.43	12.80
07	3.52	63.40	5.22	9.91	2.02	80941.72	18.32	15.08	0.84	178.70	13.09
08	3.71	65.12	7.18	9.80	2.01	80947.69	18.03	15.86	0.84	178.17	12.90
09	3.54	65.91	5.92	9.72	2.07	80790.27	17.96	16.25	0.86	177.14	12.74
10	3.87	63.69	6.27	9.59	2.10	81180.08	18.65	16.40	0.87	178.62	12.81
11	3.62	65.81	5.70	10.04	2.09	79932.39	17.92	16.32	0.87	179.68	13.03
12	3.55	66.24	5.85	9.86	2.07	82465.08	18.17	17.10	0.86	182.64	13.37
13	3.54	64.69	6.06	9.79	2.02	81466.41	17.64	16.19	0.84	180.22	12.97
14	3.48	64.55	5.52	9.67	1.97	81824.89	18.31	16.17	0.82	180.58	12.99
15	3.51	65.46	5.21	9.73	1.93	81064.38	18.20	16.25	0.80	178.76	12.88
16	3.53	64.33	5.43	9.72	1.93	82097.62	18.20	15.58	0.81	180.30	13.07
17	3.56	65.55	7.56	9.89	1.95	81482.58	17.65	15.57	0.81	178.99	13.06
18	3.86	64.32	8.53	10.10	1.95	80346.38	17.49	15.97	0.81	176.26	13.01
19	3.54	64.27	8.17	9.92	1.87	81553.95	18.06	16.22	0.78	177.68	13.12
20	2.74	65.79	8.14	10.16	1.84	79484.35	17.77	7.73	0.77	177.86	12.88
21	2.10	66.24	4.28	10.01	1.89	82192.93	17.91	12.40	0.78	185.61	13.54
22	2.57	63.85	7.49	9.96	1.87	80219.83	17.85	13.70	0.78	179.16	12.96
23	2.31	63.03	5.51	9.89	1.85	80606.48	18.33	9.96	0.77	176.39	12.94
24	2.31	63.43	5.48	9.78	1.84	80858.14	18.58	9.58	0.77	177.09	12.92
25	3.17	65.10	6.80	9.97	1.85	80171.93	18.04	13.11	0.77	176.65	12.92
26	3.36	66.05	4.05	10.07	1.84	79904.56	17.84	13.15	0.77	177.00	12.98
27	3.35	62.86	7.73	9.80	1.83	81845.40	18.46	14.26	0.76	178.20	13.11
28	3.87	64.60	4.42	10.07	1.80	80770.45	17.93	17.43	0.75	179.50	13.21
29	4.03	65.16	4.10	10.14	1.87	79949.53	17.45	17.47	0.78	178.56	13.06
30	3.70	65.11	4.40	9.94	1.90	80514.06	17.78	16.62	0.79	177.67	12.93
31	4.18	65.86	6.94	9.99	1.92	79978.98	17.70	17.47	0.80	178.12	12.92
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.38	64.49	6.25	9.87	1.96	81049.30	18.11	15.01	0.82	178.71	13.02
最大值	4.18	66.24	8.70	10.16	2.16	83060.50	19.05	17.47	0.90	185.61	13.54
發生日期											
最小值	2.10	62.03	4.05	9.59	1.80	79484.35	17.45	7.73	0.75	176.26	12.74
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國109年7月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.32	67.88	11.03	10.08	2.44	76799.18	18.37	14.44	1.02	180.98	12.69
02	2.84	67.25	9.41	9.93	2.45	76340.64	18.74	14.78	1.02	179.07	12.44
03	2.94	68.27	9.83	10.06	2.43	75853.96	19.28	14.06	1.01	180.73	12.62
04	3.11	69.01	9.61	10.13	2.42	75332.52	18.71	14.97	1.01	179.90	12.52
05	3.14	67.27	10.65	10.10	2.50	75767.13	19.16	15.27	1.04	180.85	12.65
06	3.36	68.47	11.40	10.09	2.56	74850.86	18.47	15.36	1.07	178.77	12.34
07	2.95	68.01	9.91	10.15	2.50	75098.00	19.05	14.12	1.04	180.77	12.59
08	3.15	68.72	10.24	10.08	2.52	75973.69	19.02	15.15	1.05	180.26	12.63
09	2.88	67.77	9.75	10.09	2.57	75927.65	18.67	14.81	1.07	184.19	12.68
10	3.80	68.72	10.31	10.08	2.62	76254.41	19.21	14.63	1.09	182.55	12.77
11	3.06	67.21	9.72	10.05	2.58	75283.50	18.73	15.68	1.08	179.50	12.42
12	3.23	68.09	8.45	9.96	2.46	76995.74	19.02	16.39	1.03	182.39	12.71
13	2.82	66.00	8.03	9.84	2.46	76698.16	19.18	13.46	1.02	181.08	12.51
14	2.96	67.55	9.95	10.02	2.45	75459.43	18.76	14.11	1.02	180.23	12.43
15	3.11	67.76	8.56	9.95	2.43	76094.20	19.19	15.88	1.01	180.12	12.52
16	2.57	63.76	9.40	9.86	2.45	76398.39	19.34	14.27	1.02	180.12	12.49
17	3.05	64.97	10.90	9.83	2.40	77385.95	19.21	15.31	1.00	181.43	12.64
18	2.58	67.03	11.22	10.08	2.36	75334.55	19.18	15.77	0.98	180.70	12.55
19	2.43	65.62	11.31	9.97	2.38	75988.52	19.33	15.77	0.99	181.31	12.58
20	2.50	64.01	11.49	9.88	2.31	75852.54	19.59	14.57	0.96	180.72	12.47
21	2.91	66.04	11.02	10.05	2.29	77331.52	19.52	15.47	0.95	182.77	12.97
22	3.09	65.89	10.99	10.13	2.20	75796.13	19.28	15.90	0.92	181.53	12.72
23	2.88	62.93	10.78	9.98	2.17	75928.49	19.30	14.45	0.90	179.82	12.53
24	2.68	64.15	9.97	10.09	2.24	75788.09	19.26	8.23	0.93	179.74	12.63
25	2.20	64.44	11.10	10.15	2.31	75477.27	18.89	6.87	0.96	178.63	12.56
26	2.38	66.96	9.75	10.21	2.34	75233.23	18.92	11.25	0.98	179.55	12.61
27	2.53	66.29	11.50	10.03	2.33	75974.69	19.43	14.40	0.97	179.89	12.61
28	2.70	67.92	10.70	10.20	2.33	75999.83	19.18	16.91	0.97	181.98	12.83
29	2.73	66.66	11.20	10.16	2.30	76191.86	19.31	16.94	0.96	181.93	12.85
30	2.47	67.39	11.07	10.15	2.34	76339.86	19.33	16.38	0.97	182.89	12.90
31	2.67	67.70	11.08	10.19	2.41	76492.12	19.48	16.74	1.00	183.10	12.99
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.87	66.77	10.33	10.05	2.40	76007.81	19.10	14.59	1.00	180.89	12.63
最大值	3.80	69.01	11.50	10.21	2.62	77385.95	19.59	16.94	1.09	184.19	12.99
發生日期											
最小值	2.20	62.93	8.03	9.83	2.17	74850.86	18.37	6.87	0.90	178.63	12.34
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管