

連續自動監測紀錄月報表

中華民國107年5月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	10.81	49.63	27.62	14.46	2.33	70307.53	5.15	8.44	1.16	115.71	11.67
02	11.55	62.76	12.06	14.88	2.34	65772.35	5.75	9.21	1.17	116.48	11.68
03	10.13	63.54	11.34	15.02	1.97	65344.55	6.92	9.34	0.99	113.38	11.78
04	10.21	62.33	14.19	14.95	1.81	65999.34	6.95	8.26	0.91	114.17	11.78
05	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
06	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
07	11.81	74.90	14.31	15.14	2.21	65315.25	6.33	10.46	1.10	118.27	12.17
08	10.53	70.52	19.70	15.02	2.14	67037.52	5.96	9.63	1.07	115.87	12.16
09	10.07	73.78	20.10	15.10	1.77	66618.07	6.98	9.70	0.89	113.96	12.20
10	10.58	74.57	11.34	15.10	1.59	66610.41	7.01	10.27	0.79	114.67	12.21
11	11.05	70.65	19.88	15.10	1.97	65689.48	6.69	9.97	0.99	115.40	12.08
12	11.55	70.83	15.37	14.99	2.07	67173.74	5.91	11.08	1.03	116.16	12.13
13	11.38	66.70	12.91	14.88	2.16	67955.79	5.40	10.13	1.08	116.57	12.07
14	11.48	64.47	18.09	14.90	2.16	67449.56	5.58	9.13	1.07	116.90	12.02
15	11.97	69.13	15.90	14.96	2.30	66925.37	5.08	9.39	1.15	116.73	12.05
16	12.86	67.07	15.82	14.89	2.61	67188.68	5.15	9.74	1.30	116.66	11.95
17	13.57	64.46	18.95	14.82	3.01	67175.84	4.73	10.09	1.51	116.38	11.82
18	14.56	65.76	18.30	14.85	2.83	66895.11	4.75	11.35	1.42	116.50	11.81
19	13.39	63.64	27.39	14.79	2.98	66647.38	4.05	10.27	1.49	115.87	11.65
20	14.12	55.61	26.31	14.72	3.07	65036.40	3.60	9.03	1.54	114.16	11.21
21	14.15	68.62	15.07	15.01	2.71	65368.29	5.05	9.59	1.36	116.30	11.87
22	14.25	70.75	14.79	15.05	2.65	65830.52	5.18	9.99	1.32	117.24	12.06
23	12.36	67.00	22.06	14.97	2.66	66714.65	5.20	9.25	1.33	115.57	12.01
24	12.94	67.15	19.22	15.00	2.59	66340.87	5.63	9.83	1.30	115.68	11.99
25	14.65	70.79	14.40	15.00	2.51	66104.88	5.48	12.45	1.26	116.63	11.98
26	13.94	67.10	15.63	14.97	2.56	66228.35	4.94	11.07	1.28	116.84	11.96
27	14.17	65.89	20.19	15.01	2.41	65575.22	5.09	9.85	1.20	116.79	11.92
28	14.13	63.96	20.53	14.87	2.52	67005.33	4.82	9.66	1.26	116.99	11.90
29	13.38	65.07	7.75	14.95	2.64	66344.03	4.55	9.25	1.32	116.37	11.91
30	13.78	63.91	20.18	14.95	2.55	65091.10	5.16	10.41	1.27	115.99	11.90
31	14.70	64.20	24.03	14.88	2.43	66869.52	4.34	10.40	1.21	116.84	11.89
監測日數	29	29	29	29	29	29	29	29	29	29	29
平均值	12.55	66.37	17.70	14.94	2.40	66503.97	5.43	9.90	1.20	116.04	11.93
最大值	14.70	74.90	27.62	15.14	3.07	70307.53	7.01	12.45	1.54	118.27	12.21
發生日期											
最小值	10.07	49.63	7.75	14.46	1.59	65036.40	3.60	8.26	0.79	113.38	11.21
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國107年5月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	7.69	60.14	17.52	14.73	3.24	71008.05	19.56	16.77	1.62	125.09	12.46
02	8.14	58.78	9.66	14.73	3.20	73775.15	20.06	7.95	1.60	124.16	12.89
03	8.49	69.99	7.00	14.89	3.17	72194.49	21.16	5.40	1.58	121.91	12.87
04	9.05	63.00	15.17	14.64	3.16	75173.04	20.88	6.76	1.58	122.46	12.88
05	8.53	52.72	21.35	14.23	3.10	80139.93	19.62	3.56	1.55	123.19	12.93
06	8.19	46.39	26.52	13.99	3.04	83379.55	18.58	4.03	1.52	123.46	13.01
07	7.93	55.26	18.12	14.34	2.97	77979.77	18.53	2.83	1.49	123.71	12.88
08	8.11	59.05	9.48	14.43	2.98	76544.69	18.76	6.26	1.49	122.48	12.99
09	8.50	61.74	10.42	14.48	3.01	75669.06	20.52	11.11	1.50	121.03	12.90
10	8.94	66.37	12.45	14.59	3.04	74237.50	20.49	10.09	1.52	121.40	12.88
11	9.16	66.07	14.28	14.67	3.04	73828.95	20.18	3.90	1.52	122.16	12.99
12	8.33	59.09	13.39	14.49	2.97	74132.62	19.23	3.85	1.48	122.23	12.70
13	7.99	52.55	12.48	14.22	2.93	75419.57	18.76	4.72	1.46	122.59	12.40
14	7.98	58.44	11.59	14.26	2.93	76727.59	18.49	5.63	1.46	123.23	12.72
15	8.14	54.57	14.49	14.25	2.90	76231.01	18.19	4.86	1.45	122.77	12.59
16	8.18	56.89	15.68	14.32	2.92	75334.43	18.75	7.63	1.46	123.19	12.60
17	8.39	52.26	13.71	14.23	2.89	73937.44	18.74	8.32	1.44	123.28	12.19
18	8.31	48.60	14.75	14.12	2.88	75364.06	18.23	6.85	1.44	123.30	12.23
19	8.23	55.52	14.77	14.29	2.87	74303.07	18.39	7.03	1.44	123.08	12.37
20	8.42	47.25	20.63	14.14	2.87	75625.63	18.11	6.70	1.44	123.16	12.32
21	8.18	51.28	14.58	14.17	2.88	76476.06	17.86	5.88	1.44	123.05	12.50
22	8.38	51.67	19.66	14.26	2.89	74379.54	18.54	5.73	1.44	122.69	12.32
23	8.02	52.22	18.97	14.27	2.90	75547.36	18.67	6.24	1.45	121.72	12.50
24	8.38	54.25	12.97	14.30	2.94	75539.12	18.74	6.53	1.47	121.89	12.55
25	9.41	56.03	22.60	14.37	2.92	75172.68	18.69	9.14	1.46	122.34	12.64
26	8.66	58.65	13.59	14.33	2.89	76016.92	17.97	7.98	1.45	122.67	12.71
27	8.89	51.99	22.08	14.31	2.87	76132.13	17.85	6.67	1.44	122.47	12.68
28	8.76	52.44	14.21	14.35	2.86	75770.88	17.79	4.43	1.43	122.36	12.70
29	8.52	52.15	8.45	14.42	2.86	75685.84	17.73	7.39	1.43	121.84	12.80
30	8.71	53.03	17.78	14.52	2.90	73530.56	18.63	12.58	1.44	121.18	12.84
31	9.19	49.79	19.89	14.40	2.97	76179.52	17.92	13.41	1.49	121.67	12.85
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	8.45	55.75	15.43	14.38	2.97	75530.20	18.89	7.10	1.48	122.64	12.67
最大值	9.41	69.99	26.52	14.89	3.24	83379.55	21.16	16.77	1.62	125.09	13.01
發生日期											
最小值	7.69	46.39	7.00	13.99	2.86	71008.05	17.73	2.83	1.43	121.03	12.19
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管