

連續自動監測紀錄月報表

中華民國111年6月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.59	46.59	7.69	9.64	1.40	81721.60	18.82	11.93	0.93	180.11	13.03
02	2.23	46.98	8.63	9.62	3.79	82044.90	19.06	11.52	0.95	181.00	13.11
03	2.39	49.62	7.83	9.72	3.70	81827.78	18.51	11.90	0.93	181.08	13.12
04	2.68	50.43	7.03	9.71	3.65	82033.23	18.50	12.23	0.91	181.19	13.13
05	2.71	48.89	7.74	9.63	1.40	82292.15	18.73	11.63	0.94	181.12	13.10
06	2.58	45.70	7.19	9.57	2.99	81768.07	18.81	11.33	0.93	179.88	12.94
07	3.09	49.06	7.35	9.82	1.34	82104.16	17.92	11.83	0.90	180.15	13.15
08	2.52	49.39	8.00	9.79	1.33	82113.08	18.56	11.53	0.89	180.42	13.23
09	2.59	47.30	9.13	9.57	1.38	83141.04	18.57	11.88	0.92	180.48	13.14
10	2.24	48.62	7.58	9.62	1.41	83024.08	18.97	11.84	0.94	181.83	13.28
11	2.50	49.14	6.73	9.53	1.38	82956.12	19.00	12.30	0.92	181.07	13.17
12	2.46	50.87	5.97	9.69	1.34	82007.14	18.54	12.16	0.90	180.28	13.08
13	2.72	48.33	6.72	9.58	1.38	82487.04	18.55	12.02	0.92	180.58	13.04
14	2.36	48.89	6.38	9.60	1.40	82195.69	18.74	11.86	0.93	181.11	13.07
15	2.94	46.61	7.53	9.65	1.38	81273.95	18.10	11.69	0.92	178.75	12.81
16	2.24	47.30	7.00	9.48	1.31	82581.12	18.68	12.04	0.88	179.53	12.93
17	1.83	50.96	9.88	9.64	1.33	82323.95	18.88	12.14	0.89	182.20	13.19
18	2.36	50.40	7.12	9.79	1.34	81457.42	18.07	12.26	0.90	180.59	13.05
19	2.13	47.53	8.17	9.76	1.32	81665.70	18.05	11.96	0.88	181.38	13.07
20	2.38	47.52	6.95	9.54	1.32	81628.86	18.22	12.07	0.88	179.06	12.77
21	2.35	47.34	7.31	9.58	1.32	82163.61	18.25	12.06	0.88	180.34	12.94
22	2.70	44.08	6.28	9.52	1.32	81520.35	18.38	12.00	0.88	179.81	12.78
23	2.70	47.02	6.70	9.39	1.26	81637.65	18.57	12.18	0.84	178.98	12.66
24	2.02	46.54	9.12	9.67	1.19	82086.19	17.97	11.86	0.79	180.43	13.00
25	2.53	47.35	8.08	9.67	1.21	81977.37	17.76	11.75	0.81	179.96	12.94
26	2.64	46.41	7.15	9.59	1.25	82159.84	17.88	12.27	0.83	179.84	12.88
27	2.37	47.08	6.90	9.55	1.27	81746.13	18.00	12.06	0.85	179.92	12.80
28	2.25	46.19	7.51	9.56	1.30	82899.47	18.33	11.84	0.87	181.24	13.08
29	2.02	47.44	6.92	9.53	1.31	82377.02	18.15	11.46	0.87	180.95	12.93
30	2.12	44.61	5.69	9.51	1.31	82372.78	18.02	12.19	0.88	180.21	12.86
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.44	47.81	7.41	9.62	1.62	82119.58	18.42	11.93	0.89	180.45	13.01
最大值	3.09	50.96	9.88	9.82	3.79	83141.04	19.06	12.30	0.95	182.20	13.28
發生日期											
最小值	1.83	44.08	5.69	9.39	1.19	81273.95	17.76	11.33	0.79	178.75	12.66
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年6月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.57	49.40	8.99	10.53	1.47	82188.47	18.17	12.15	0.98	187.55	14.32
02	3.40	49.97	7.59	10.57	3.89	81203.59	18.34	12.23	0.97	187.46	14.23
03	3.55	50.51	6.65	10.65	3.87	81159.12	18.20	12.23	0.97	188.20	14.34
04	3.87	49.14	7.68	10.64	3.83	80833.32	18.06	12.43	0.96	187.60	14.22
05	3.63	48.64	7.80	10.40	1.46	82255.48	18.46	12.06	0.97	187.86	14.22
06	3.43	45.57	7.68	10.38	3.16	82015.64	18.53	12.06	0.99	187.48	14.17
07	3.20	49.89	8.67	10.76	1.50	81046.32	17.94	12.34	1.00	188.58	14.48
08	3.26	52.88	9.87	10.75	1.51	82232.07	18.27	12.28	1.00	189.68	14.72
09	3.73	48.93	9.10	10.57	1.52	82490.17	18.22	12.40	1.01	188.71	14.49
10	3.25	52.69	7.45	10.71	1.53	81720.76	18.40	12.49	1.02	189.67	14.61
11	3.40	51.56	7.29	10.66	1.53	81658.89	18.23	12.91	1.02	188.35	14.47
12	3.52	53.72	6.91	10.74	1.53	81975.58	18.06	12.61	1.01	189.22	14.62
13	3.59	52.51	7.62	10.53	1.50	82048.60	18.34	12.18	1.00	189.50	14.38
14	3.12	49.54	6.66	10.55	1.47	81686.41	18.43	12.07	0.98	190.50	14.40
15	4.00	50.25	8.34	10.58	1.47	81110.06	17.85	12.59	0.98	189.01	14.21
16	2.93	49.50	6.84	10.54	1.52	81984.35	18.35	12.32	1.01	189.90	14.40
17	2.92	52.11	9.81	10.64	1.54	80880.48	18.66	12.19	1.02	190.98	14.41
18	3.23	54.29	8.73	10.82	1.47	81946.22	17.78	12.83	0.98	191.52	14.75
19	3.25	48.48	6.58	10.61	1.42	82035.42	17.93	12.22	0.95	190.52	14.47
20	3.37	47.64	7.95	10.47	1.44	81602.31	18.06	13.00	0.96	189.59	14.19
21	3.22	47.23	8.63	10.61	1.45	81631.60	17.87	12.14	0.96	190.19	14.38
22	3.46	48.90	9.38	10.53	1.46	82756.49	18.07	12.24	0.97	191.28	14.54
23	3.59	47.30	7.55	10.31	1.41	81858.41	18.21	12.61	0.94	188.53	14.01
24	2.96	50.57	8.88	10.66	1.40	81874.75	17.73	11.97	0.93	190.36	14.45
25	3.11	49.88	9.60	10.66	1.37	81638.31	17.63	12.61	0.92	190.49	14.42
26	3.10	49.33	7.08	10.58	1.36	81880.41	17.69	12.82	0.91	190.52	14.36
27	3.09	51.31	7.30	10.43	1.40	82260.97	18.12	12.75	0.94	189.96	14.27
28	2.82	50.85	8.22	10.62	1.44	82317.54	17.96	12.24	0.96	192.89	14.61
29	2.83	49.85	7.59	10.60	1.37	82191.28	17.72	12.20	0.92	191.89	14.48
30	2.72	49.11	6.92	10.56	1.33	82672.43	17.80	12.58	0.89	192.39	14.55
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.30	50.05	7.98	10.59	1.75	81838.52	18.10	12.39	0.97	189.68	14.41
最大值	4.00	54.29	9.87	10.82	3.89	82756.49	18.66	13.00	1.02	192.89	14.75
發生日期											
最小值	2.72	45.57	6.58	10.31	1.33	80833.32	17.63	11.97	0.89	187.46	14.01
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管