

連續自動監測紀錄月報表

中華民國112年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.77	49.94	8.45	12.17	1.43	71297.36	13.58	9.14	1.13	179.70	13.72
02	2.54	51.27	8.84	12.13	1.22	72684.76	13.63	8.82	0.94	181.55	13.98
03	2.17	47.96	7.30	11.97	1.29	72907.74	14.23	8.38	1.00	184.99	13.99
04	2.21	46.89	7.96	12.13	1.29	71305.14	14.14	8.52	0.99	185.45	13.92
05	2.68	47.99	9.20	12.29	1.26	71155.50	13.91	8.85	0.98	182.30	14.02
06	3.01	47.22	9.40	12.29	1.25	70935.17	13.53	8.90	0.96	180.57	13.86
07	3.08	46.76	8.19	12.28	1.19	70788.01	13.63	8.99	0.92	179.68	13.79
08	3.37	46.43	9.74	12.42	1.18	68739.10	13.62	8.78	0.91	180.01	13.62
09	3.19	47.21	9.04	12.42	1.20	68479.94	13.58	8.46	0.93	179.73	13.55
10	3.34	44.13	9.23	12.48	1.26	67304.14	13.66	9.04	0.97	179.87	13.44
11	3.01	45.00	8.70	12.70	1.28	65998.29	14.05	8.44	0.98	181.74	13.65
12	3.26	47.73	9.35	12.80	1.26	66501.19	13.44	8.88	0.97	181.95	13.83
13	3.86	48.98	9.71	12.89	1.25	66254.32	12.92	8.96	0.97	181.22	13.80
14	3.25	46.95	8.64	12.87	1.26	65234.46	13.34	8.61	0.97	180.49	13.61
15	3.89	44.26	9.68	12.84	1.25	65606.86	13.36	9.16	0.96	181.34	13.68
16	3.73	48.68	9.34	12.79	1.20	67852.18	12.69	8.99	0.92	179.47	13.88
17	3.79	45.45	9.80	12.45	1.20	70971.03	12.97	9.00	0.93	179.73	14.00
18	3.24	46.78	9.07	12.44	1.25	69248.35	13.54	8.75	0.96	180.53	13.76
19	3.08	45.31	9.15	12.40	1.23	70224.89	13.87	8.70	0.95	182.18	14.00
20	3.15	44.99	11.11	12.46	1.19	70929.71	13.37	8.81	0.92	181.52	14.13
21	2.98	45.47	11.20	12.07	1.17	75274.02	13.39	8.77	0.90	181.17	14.34
22	2.99	44.20	10.26	11.83	1.20	76372.61	13.63	8.97	0.92	180.22	14.18
23	3.45	38.31	8.35	12.14	1.20	72372.74	13.16	9.08	0.93	178.81	13.78
24	3.01	44.84	8.52	12.01	1.21	74377.54	13.68	8.78	0.93	181.18	14.13
25	2.98	47.40	8.70	11.83	1.20	75569.76	13.69	8.88	0.92	180.51	14.04
26	3.02	49.89	10.14	12.17	1.22	71482.60	15.51	9.56	0.94	181.27	14.01
27	2.85	47.81	9.81	12.51	1.25	64963.79	18.00	9.69	0.97	180.40	13.73
28	2.91	50.53	9.50	12.44	1.55	65671.43	18.43	9.75	1.20	180.88	13.83
29	2.69	53.65	9.88	12.65	1.39	65169.06	18.13	9.74	1.08	182.41	14.09
30	2.46	50.99	8.46	12.46	1.22	65129.71	18.60	9.27	0.94	181.31	13.81
31	3.09	48.73	8.93	12.46	1.23	65431.91	18.07	9.12	0.95	180.11	13.75
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.07	47.15	9.21	12.38	1.25	69555.91	14.37	8.96	0.97	181.04	13.87
最大值	3.89	53.65	11.20	12.89	1.55	76372.61	18.60	9.75	1.20	185.45	14.34
發生日期											
最小值	2.17	38.31	7.30	11.83	1.17	64963.79	12.69	8.38	0.90	178.81	13.44
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.41	46.87	8.86	11.67	1.15	79788.10	15.22	9.39	0.89	189.55	15.14
02	3.33	46.14	9.74	11.89	1.17	78231.78	15.25	7.08	0.90	190.31	15.23
03	3.71	42.84	8.31	11.69	1.23	78978.32	15.99	8.01	0.96	190.30	15.19
04	3.43	44.16	8.82	11.47	1.28	79975.21	16.51	8.41	0.99	190.55	15.13
05	3.36	45.39	9.33	11.57	1.27	79669.86	16.30	9.06	0.98	191.19	15.20
06	4.10	44.81	9.68	11.56	1.28	79227.99	15.71	9.02	0.99	189.71	14.96
07	3.75	45.54	8.25	11.42	1.25	81006.90	15.83	9.53	0.97	189.97	15.09
08	4.72	44.34	9.59	11.72	1.26	77878.05	15.47	9.73	0.97	190.73	14.93
09	4.55	41.96	9.76	11.67	1.27	78088.05	15.66	9.20	0.98	190.47	14.92
10	4.10	40.48	10.35	11.67	1.23	77751.97	16.09	8.96	0.95	191.63	14.98
11	3.59	41.84	9.32	11.54	1.23	78284.80	16.88	8.53	0.95	192.70	15.03
12	3.67	44.46	11.08	11.68	1.20	78629.17	16.20	9.14	0.93	192.33	15.20
13	4.25	42.00	10.85	11.75	1.20	78216.72	15.61	9.47	0.92	191.53	15.10
14	3.13	43.31	8.82	11.62	1.18	78629.00	16.42	8.66	0.91	193.06	15.16
15	3.83	43.98	9.06	11.63	1.15	78344.73	16.51	8.64	0.88	193.06	15.15
16	4.65	44.47	10.00	12.01	1.11	77510.34	14.77	9.97	0.85	190.56	15.21
17	4.63	42.59	9.12	12.07	1.14	77804.06	14.47	9.83	0.87	191.49	15.36
18	3.90	44.94	8.21	12.19	1.17	75849.58	14.89	8.55	0.90	193.21	15.30
19	4.01	43.51	9.98	12.25	1.19	75034.27	15.12	9.31	0.92	192.58	15.26
20	4.19	42.87	10.78	12.24	1.22	75412.17	14.78	9.17	0.94	191.08	15.21
21	4.25	42.40	11.34	12.27	1.19	76601.89	14.05	9.15	0.92	191.80	15.39
22	4.27	44.15	10.01	12.29	1.17	76657.02	14.11	10.00	0.90	191.13	15.43
23	4.75	38.31	9.50	12.38	1.19	75320.12	13.97	10.10	0.92	190.81	15.28
24	4.39	43.51	9.95	12.30	1.19	75956.09	14.29	9.91	0.91	191.84	15.35
25	4.20	45.43	9.42	12.27	1.17	76487.99	14.11	9.46	0.90	191.54	15.37
26	4.93	46.34	11.03	12.55	1.17	72214.50	16.00	10.21	0.90	191.65	15.27
27	5.20	45.00	11.53	13.11	1.18	64838.38	18.15	11.26	0.91	192.02	15.16
28	4.89	48.32	9.82	13.04	1.18	64770.25	18.59	11.19	0.91	191.83	15.07
29	4.66	48.80	10.62	13.18	1.17	64038.89	18.53	10.72	0.90	191.42	15.15
30	4.42	46.21	9.91	13.13	1.18	63844.14	18.80	10.37	0.91	191.16	15.06
31	4.31	44.47	9.44	12.88	1.19	65726.51	18.74	9.50	0.92	190.11	14.96
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.18	44.18	9.76	12.09	1.20	75508.61	15.90	9.40	0.92	191.33	15.17
最大值	5.20	48.80	11.53	13.18	1.28	81006.90	18.80	11.26	0.99	193.21	15.43
發生日期											
最小值	3.13	38.31	8.21	11.42	1.11	63844.14	13.97	7.08	0.85	189.55	14.92
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管