

連續自動監測紀錄月報表

中華民國108年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	10.61	103.64	6.33	11.23	2.30	80135.09	15.85	18.07	0.96	178.33	14.28
02	10.56	106.56	8.13	11.50	2.28	78777.02	15.55	16.49	0.95	178.13	14.37
03	11.69	103.74	7.73	11.46	2.32	79303.82	15.59	16.10	0.97	177.02	14.40
04	11.67	101.36	9.08	11.33	2.25	79792.61	17.11	14.69	0.94	149.36	13.65
05	11.27	97.17	9.04	11.10	2.22	80359.44	17.15	12.39	0.92	150.41	13.45
06	11.07	100.56	6.99	11.18	2.15	80329.33	17.53	11.11	0.90	151.52	13.66
07	11.41	99.83	9.46	11.14	2.07	80978.94	17.66	10.70	0.86	150.13	13.67
08	11.04	101.08	6.98	11.14	2.05	79849.02	18.29	11.78	0.86	149.37	13.57
09	10.69	108.78	3.80	11.42	2.03	79905.55	18.59	9.76	0.84	149.72	14.04
10	10.99	109.86	3.23	11.32	2.06	79871.11	17.97	10.36	0.86	150.21	13.80
11	11.34	108.92	4.39	11.29	2.07	80258.52	17.92	10.24	0.86	150.06	13.81
12	11.50	108.37	4.28	11.16	2.01	80701.17	17.45	8.02	0.84	149.52	13.61
13	10.38	109.42	8.72	11.21	2.11	79981.79	17.47	5.29	0.88	150.21	13.60
14	9.76	97.41	8.61	11.16	2.11	79022.48	17.69	9.95	0.88	152.94	13.48
15	10.65	102.53	4.86	11.00	2.03	80427.98	17.50	11.65	0.85	154.03	13.49
16	11.16	108.12	5.03	11.15	1.99	81192.01	17.70	11.01	0.83	150.20	13.73
17	11.32	111.11	3.74	11.25	1.94	80236.58	17.18	11.32	0.81	150.14	13.63
18	11.77	114.29	5.78	11.28	1.89	80234.32	16.53	12.25	0.79	149.86	13.57
19	11.57	108.35	3.76	10.94	1.89	82606.63	17.54	10.36	0.79	149.63	13.64
20	11.06	87.99	9.61	10.90	1.96	84004.23	18.24	12.70	0.81	158.96	14.25
21	10.47	53.54	15.65	10.61	1.91	84947.73	17.58	17.35	0.80	181.41	14.63
22	10.78	69.34	7.76	10.87	1.88	83186.25	17.38	16.29	0.78	178.78	14.56
23	11.15	77.75	9.76	10.92	1.90	82991.80	17.15	17.68	0.79	178.74	14.56
24	11.15	104.68	8.60	11.06	1.93	83199.09	17.14	16.65	0.80	178.88	14.80
25	11.02	103.52	6.31	10.77	2.03	84379.54	17.44	16.10	0.85	179.80	14.67
26	11.42	106.78	4.15	11.01	2.03	83052.42	16.97	15.00	0.85	173.07	14.45
27	12.25	106.21	11.26	11.56	1.94	79962.79	15.82	12.69	0.81	159.14	14.11
28	11.37	77.41	14.11	11.22	2.01	81922.09	15.83	9.97	0.83	179.71	14.61
29	11.45	74.47	12.69	11.14	1.99	82089.78	15.91	11.04	0.83	179.06	14.51
30	11.44	90.50	10.23	11.20	1.98	81253.48	16.26	11.61	0.83	178.30	14.49
31	11.27	110.99	8.99	11.01	2.01	83798.06	15.86	12.45	0.84	179.81	14.64
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	11.14	98.85	7.71	11.15	2.04	81250.02	17.09	12.62	0.85	162.79	14.06
最大值	12.25	114.29	15.65	11.56	2.32	84947.73	18.59	18.07	0.97	181.41	14.80
發生日期											
最小值	9.76	53.54	3.23	10.61	1.88	78777.02	15.55	5.29	0.78	149.36	13.45
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	14.13	104.90	14.84	11.27	3.01	74908.67	15.41	16.24	1.26	190.24	13.67
02	13.84	107.04	12.38	11.35	3.07	74746.28	15.41	14.15	1.28	189.22	13.74
03	14.78	102.06	12.74	11.38	3.04	74674.88	15.70	13.95	1.27	188.21	13.78
04	15.63	103.08	15.38	11.31	2.85	75530.15	18.00	16.63	1.19	152.96	13.14
05	15.28	97.67	14.41	11.14	2.71	76679.21	19.03	15.59	1.35	158.18	13.44
06	13.38	101.97	15.84	11.58	2.76	75021.51	17.93	15.64	1.15	159.90	13.65
07	16.26	103.61	16.04	11.25	2.75	76348.26	18.40	14.79	1.15	152.57	13.25
08	16.70	104.41	13.98	11.33	2.74	76164.68	18.66	17.30	1.14	152.02	13.34
09	16.20	107.29	11.47	11.38	2.79	76605.63	19.11	14.78	1.16	152.14	13.57
10	15.40	106.69	12.10	11.21	2.86	76960.97	19.19	15.24	1.19	153.04	13.43
11	16.44	105.89	13.15	11.15	2.82	76024.40	18.90	15.35	1.18	151.65	13.11
12	17.00	107.44	15.93	11.10	2.79	76678.34	18.23	13.60	1.16	150.75	13.01
13	14.98	111.12	13.81	11.30	2.79	77189.81	17.98	10.59	1.16	152.00	13.38
14	14.15	94.59	15.17	11.27	2.91	77132.81	17.48	14.65	1.21	170.92	13.86
15	14.28	92.71	15.28	11.16	3.05	76776.68	16.83	14.29	1.27	187.68	14.02
16	17.40	112.82	18.33	11.23	2.96	77078.84	18.14	14.67	1.23	155.51	13.40
17	17.06	111.83	14.54	11.23	2.94	76993.31	17.69	15.42	1.23	153.74	13.25
18	17.04	114.78	13.42	11.22	2.95	76661.10	17.54	15.30	1.23	152.17	13.09
19	16.51	110.75	15.65	10.91	2.93	79540.58	18.20	14.59	1.22	153.76	13.32
20	17.40	101.24	14.45	11.04	3.03	78830.89	17.71	16.84	1.26	166.70	13.72
21	14.46	89.19	19.92	10.94	3.07	79189.37	16.46	17.79	1.28	189.95	14.16
22	13.91	80.35	17.84	11.00	2.99	78725.40	16.78	13.72	1.25	190.12	14.22
23	14.57	89.38	19.54	10.95	3.04	78935.96	16.89	15.68	1.27	191.25	14.23
24	14.14	113.59	17.03	10.98	3.02	79199.54	17.08	15.71	1.26	188.42	14.27
25	14.14	109.18	14.43	10.85	2.97	79186.74	17.21	15.36	1.24	189.01	14.14
26	14.33	111.31	12.92	11.02	2.92	77889.43	16.41	15.86	1.22	188.93	13.99
27	17.20	115.02	12.00	11.60	2.91	76036.70	15.78	14.49	1.21	172.86	13.92
28	14.47	88.26	21.85	11.37	2.96	76837.06	14.94	9.78	1.23	190.06	14.09
29	13.46	78.13	14.97	11.07	2.99	78214.14	16.30	9.87	1.25	191.13	14.17
30	14.34	94.71	19.77	11.26	2.96	77428.90	15.99	12.67	1.23	188.72	14.17
31	13.56	117.75	15.78	11.11	2.92	78391.14	16.27	11.27	1.21	189.11	14.19
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	15.24	102.86	15.32	11.19	2.92	77115.53	17.28	14.57	1.22	171.38	13.70
最大值	17.40	117.75	21.85	11.60	3.07	79540.58	19.19	17.79	1.35	191.25	14.27
發生日期											
最小值	13.38	78.13	11.47	10.85	2.71	74674.88	14.94	9.78	1.14	150.75	13.01
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管