

連續自動監測紀錄月報表

中華民國110年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.28	57.19	6.11	10.76	1.68	80688.71	15.82	15.38	1.11	172.73	13.55
02	3.56	56.54	4.51	10.70	1.65	81329.07	16.15	15.46	1.10	173.45	13.63
03	3.63	58.09	3.39	10.64	1.65	81004.16	16.33	15.35	1.10	174.23	13.56
04	3.48	55.54	3.83	10.56	1.61	81352.65	17.04	15.49	1.07	174.67	13.63
05	3.28	55.79	3.47	10.53	1.62	82465.78	17.37	14.87	1.08	176.26	13.91
06	3.50	53.11	3.54	10.43	1.66	82870.41	17.58	16.51	1.11	175.55	13.83
07	3.44	54.90	3.76	10.48	1.67	83377.97	16.94	16.22	1.11	174.83	13.85
08	3.54	53.54	4.41	10.62	1.68	83777.27	16.54	15.55	1.12	174.63	14.03
09	3.65	55.15	5.77	10.73	1.72	83298.49	15.97	15.46	1.15	174.27	14.00
10	3.50	55.08	3.36	10.55	1.75	84389.96	16.65	15.56	1.17	175.56	14.09
11	3.26	56.65	2.82	10.64	1.75	81794.36	16.45	14.58	1.17	172.79	13.66
12	3.44	56.38	2.66	10.73	1.74	82129.67	16.18	15.15	1.16	174.16	13.83
13	3.60	53.57	5.73	10.70	1.73	79805.70	16.38	15.56	1.15	174.34	13.44
14	3.26	57.63	4.87	10.57	1.71	82646.38	17.01	15.53	1.14	174.15	13.84
15	3.52	59.72	6.60	10.54	1.71	82629.62	17.10	15.96	1.14	175.13	13.84
16	3.74	59.95	7.18	10.54	1.70	82213.80	16.70	15.50	1.14	174.01	13.67
17	3.98	62.57	6.36	10.61	1.66	81633.50	16.09	16.79	1.11	172.03	13.50
18	3.61	63.29	5.73	10.65	1.69	80834.83	15.68	15.40	1.13	170.79	13.32
19	3.69	63.67	6.54	10.70	1.75	80066.53	15.57	15.42	1.17	171.00	13.26
20	3.46	60.83	7.63	10.50	1.76	80334.29	16.65	15.64	1.17	172.23	13.25
21	3.20	60.37	7.87	10.33	1.73	81643.82	17.39	15.45	1.15	174.51	13.44
22	3.18	61.32	5.85	10.43	1.71	81011.86	17.69	16.01	1.14	174.98	13.52
23	3.59	61.33	8.78	10.68	1.66	79825.27	16.85	16.63	1.11	173.25	13.47
24	3.88	62.37	8.34	10.69	1.63	80578.49	15.92	16.16	1.08	172.99	13.44
25	3.85	63.20	4.74	10.55	1.65	81255.59	16.22	15.77	1.10	172.95	13.42
26	3.37	62.63	7.08	10.65	1.66	81509.55	16.54	16.20	1.11	174.61	13.71
27	3.37	60.05	6.23	10.49	1.70	82082.65	16.82	15.58	1.13	174.13	13.61
28	3.85	62.01	7.91	10.60	1.68	82789.83	15.99	16.47	1.12	173.94	13.75
29	3.53	62.27	5.48	10.57	1.67	83303.37	16.03	16.37	1.11	173.86	13.78
30	3.65	61.06	8.12	10.72	1.75	82055.51	15.80	16.50	1.16	174.57	13.75
31	3.51	60.86	6.28	10.72	1.75	82204.92	16.02	16.21	1.17	175.51	13.84
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.56	58.92	5.64	10.60	1.69	81835.61	16.50	15.77	1.13	173.94	13.66
最大值	4.28	63.67	8.78	10.76	1.76	84389.96	17.69	16.79	1.17	176.26	14.09
發生日期											
最小值	3.18	53.11	2.66	10.33	1.61	79805.70	15.57	14.58	1.07	170.79	13.25
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年1月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.96	61.99	6.51	11.29	1.78	78043.04	15.49	15.63	1.18	184.01	14.11
02	3.83	58.25	6.20	11.20	1.75	78018.37	15.92	16.00	1.17	181.49	13.95
03	3.68	56.07	5.25	11.22	1.76	76862.85	16.16	15.62	1.17	181.56	13.82
04	3.55	57.87	7.42	11.30	1.75	76554.60	16.55	15.84	1.17	182.94	13.98
05	3.34	56.90	5.72	11.23	1.74	77626.43	17.00	15.55	1.16	183.83	14.19
06	3.58	56.48	6.54	11.33	1.68	77209.78	16.76	15.94	1.12	183.67	14.20
07	3.66	52.83	5.21	11.42	1.67	78052.67	16.01	16.20	1.11	184.41	14.38
08	3.54	54.33	4.35	11.52	1.74	77895.82	15.69	13.58	1.16	183.15	14.40
09	3.74	54.41	4.25	11.47	1.77	78292.03	15.33	14.88	1.18	182.30	14.32
10	3.74	53.70	3.86	11.45	1.76	78718.68	15.68	14.86	1.17	183.76	14.46
11	3.47	58.32	4.13	11.74	1.74	76052.21	15.62	13.42	1.16	180.54	14.30
12	3.62	57.71	4.42	11.70	1.75	76984.95	15.58	15.00	1.16	182.63	14.48
13	3.74	53.42	4.91	11.58	1.80	77231.09	15.65	14.51	1.20	182.64	14.35
14	3.66	56.40	8.27	11.74	1.80	77267.92	15.38	13.96	1.20	182.78	14.57
15	4.07	58.03	7.41	11.58	1.74	76543.81	15.89	16.16	1.16	182.70	14.27
16	4.54	59.81	8.28	11.64	1.72	76050.57	15.39	15.74	1.15	183.47	14.21
17	4.81	60.94	7.77	11.76	1.66	76575.34	14.78	16.76	1.11	182.80	14.36
18	4.35	65.97	6.85	11.86	1.66	75885.31	14.73	15.43	1.11	183.09	14.39
19	4.41	61.72	8.00	11.89	1.76	75451.67	14.59	15.36	1.17	182.79	14.32
20	4.14	55.93	9.01	11.66	1.81	75314.81	15.30	15.50	1.21	182.67	14.06
21	4.14	55.55	10.06	11.52	1.83	76108.66	15.62	15.05	1.22	183.13	14.07
22	4.26	59.38	10.85	11.79	1.80	74303.99	15.74	14.67	1.20	182.63	14.14
23	4.53	61.52	10.16	11.85	1.72	75085.98	15.61	16.21	1.15	183.30	14.39
24	4.82	59.95	9.60	11.71	1.67	76705.33	14.80	16.47	1.11	183.40	14.35
25	4.79	62.21	8.72	11.70	1.66	76807.61	15.17	15.57	1.11	183.28	14.40
26	4.34	63.89	8.47	11.82	1.68	75736.36	15.22	16.56	1.12	185.21	14.45
27	4.36	63.16	7.84	11.86	1.68	75136.27	15.42	15.42	1.12	182.81	14.35
28	4.70	64.30	8.62	12.00	1.65	75718.00	14.60	15.80	1.10	184.18	14.62
29	4.58	61.41	8.23	11.97	1.64	75675.72	14.56	15.95	1.10	182.20	14.46
30	4.66	58.85	9.18	12.17	1.68	73047.89	14.51	16.00	1.12	181.29	14.24
31	4.65	60.34	7.84	12.25	1.75	72997.07	14.70	15.77	1.17	182.10	14.42
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.11	58.76	7.22	11.65	1.73	76385.64	15.47	15.46	1.15	182.93	14.29
最大值	4.82	65.97	10.85	12.25	1.83	78718.68	17.00	16.76	1.22	185.21	14.62
發生日期											
最小值	3.34	52.83	3.86	11.20	1.64	72997.07	14.51	13.42	1.10	180.54	13.82
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管