

連續自動監測紀錄月報表

中華民國106年01月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.71	85.48	25.64	14.10	2.27	66764.05	20.42	6.08	1.13	125.73	10.94
02	4.10	89.23	20.29	14.29	2.08	65089.62	20.03	6.17	1.04	124.74	10.93
03	5.02	87.59	20.26	14.26	2.07	65170.62	21.11	5.48	1.03	125.11	10.91
04	5.32	84.19	27.30	14.23	1.43	65643.92	20.83	6.42	0.72	125.38	10.95
05	5.55	89.14	24.23	14.27	1.62	65815.05	20.29	8.92	0.81	124.80	11.02
06	6.09	85.82	27.61	14.30	1.85	65231.76	20.84	10.38	0.92	125.14	10.98
07	5.83	84.01	33.65	14.28	2.12	65685.26	20.76	10.13	1.06	125.23	11.01
08	5.54	86.54	23.03	14.35	1.91	65036.68	20.69	8.11	0.96	124.20	10.98
09	4.90	90.15	23.73	14.36	1.38	65294.83	19.49	10.46	0.69	123.02	11.04
10	5.05	90.97	25.07	14.39	1.55	64499.04	20.10	8.25	0.77	123.57	10.96
11	7.40	88.09	26.50	14.33	1.35	64930.67	20.14	9.94	0.68	124.28	10.95
12	7.06	91.07	30.50	14.46	1.54	63935.40	19.93	12.16	0.77	124.30	10.99
13	3.34	85.98	26.97	14.53	0.61	62218.54	19.81	9.51	0.31	122.53	10.77
14	2.06	85.88	26.80	14.60	0.83	62710.93	18.23	10.83	0.42	121.00	10.93
15	2.17	84.75	25.62	14.48	0.74	63549.67	18.80	10.55	0.37	121.24	10.89
16	1.70	84.27	25.50	14.42	2.13	64122.07	19.34	8.01	1.06	121.40	10.9
17	4.47	89.17	24.93	14.53	2.81	61968.24	19.65	8.21	1.40	123.40	10.75
18	5.07	89.73	25.60	14.63	3.74	62109.71	19.04	9.36	1.87	123.20	10.96
19	6.14	84.45	27.10	14.55	4.12	63545.71	18.99	11.33	2.06	123.10	11.07
20	4.72	90.94	24.79	14.74	3.37	60888.16	17.85	12.90	1.68	120.10	11.02
21	5.82	80.78	31.29	14.58	3.35	62441.49	17.82	13.81	1.67	119.57	11
22	6.19	86.18	24.87	14.66	3.59	61410.94	17.99	13.49	1.80	119.97	10.97
23	5.54	80.78	25.58	14.60	3.24	62747.68	17.54	10.30	1.62	119.59	11.1
24	5.34	71.23	33.19	14.44	3.29	63920.43	17.89	8.45	1.64	119.76	11.03
25	5.03	65.44	49.35	14.32	3.41	63525.16	18.83	6.00	1.71	119.93	10.76
26	5.05	69.39	29.91	14.83	3.14	58761.65	18.48	6.69	1.57	119.03	10.77
27	7.66	76.76	30.07	15.03	3.25	56551.36	18.12	5.72	1.62	119.96	10.72
28	7.65	72.00	37.88	15.04	3.56	56170.50	18.96	5.91	1.78	120.32	10.69
29	7.64	66.03	41.36	15.17	3.66	54308.58	18.92	6.42	1.83	119.65	10.54
30	6.79	50.15	52.68	15.52	4.17	50888.14	18.24	4.69	2.09	116.59	10.43
31	6.77	28.64	66.69	15.61	3.57	49621.75	17.55	3.94	1.79	113.70	10.26
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	5.38	80.48	30.26	14.58	2.51	62082.50	19.25	8.67	1.25	121.92	10.88
最大值	7.66	91.07	66.69	15.61	4.17	66764.05	21.11	13.81	2.09	125.73	11.10
發生日期	27	12	31	31	30	1	3	21	30	1	23
最小值	1.70	28.64	20.26	14.10	0.61	49621.75	17.54	3.94	0.31	113.70	10.26
發生日期	16	31	3	1	13	31	23	31	13	31	31
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國106年01月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	8.21	70.97	15.82	12.76	2.53	74081.97	19.78	14.20	1.26	132.26	10.42
02	7.54	75.53	13.97	12.90	2.54	72711.50	18.62	10.46	1.27	131.35	10.39
03	6.86	69.95	14.36	12.83	2.61	72560.93	19.34	9.24	1.30	131.55	10.29
04	7.57	69.15	19.61	12.72	2.60	74509.75	19.92	11.11	1.30	132.35	10.45
05	7.75	72.44	17.01	12.77	2.61	73206.08	19.41	10.36	1.31	131.61	10.29
06	7.37	68.27	18.89	12.85	2.59	74761.06	19.42	10.99	1.29	131.58	10.63
07	7.97	72.62	25.99	13.00	2.61	74649.68	19.61	12.19	1.31	131.40	10.78
08	7.86	66.31	18.93	13.02	2.65	73750.55	18.85	12.06	1.32	129.94	10.7
09	8.34	75.94	15.62	13.18	2.63	72664.44	16.94	17.64	1.32	129.03	10.7
10	7.59	75.40	18.10	13.23	2.73	74065.44	17.50	15.28	1.37	129.29	10.98
11	8.60	74.11	28.51	13.35	2.73	71608.45	16.27	19.18	1.37	129.30	10.77
12	8.33	74.66	25.43	13.46	2.76	70956.04	16.19	16.46	1.38	129.72	10.87
13	7.13	76.79	21.52	13.65	2.61	69082.72	16.02	11.57	1.31	128.27	10.79
14	7.47	77.53	23.47	13.77	2.41	67792.31	14.14	16.81	1.20	127.32	10.74
15	7.08	75.59	20.19	13.73	2.65	69324.27	15.20	15.14	1.32	127.70	10.91
16	6.86	75.92	15.42	13.35	2.61	72511.80	16.89	14.08	1.31	127.58	10.86
17	7.54	76.38	21.68	13.57	2.73	72123.64	16.15	13.45	1.36	129.08	11.17
18	7.48	74.58	32.02	13.77	2.83	70206.07	14.83	12.58	1.41	128.85	11.18
19	7.58	73.91	23.88	13.77	2.84	70699.73	15.00	14.34	1.42	128.58	11.24
20	7.38	79.11	23.17	14.00	2.90	70069.41	14.01	15.19	1.45	126.66	11.42
21	7.41	71.68	26.07	14.18	2.75	69922.79	13.46	14.57	1.38	125.82	11.53
22	7.25	71.66	20.28	14.45	2.97	68143.46	13.09	14.21	1.48	125.16	11.69
23	7.46	57.20	34.56	14.82	3.23	59156.85	11.76	14.84	1.62	123.46	10.64
24	7.41	46.52	35.23	15.66	3.45	44338.95	9.46	15.58	1.72	121.35	9.23
25	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
26	8.73	68.41	27.88	13.47	3.00	72163.60	14.85	16.64	1.50	127.55	10.82
27	7.48	70.71	21.54	13.30	2.91	70987.91	14.71	12.36	1.46	128.37	10.43
28	8.10	64.69	25.31	13.01	2.84	71131.26	16.31	14.05	1.42	129.43	10.09
29	7.52	58.80	21.84	12.79	2.94	69152.60	17.25	11.95	1.47	128.99	9.53
30	6.58	64.56	18.01	12.76	2.77	72314.92	17.92	11.27	1.39	128.34	9.92
31	6.27	68.61	19.72	12.81	2.64	74187.50	17.93	11.57	1.32	128.00	10.22
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	7.56	70.60	22.13	13.43	2.76	70427.86	16.36	13.65	1.38	128.66	10.66
最大值	8.73	79.11	35.23	15.66	3.45	74761.06	19.92	19.18	1.72	132.35	11.69
發生日期	26	20	24	24	24	6	4	11	24	4	22
最小值	6.27	46.52	13.97	12.72	2.41	44338.95	9.46	9.24	1.20	121.35	9.23
發生日期	25	25	25	25	25	25	25	25	25	25	25
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管