

連續自動監測紀錄月報表

中華民國115年9月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.26	52.03	12.43	11.09	0.99	73348.17	20.03	5.99	0.76	198.61	14.14
02	2.05	51.81	11.65	11.04	0.97	73704.13	19.75	7.95	0.75	194.27	13.98
03	2.38	56.29	13.31	10.94	0.89	73754.54	19.66	7.67	0.69	186.67	13.60
04	1.16	55.32	10.64	10.69	0.92	76357.86	20.69	6.04	0.71	193.61	14.12
05	1.48	56.69	10.01	10.79	0.95	76016.87	20.27	7.20	0.74	192.29	14.09
06	1.68	55.08	9.45	10.79	0.93	76524.06	20.04	7.28	0.72	187.82	14.01
07	1.72	58.06	8.59	10.86	0.85	66615.01	19.62	6.84	0.66	170.34	12.31
08	1.67	54.89	9.11	10.88	1.00	75755.76	19.43	5.72	0.77	196.78	14.14
09	1.85	56.18	10.04	10.83	1.00	75803.59	19.38	6.83	0.77	193.87	14.00
10	2.36	57.02	9.05	10.99	1.02	75194.02	19.13	7.61	0.78	186.99	13.85
11	1.79	53.97	11.43	11.08	1.01	75596.54	19.38	7.50	0.78	194.28	14.33
12	1.64	56.00	10.60	11.03	1.02	74220.66	19.70	6.53	0.79	193.17	14.02
13	2.51	56.11	9.53	11.12	0.98	72823.78	19.19	6.31	0.75	187.80	13.62
14	3.11	57.72	10.10	11.04	1.01	73270.31	19.11	7.74	0.78	191.88	13.70
15	1.71	53.37	11.94	11.10	1.04	74200.38	19.31	6.93	0.80	196.78	14.15
16	2.09	55.24	10.62	11.07	1.00	74813.44	18.80	7.90	0.77	193.73	14.05
17	2.24	57.03	9.57	11.07	1.00	73610.01	18.52	8.06	0.77	187.23	13.57
18	1.81	52.39	12.15	11.01	0.98	74789.11	19.30	7.67	0.76	195.85	14.10
19	1.84	47.80	12.04	10.91	0.97	75399.70	19.09	8.01	0.75	198.59	14.07
20	1.72	49.36	13.25	11.10	0.95	73772.86	18.95	8.04	0.73	191.73	13.86
21	1.62	53.63	11.26	11.07	0.93	73706.63	18.97	7.84	0.72	195.25	13.91
22	1.78	55.05	14.30	11.14	0.91	74161.98	18.78	8.12	0.70	198.92	14.18
23	2.18	50.94	15.45	11.25	0.94	73022.90	18.27	8.51	0.72	194.45	13.89
24	2.27	52.52	13.16	11.43	0.96	72677.51	18.32	8.09	0.74	190.16	13.96
25	1.16	50.20	10.82	11.08	0.95	74169.64	19.63	7.16	0.73	196.41	14.16
26	1.16	45.28	11.38	11.18	0.96	73903.00	19.46	7.77	0.74	194.95	14.17
27	1.21	45.22	12.42	11.49	0.97	71886.86	19.07	6.95	0.74	191.08	14.05
28	1.11	45.18	12.08	11.36	0.97	71736.87	19.08	5.97	0.74	195.04	13.96
29	0.58	45.58	10.52	11.35	0.98	72411.55	19.47	4.36	0.76	200.89	14.31
30	0.47	41.97	10.72	11.27	0.97	71629.24	19.92	5.67	0.75	196.43	13.99
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.72	52.60	11.25	11.07	0.97	73829.23	19.34	7.14	0.75	192.86	13.94
最大值	3.11	58.06	15.45	11.49	1.04	76524.06	20.69	8.51	0.80	200.89	14.33
發生日期											
最小值	0.47	41.97	8.59	10.69	0.85	66615.01	18.27	4.36	0.66	170.34	12.31
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年9月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H2O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.51	53.94	14.06	11.02	1.12	70591.25	21.42	5.46	0.86	202.69	13.37
02	1.77	52.77	17.42	10.82	1.08	71793.16	21.12	6.75	0.83	198.20	13.14
03	2.03	52.16	18.10	10.48	1.06	72900.21	21.20	6.19	0.81	188.90	12.67
04	0.98	49.41	14.80	10.53	1.10	74009.60	22.13	5.32	0.84	196.53	13.29
05	1.32	48.38	17.47	10.55	1.10	74429.37	21.58	5.47	0.85	196.05	13.30
06	1.84	50.35	15.82	10.45	1.10	74742.42	21.46	6.48	0.84	189.84	13.02
07	1.62	52.05	12.48	10.59	1.03	66539.87	20.90	5.57	0.79	174.44	11.82
08	1.38	54.90	12.41	10.62	1.14	74061.79	20.93	4.91	0.88	200.38	13.32
09	1.59	53.53	14.29	10.65	1.10	74446.73	20.91	5.53	0.84	199.32	13.40
10	2.29	51.25	15.39	10.54	1.06	73918.31	20.71	5.40	0.82	189.51	12.86
11	1.49	48.78	15.67	10.57	1.07	73182.93	21.31	4.57	0.82	195.62	13.03
12	1.67	52.02	16.71	10.63	1.06	72474.84	21.30	6.01	0.81	195.95	12.99
13	2.12	56.96	16.38	10.81	1.09	72686.80	20.86	5.54	0.83	192.48	13.10
14	2.19	54.63	14.72	10.68	1.11	73090.30	20.69	5.55	0.85	196.96	13.09
15	1.34	52.70	16.04	10.79	1.07	73328.98	20.88	6.15	0.82	202.23	13.45
16	1.51	52.53	14.56	10.63	1.04	74846.11	20.46	6.74	0.80	199.34	13.38
17	1.85	59.18	15.64	10.72	1.03	73720.62	19.98	6.88	0.79	191.87	12.99
18	1.34	54.12	14.98	10.64	1.05	74012.93	20.81	6.49	0.81	200.46	13.33
19	1.06	40.78	16.63	10.54	1.05	73511.54	20.66	6.13	0.81	198.44	13.02
20	1.05	45.75	17.89	10.57	1.05	74633.78	20.58	6.83	0.81	193.87	13.14
21	1.04	55.29	12.28	10.50	1.09	74373.74	20.33	6.75	0.84	198.10	13.07
22	0.95	52.82	14.87	10.63	1.12	74372.58	20.12	6.92	0.86	202.30	13.32
23	1.27	48.77	15.46	10.62	1.24	73227.21	20.03	6.67	0.92	197.22	12.95
24	1.49	51.38	13.86	10.86	1.24	73392.95	19.76	5.91	0.96	191.35	13.08
25	0.78	50.16	12.69	10.63	1.18	73861.06	20.98	5.23	0.91	197.77	13.24
26	0.85	49.27	13.08	10.67	1.16	73938.26	20.85	5.60	0.89	198.73	13.31
27	1.10	44.07	14.12	10.85	1.15	72112.96	20.70	4.80	0.89	192.00	13.00
28	1.13	43.82	14.24	10.75	1.15	71302.36	20.54	4.39	0.88	195.25	12.78
29	0.76	48.80	12.82	10.90	1.11	71910.63	20.66	3.20	0.85	202.81	13.33
30	0.72	49.03	11.84	10.62	1.03	72250.90	21.50	4.54	0.80	199.53	13.07
監測日數	30	51	30	30	30	30	30	30	30	30	30
平均值	1.40	50.99	14.89	10.66	1.10	73122.14	20.85	5.73	0.84	195.94	13.10
最大值	2.29	59.18	18.10	11.02	1.24	74846.11	22.13	6.92	0.96	202.81	13.45
發生日期											
最小值	0.72	40.78	11.84	10.45	1.03	66539.87	19.76	3.20	0.79	174.44	11.82
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管