

# 連續自動監測紀錄月報表

中華民國112年11月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	2.56	42.58	8.39	11.61	1.13	73394.09	14.82	8.38	0.87	180.37	13.49
02	2.49	44.62	8.56	11.56	1.15	73388.53	14.79	9.02	0.88	180.41	13.41
03	2.47	43.33	9.65	11.64	1.16	73077.96	14.92	8.73	0.89	180.95	13.50
04	2.40	42.70	9.11	11.74	1.16	72456.51	14.75	8.33	0.89	180.76	13.51
05	2.59	42.62	8.14	11.80	1.18	72580.78	14.87	8.74	0.91	181.32	13.66
06	2.48	42.95	8.94	11.75	1.19	72277.70	14.61	8.58	0.92	180.59	13.45
07	2.73	44.95	7.76	11.90	1.17	72405.72	14.07	8.57	0.91	182.81	13.68
08	2.83	43.72	9.21	12.01	1.22	70967.56	14.06	8.65	0.94	181.23	13.52
09	2.46	45.93	8.50	11.95	1.26	70046.99	14.36	8.69	0.97	179.48	13.27
10	2.50	42.75	9.46	11.96	1.23	71207.92	14.45	8.27	0.95	181.19	13.56
11	3.00	37.56	9.78	12.15	1.22	70541.34	13.97	8.79	0.94	179.90	13.60
12	2.78	38.45	8.84	12.07	1.17	71226.95	14.05	8.52	0.90	180.29	13.64
13	2.82	45.89	8.51	12.08	1.07	72079.91	13.76	8.63	0.82	180.47	13.78
14	2.98	44.69	9.10	12.12	1.11	71809.86	13.59	8.46	0.85	181.04	13.78
15	3.35	45.71	10.22	11.97	1.14	72484.23	13.69	8.61	0.88	180.63	13.69
16	2.95	48.30	9.13	11.49	1.17	75259.60	14.50	8.35	0.90	180.45	13.61
17	2.66	49.25	8.10	11.41	1.16	77291.14	14.14	8.60	0.89	180.70	13.83
18	2.32	46.19	7.47	11.23	1.18	78326.43	14.51	8.27	0.91	179.87	13.77
19	2.21	46.06	8.89	11.20	1.24	78522.47	14.63	8.71	0.96	181.40	13.84
20	1.79	47.61	7.79	11.21	1.22	77635.09	15.32	8.42	0.94	182.17	13.81
21	2.14	49.04	9.52	11.37	1.23	76289.58	15.08	8.57	0.95	182.14	13.76
22	2.66	48.62	9.37	11.45	1.21	74805.31	14.41	8.84	0.93	180.63	13.47
23	2.80	47.61	9.30	11.52	1.20	75007.55	14.18	8.67	0.93	179.31	13.52
24	2.99	49.70	9.95	11.74	1.22	74506.60	13.71	9.33	0.94	180.15	13.72
25	2.79	46.95	9.97	11.74	1.25	73791.44	13.76	8.87	0.96	179.08	13.55
26	2.48	45.48	9.69	11.55	1.27	74895.70	14.52	8.90	0.98	180.14	13.63
27	2.20	48.75	9.27	11.72	1.27	74217.48	14.56	8.54	0.98	182.36	13.82
28	2.72	48.71	9.19	11.95	1.25	72961.32	13.72	8.62	0.97	181.30	13.77
29	2.60	48.44	10.13	12.04	1.24	71563.76	13.73	8.98	0.96	181.57	13.64
30	2.55	47.84	7.80	12.05	1.23	71520.42	13.69	8.87	0.95	181.06	13.63
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.61	45.57	8.99	11.73	1.20	73551.33	14.31	8.65	0.92	180.79	13.63
最大值	3.35	49.70	10.22	12.15	1.27	78522.47	15.32	9.33	0.98	182.81	13.84
發生日期											
最小值	1.79	37.56	7.47	11.20	1.07	70046.99	13.59	8.27	0.82	179.08	13.27
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國112年11月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO <sub>2</sub> 二氧化硫	NO <sub>x</sub> 氮氧化物	CO 一氧化碳	O <sub>2</sub> 氧氣	DUST 粉塵濃度	MASS 排放流率	H <sub>2</sub> O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	2.78	42.54	8.72	11.36	1.02	80220.32	16.03	7.89	0.78	194.38	15.02
02	2.55	41.54	9.12	11.22	1.01	80743.04	15.83	7.37	0.78	193.31	14.84
03	2.98	40.06	10.30	11.13	1.02	81640.03	16.73	6.65	0.78	194.91	15.08
04	3.32	40.74	9.29	11.39	1.06	80112.40	16.17	6.77	0.82	193.76	15.07
05	3.18	41.98	9.27	11.40	1.08	80091.79	16.54	6.71	0.83	194.40	15.15
06	3.45	41.66	9.24	11.38	1.06	80260.13	16.06	6.04	0.81	193.36	15.03
07	3.75	43.31	8.98	11.58	1.06	79749.23	15.53	5.41	0.81	192.90	15.15
08	4.48	42.91	10.10	11.56	1.10	79401.32	15.73	5.75	0.85	192.63	15.07
09	4.30	43.15	10.32	11.68	1.12	78040.66	15.51	7.58	0.86	192.12	14.96
10	4.17	44.48	10.33	11.65	1.11	78746.98	15.81	7.69	0.85	193.01	15.13
11	3.89	43.90	10.13	11.60	1.04	79901.88	15.94	8.35	0.80	192.09	15.26
12	4.25	41.97	10.22	11.81	1.02	78593.59	15.47	6.54	0.78	191.56	15.25
13	3.70	44.90	10.00	11.79	0.97	79273.78	15.37	5.51	0.75	191.00	15.31
14	3.45	42.66	9.30	11.41	0.95	80772.89	16.22	6.54	0.74	190.71	15.12
15	5.13	42.91	10.00	11.46	0.99	80341.31	15.61	7.58	0.76	189.77	15.00
16	3.48	45.45	9.69	11.36	1.04	80984.21	16.14	6.80	0.80	191.23	15.09
17	4.36	47.07	10.12	11.56	1.13	80885.39	15.34	8.17	0.87	190.74	15.24
18	4.00	44.29	10.06	11.44	1.20	81842.26	15.42	7.85	0.93	190.67	15.24
19	3.92	41.30	9.56	11.44	1.23	81398.78	15.59	8.01	0.95	190.69	15.18
20	3.56	40.74	10.15	11.25	1.24	82197.93	16.26	7.36	0.96	191.29	15.17
21	3.67	42.11	9.29	11.50	1.24	79935.44	16.26	8.09	0.96	191.62	15.15
22	4.37	41.93	9.36	11.64	1.23	79225.15	15.54	7.91	0.95	190.63	15.07
23	4.46	45.04	9.77	11.69	1.20	79407.78	14.93	8.19	0.93	190.60	15.09
24	5.43	45.17	10.95	11.86	1.18	78943.17	14.61	10.32	0.90	189.66	15.19
25	4.57	44.64	10.44	11.87	1.16	78555.30	14.75	8.59	0.89	189.57	15.16
26	4.26	41.05	10.33	11.50	1.16	80619.50	15.88	8.08	0.90	189.94	15.17
27	3.50	43.80	10.00	11.58	1.19	79954.58	15.82	6.60	0.92	191.16	15.18
28	3.95	44.49	9.01	11.70	1.18	79582.26	15.35	6.54	0.90	190.55	15.20
29	4.21	43.31	10.58	11.58	1.19	78990.57	15.47	8.18	0.92	189.87	14.91
30	4.18	44.26	8.94	11.57	1.20	79569.76	15.50	9.22	0.93	189.62	15.00
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.91	43.11	9.79	11.53	1.11	79999.38	15.71	7.41	0.86	191.59	15.12
最大值	5.43	47.07	10.95	11.87	1.24	82197.93	16.73	10.32	0.96	194.91	15.31
發生日期											
最小值	2.55	40.06	8.72	11.13	0.95	78040.66	14.61	5.41	0.74	189.57	14.84
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管