

# 連續自動監測紀錄月報表

中華民國109年10月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	4.39	70.37	5.56	9.97	2.21	82038.32	17.39	14.80	0.92	178.22	13.16
02	3.64	68.90	4.12	9.78	2.21	82129.58	18.12	8.68	0.92	178.80	13.09
03	3.98	67.32	4.17	9.79	2.21	81965.97	17.87	8.51	0.92	179.13	13.05
04	4.20	68.78	5.25	9.68	2.24	82378.93	18.06	9.46	0.93	179.21	13.01
05	4.22	68.64	5.02	9.74	2.23	83150.96	18.02	8.36	0.93	178.58	13.18
06	4.44	69.13	4.70	10.00	2.42	81612.03	17.48	7.61	1.01	178.14	13.15
07	4.83	69.78	3.89	10.06	2.57	80956.45	16.97	10.02	1.07	178.30	13.04
08	4.66	69.27	4.14	10.09	2.58	80943.18	16.84	9.50	1.07	178.77	13.08
09	4.84	71.67	5.55	10.11	2.56	81539.18	17.01	11.60	1.07	178.93	13.22
10	4.49	70.81	4.16	9.95	2.54	81219.61	17.42	8.71	1.06	177.75	13.02
11	4.80	70.08	4.85	9.99	2.52	81537.35	17.54	11.64	1.05	179.07	13.16
12	4.50	68.17	4.15	9.76	2.55	82642.26	18.43	10.89	1.06	179.94	13.23
13	4.94	69.42	5.68	9.86	2.59	82559.14	17.86	12.40	1.08	179.57	13.24
14	5.30	68.72	4.86	9.96	2.62	81436.03	17.09	14.31	1.09	177.49	12.99
15	4.71	68.71	4.21	9.79	2.61	82369.95	17.75	12.77	1.09	178.50	13.08
16	5.11	68.67	6.74	9.98	2.64	80976.96	17.51	13.93	1.10	177.48	13.02
17	4.89	68.85	7.00	9.82	2.57	82334.80	18.02	14.56	1.07	177.36	13.12
18	4.94	69.32	6.52	9.97	2.51	81145.98	17.31	15.29	1.04	176.29	12.97
19	4.04	66.35	5.81	10.14	2.49	79625.68	17.08	11.97	1.04	175.95	12.88
20	4.44	60.78	5.86	10.14	2.54	80319.72	17.19	12.75	1.06	176.32	13.01
21	4.71	59.88	6.44	9.92	2.60	81773.27	17.50	14.74	1.08	177.37	13.07
22	4.55	60.36	5.32	9.84	2.51	82763.25	17.64	15.47	1.04	177.56	13.15
23	4.48	61.82	4.49	10.16	2.47	81840.54	17.13	15.09	1.03	178.46	13.33
24	5.03	63.00	5.12	10.14	2.50	82310.97	16.99	17.09	1.04	178.67	13.37
25	5.22	62.00	5.54	10.19	2.57	81427.53	16.91	16.58	1.07	178.34	13.28
26	4.52	61.71	3.87	10.02	2.62	81827.41	17.06	16.40	1.09	177.98	13.14
27	4.70	61.19	5.70	10.09	2.61	81189.80	17.03	16.25	1.09	177.84	13.12
28	4.62	60.87	4.77	9.95	2.62	81305.14	17.30	16.99	1.09	177.69	13.00
29	4.78	58.73	6.89	9.90	2.57	81590.64	17.00	16.49	1.07	177.29	12.93
30	4.85	62.09	7.09	10.29	2.51	81139.79	16.64	17.30	1.05	176.46	13.25
31	5.51	59.87	7.02	10.30	2.49	81198.63	16.14	16.75	1.04	174.23	13.13
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.66	65.98	5.31	9.98	2.50	81653.20	17.36	13.13	1.04	177.93	13.11
最大值	5.51	71.67	7.09	10.30	2.64	83150.96	18.43	17.30	1.10	179.94	13.37
發生日期											
最小值	3.64	58.73	3.87	9.68	2.21	79625.68	16.14	7.61	0.92	174.23	12.88
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

