

連續自動監測紀錄月報表

中華民國112年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.04	53.98	6.57	10.52	1.88	77084.94	16.77	12.24	1.25	179.11	12.97
02	2.81	51.51	5.58	10.36	1.90	77558.27	17.33	11.93	1.26	179.81	12.95
03	2.89	54.32	7.46	10.60	1.85	77967.61	16.77	11.93	1.23	181.32	13.27
04	2.86	51.72	6.71	10.38	1.86	78754.41	16.93	12.14	1.25	180.67	13.17
05	2.81	45.80	7.33	9.88	1.96	80292.79	17.30	12.80	1.31	180.35	12.85
06	2.66	49.68	8.34	9.95	1.92	80357.23	17.45	12.64	1.28	180.51	12.95
07	2.94	51.07	8.02	10.19	1.91	80317.46	16.47	12.65	1.27	181.20	13.10
08	2.57	50.16	6.80	10.15	1.98	80861.54	16.93	12.36	1.32	183.19	13.28
09	2.66	49.44	6.20	10.03	1.94	80028.44	16.83	12.53	1.29	181.52	12.92
10	2.99	51.31	6.96	10.01	1.94	81704.73	17.04	12.58	1.30	182.78	13.24
11	2.88	50.66	8.14	10.13	1.97	81697.06	16.82	12.76	1.32	184.03	13.39
12	3.03	50.37	7.71	10.21	1.94	81352.26	16.34	12.88	1.30	183.66	13.34
13	3.15	52.41	7.68	10.27	1.93	80867.14	16.46	15.48	1.28	183.71	13.37
14	2.96	51.99	7.21	10.28	1.90	80323.59	16.34	12.86	1.27	183.00	13.24
15	3.47	55.55	4.53	10.84	1.82	80870.35	15.03	12.90	1.21	185.16	13.92
16	3.48	55.86	5.82	11.02	1.81	80853.81	14.12	12.37	1.21	187.43	14.08
17	2.99	53.79	5.80	10.62	1.84	81504.88	15.38	13.01	1.23	185.84	13.80
18	3.34	51.95	6.68	10.43	1.80	81712.30	15.60	13.10	1.20	184.36	13.58
19	3.39	50.19	6.68	10.50	1.90	80108.62	15.21	13.11	1.26	183.27	13.31
20	3.96	53.50	7.41	10.62	1.91	79379.48	14.77	13.05	1.27	181.16	13.21
21	4.23	52.22	6.68	10.50	1.90	79875.41	14.81	12.86	1.26	181.10	13.14
22	3.72	52.06	6.55	10.29	1.88	80885.30	15.55	12.73	1.25	181.77	13.18
23	3.29	53.27	6.02	10.30	1.83	79836.48	15.55	12.28	1.22	180.63	12.99
24	3.24	56.87	5.63	10.54	1.82	81616.21	14.92	10.96	1.21	182.12	13.53
25	2.56	56.20	5.31	10.47	1.88	83246.19	16.03	9.60	1.25	184.62	13.96
26	2.76	53.81	5.62	10.36	1.98	82830.49	16.24	8.80	1.32	184.70	13.80
27	3.02	54.51	5.67	10.35	2.00	83523.24	16.43	9.26	1.34	185.11	13.94
28	3.51	55.87	5.04	10.54	1.96	82905.71	15.60	9.61	1.31	184.47	13.92
29	3.66	54.76	5.39	10.52	1.95	82182.04	15.39	10.29	1.30	184.23	13.74
30	3.16	53.89	6.13	10.85	2.00	79793.97	8.55	8.55	1.34	185.35	13.91
31	3.73	53.29	6.12	10.68	2.04	80292.65	15.61	9.58	1.37	184.24	13.67
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.15	52.65	6.51	10.40	1.91	80664.02	15.82	11.93	1.27	182.92	13.41
最大值	4.23	56.87	8.34	11.02	2.04	83523.24	17.45	15.48	1.37	187.43	14.08
發生日期											
最小值	2.56	45.80	4.53	9.88	1.80	77084.94	8.55	8.55	1.20	179.11	12.85
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年1月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.15	54.39	7.23	11.21	1.66	79125.70	17.14	11.45	1.11	195.51	14.81
02	2.79	57.71	6.56	11.18	1.67	78838.50	17.34	11.36	1.11	195.52	14.75
03	2.92	55.84	7.04	11.30	1.68	79112.82	17.02	11.37	1.12	196.75	14.97
04	3.23	55.27	7.61	11.26	1.63	79043.12	16.88	12.22	1.09	195.87	14.88
05	3.29	56.69	6.59	11.11	1.66	80688.00	17.18	12.18	1.11	197.06	15.01
06	2.84	57.71	7.56	11.27	1.69	80129.36	16.98	12.77	1.13	196.34	15.09
07	3.26	58.42	7.08	11.11	1.66	81713.68	16.53	13.25	1.10	195.39	15.03
08	2.73	55.32	7.76	11.11	1.69	81256.63	17.03	12.71	1.13	195.93	15.05
09	3.11	50.06	8.70	10.94	1.77	81358.72	17.02	12.73	1.18	194.39	14.77
10	3.10	53.80	7.43	11.20	1.80	80284.27	16.93	12.57	1.20	194.67	14.95
11	3.19	53.40	7.79	11.25	1.74	80114.79	16.79	12.50	1.16	195.43	15.00
12	3.50	53.20	6.79	11.26	1.72	80169.51	16.20	12.64	1.15	194.63	14.89
13	3.64	54.31	7.02	11.29	1.70	79293.49	16.34	13.13	1.14	193.60	14.77
14	3.35	55.49	6.63	11.42	1.68	78459.05	16.46	13.02	1.12	193.88	14.85
15	3.64	55.96	5.42	11.35	1.65	80547.34	15.94	13.15	1.10	192.96	15.00
16	3.76	57.84	7.25	11.40	1.68	80998.11	15.16	12.78	1.13	193.35	15.04
17	3.63	58.38	7.40	11.50	1.70	80255.47	15.53	13.58	1.13	195.09	15.18
18	3.41	58.11	7.31	11.41	1.64	80395.71	15.89	13.41	1.09	194.36	15.10
19	3.91	55.36	7.59	11.30	1.64	80589.55	15.62	13.26	1.09	193.03	14.90
20	4.57	58.13	7.37	11.48	1.65	79852.79	15.21	13.44	1.10	193.06	14.96
21	4.73	53.60	9.28	11.41	1.68	79874.46	15.18	13.96	1.12	195.09	14.91
22	5.30	53.71	8.85	11.32	1.71	79675.19	15.67	12.78	1.14	194.85	14.80
23	4.46	56.24	6.35	11.32	1.71	79710.38	15.94	10.69	1.14	193.26	14.81
24	3.82	59.27	6.74	11.44	1.76	81853.67	15.13	10.99	1.17	193.45	15.26
25	2.77	60.72	7.00	11.35	1.81	83253.96	16.25	8.61	1.21	195.42	15.65
26	3.50	58.52	6.68	11.34	1.84	82369.79	16.33	7.00	1.22	195.84	15.50
27	3.79	57.97	7.15	11.26	1.78	83226.28	16.42	7.62	1.18	196.01	15.56
28	3.95	60.15	7.26	11.34	1.72	83796.47	15.90	7.80	1.15	195.64	15.67
29	4.77	56.92	8.07	11.38	1.76	83117.50	15.64	10.15	1.18	195.13	15.55
30	3.52	58.76	7.52	11.26	1.80	83446.97	16.37	7.75	1.20	195.92	15.59
31	4.09	58.34	7.94	11.36	1.76	82472.38	15.94	8.18	1.21	195.40	15.46
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.60	56.44	7.32	11.29	1.71	80807.21	16.26	11.58	1.14	194.93	15.09
最大值	5.30	60.72	9.28	11.50	1.84	83796.47	17.34	13.96	1.22	197.06	15.67
發生日期											
最小值	2.73	50.06	5.42	10.94	1.63	78459.05	15.13	7.00	1.09	192.96	14.75
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管