

連續自動監測紀錄月報表

中華民國109年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	6.19	61.85	6.38	10.89	2.26	82929.17	16.90	11.64	0.94	176.26	14.37
02	6.13	62.14	6.08	10.69	2.24	82956.33	16.94	12.60	0.93	175.82	14.10
03	6.06	62.40	5.47	10.80	2.45	81848.22	16.97	13.77	1.02	174.83	14.02
04	5.87	61.91	8.46	10.87	2.73	81576.77	16.46	14.23	1.14	174.39	13.99
05	5.71	61.17	6.05	10.76	2.75	81733.34	17.00	14.27	1.14	174.93	13.96
06	5.30	58.64	5.95	10.52	2.75	82805.71	17.53	14.16	1.15	174.81	13.91
07	5.34	60.94	5.88	10.81	2.77	81232.76	16.95	14.42	1.15	174.66	13.93
08	4.65	56.70	6.48	10.92	2.74	80962.88	16.72	14.34	1.14	173.48	13.97
09	5.46	60.14	6.80	10.75	2.76	82019.70	16.69	14.60	1.15	173.15	13.89
10	5.80	59.55	6.31	10.80	2.74	81762.66	16.79	14.73	1.14	174.41	13.99
11	5.96	63.62	7.66	11.02	2.71	81487.72	16.00	14.88	1.13	174.50	14.11
12	6.19	63.41	6.83	10.85	2.65	83094.78	15.73	14.87	1.10	173.54	14.07
13	5.80	63.17	4.29	10.89	2.73	81413.05	16.23	14.28	1.14	172.63	13.89
14	5.82	63.11	6.13	10.86	2.73	82063.24	16.40	13.98	1.14	175.66	14.09
15	6.13	63.77	7.23	10.93	2.77	82607.72	16.27	14.44	1.15	176.03	14.26
16	6.05	63.62	9.41	10.74	2.80	83070.31	16.27	14.64	1.17	176.30	14.10
17	5.99	63.91	8.50	10.84	2.78	83396.81	16.45	14.67	1.16	176.25	14.31
18	6.17	63.62	11.99	10.94	2.78	83601.29	15.55	15.26	1.16	175.50	14.32
19	5.81	63.51	11.88	10.86	2.82	83561.70	16.02	15.17	1.18	175.78	14.29
20	5.66	63.80	9.52	10.91	2.76	82979.44	16.14	14.63	1.15	175.48	14.25
21	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
22	7.33	69.17	11.88	11.36	2.56	82346.22	14.73	16.13	1.07	176.42	14.60
23	6.44	64.77	10.01	11.23	2.60	82385.29	15.49	15.05	1.08	175.27	14.50
24	6.22	64.86	9.97	11.10	2.59	82137.67	15.85	14.43	1.08	174.89	14.32
25	6.40	65.59	9.75	10.94	2.60	83294.05	16.04	14.37	1.08	176.77	14.39
26	6.27	66.46	6.25	10.92	2.61	84027.47	16.20	14.71	1.09	176.92	14.52
27	6.09	68.23	3.83	11.08	2.66	82779.28	15.23	14.26	1.11	174.90	14.29
28	5.33	64.17	4.45	11.08	2.72	82354.37	15.83	12.25	1.13	176.20	14.37
29	5.15	63.58	4.87	11.08	2.66	82882.62	16.64	11.96	1.11	174.70	14.55
30	4.92	63.43	5.04	10.81	2.65	85261.51	17.27	11.72	1.11	176.70	14.75
31	5.06	63.42	5.71	10.89	2.71	85097.52	16.59	14.19	1.13	176.54	14.71
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	5.84	63.16	7.30	10.90	2.67	82655.65	16.33	14.16	1.11	175.26	14.23
最大值	7.33	69.17	11.99	11.36	2.82	85261.51	17.53	16.13	1.18	176.92	14.75
發生日期											
最小值	4.65	56.70	3.83	10.52	2.24	80962.88	14.73	11.64	0.93	172.63	13.89
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國109年1月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	5.54	64.20	7.58	11.22	2.81	79373.09	16.47	12.74	1.17	188.58	14.55
02	5.54	63.66	7.27	11.12	2.87	78466.79	16.31	12.52	1.19	186.24	14.12
03	5.20	63.65	9.52	11.18	2.81	78262.40	16.25	13.95	1.17	187.58	14.22
04	4.99	63.91	10.40	11.22	2.63	77987.17	15.97	14.02	1.10	186.61	14.15
05	4.99	63.20	8.25	11.16	2.55	78104.74	16.25	14.08	1.06	188.41	14.19
06	4.51	63.37	7.63	11.09	2.57	78635.28	16.59	13.64	1.07	188.44	14.24
07	4.88	64.19	8.16	11.38	2.50	77676.23	16.11	14.10	1.04	187.43	14.38
08	5.47	66.37	8.49	11.37	2.55	78296.23	15.61	14.33	1.06	185.64	14.33
09	5.18	64.58	8.88	11.36	2.58	78315.10	15.47	14.66	1.08	185.52	14.29
10	3.97	64.09	9.79	11.71	2.65	77665.46	15.62	14.75	1.10	185.33	14.73
11	5.41	65.88	9.68	11.45	2.75	77574.26	15.52	15.06	1.14	184.82	14.27
12	5.52	65.76	8.19	11.33	2.74	79064.28	15.06	14.90	1.14	183.33	14.24
13	5.02	65.51	8.48	11.38	2.70	78574.84	15.43	14.75	1.12	183.00	14.28
14	4.98	66.23	7.31	11.37	2.66	78741.87	15.66	10.76	1.11	186.20	14.44
15	5.13	65.82	10.22	11.30	2.68	80427.68	15.31	14.71	1.12	192.65	14.80
16	5.46	65.68	7.79	11.47	2.76	78385.70	14.93	15.02	1.15	185.92	14.40
17	5.27	66.81	8.04	11.49	2.77	79179.40	15.09	14.71	1.16	187.37	14.64
18	5.38	65.21	10.72	11.53	2.86	79376.39	14.23	15.26	1.19	184.14	14.50
19	5.37	64.24	10.40	11.50	2.91	79555.54	14.64	15.02	1.21	184.75	14.56
20	6.95	63.80	10.21	11.30	2.82	80236.03	14.13	14.40	1.18	180.07	14.17
21	5.45	66.05	8.78	11.25	2.83	80840.55	14.83	14.85	1.18	181.20	14.35
22	6.33	66.86	12.76	11.39	2.82	78864.95	14.38	15.71	1.17	182.35	14.16
23	5.81	63.79	9.93	11.44	2.79	77061.39	14.90	15.42	1.16	181.58	13.97
24	5.55	65.53	9.83	11.39	2.75	77715.48	15.10	15.75	1.15	184.47	14.14
25	5.33	65.16	9.56	11.17	2.77	79353.48	15.77	14.88	1.15	186.29	14.27
26	5.45	65.58	9.91	11.26	2.67	79037.56	14.89	14.99	1.11	184.01	14.12
27	5.43	66.07	9.35	11.52	2.68	78223.23	14.11	14.52	1.12	182.35	14.18
28	4.53	65.33	8.52	11.40	2.65	78271.11	15.11	13.32	1.10	181.92	14.17
29	3.78	65.17	9.69	11.27	2.77	80797.32	16.46	11.40	1.15	186.73	14.82
30	4.16	64.16	8.85	11.36	2.87	80759.34	15.72	11.81	1.19	185.84	14.79
31	4.33	64.59	10.08	11.28	2.89	81754.61	15.82	13.61	1.20	185.23	14.86
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	5.19	64.98	9.17	11.34	2.73	78921.85	15.41	14.18	1.14	185.29	14.37
最大值	6.95	66.86	12.76	11.71	2.91	81754.61	16.59	15.75	1.21	192.65	14.86
發生日期											
最小值	3.78	63.20	7.27	11.09	2.50	77061.39	14.11	10.76	1.04	180.07	13.97
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管