

連續自動監測紀錄月報表

中華民國114年06月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.22	49.23	11.97	9.82	1.26	79409.63	21.48	8.04	0.97	185.32	13.44
02	1.21	48.92	11.95	9.58	1.24	79429.91	21.73	8.00	0.96	183.92	13.17
03	1.38	48.58	13.04	9.93	1.24	79174.71	20.76	7.73	0.96	183.22	13.37
04	1.04	50.51	10.89	9.89	1.25	79953.25	21.02	8.18	0.96	184.63	13.53
05	1.21	51.02	10.45	8.69	1.29	80207.60	21.48	8.69	1.00	184.83	13.44
06	0.73	51.86	10.46	9.78	1.28	80207.82	21.80	8.50	0.99	186.68	13.64
07	0.92	51.43	10.41	9.65	1.25	80104.89	21.78	8.63	0.96	185.99	13.43
08	1.23	51.08	10.62	9.51	1.25	80567.81	22.53	8.78	0.97	186.82	13.50
09	1.19	51.29	10.85	9.47	1.25	79949.39	22.11	8.74	0.97	185.10	13.23
10	0.86	51.67	10.73	9.54	1.24	80209.77	22.11	8.04	0.96	186.49	13.39
11	1.26	52.42	10.72	9.64	1.21	79881.08	21.45	8.71	0.94	186.32	13.35
12	1.26	54.39	10.10	9.68	1.21	79841.13	21.15	8.31	0.94	185.90	13.31
13	1.04	53.97	9.54	9.77	1.22	79969.07	21.63	9.03	0.94	187.03	13.56
14	1.46	50.43	10.37	9.91	1.24	78158.86	21.42	8.23	0.96	185.46	13.34
15	1.38	50.81	9.98	9.52	1.23	80695.21	22.40	7.96	0.95	187.20	13.52
16	1.78	49.63	9.97	9.44	1.21	81154.10	21.99	8.44	0.93	187.13	13.43
17	1.34	50.02	11.19	9.51	1.19	81210.30	21.99	8.04	0.92	187.25	13.52
18	1.74	50.33	9.66	9.55	1.20	80945.27	21.84	8.36	0.93	187.24	13.50
19	1.45	52.47	8.86	9.46	1.21	80659.09	21.65	8.17	0.93	186.22	13.29
20	1.18	51.64	8.42	9.61	1.21	80717.48	21.94	8.01	0.93	187.97	13.58
21	1.25	52.48	8.35	9.64	1.23	80242.59	21.86	7.61	0.95	187.35	13.50
22	1.34	50.03	10.41	9.36	1.23	81612.25	22.67	7.38	0.95	188.65	13.58
23	1.50	49.37	8.79	9.34	1.21	80283.51	22.14	7.34	0.93	186.63	13.18
24	1.14	49.72	11.42	9.55	1.20	80375.59	21.83	7.31	0.92	187.57	13.42
25	1.25	50.31	11.23	9.54	1.21	81374.28	22.19	7.28	0.94	189.26	13.68
26	1.55	50.79	9.87	9.57	1.20	80764.62	21.57	7.82	0.93	187.69	13.46
27	1.32	51.76	11.57	9.99	1.19	80363.87	20.72	7.26	0.92	188.62	13.78
28	1.51	53.26	9.63	9.94	1.21	80294.49	20.97	7.79	0.94	187.73	13.73
29	2.01	51.12	10.39	9.72	1.21	80767.58	21.96	7.71	0.93	188.36	13.73
30	1.93	52.45	10.77	9.53	1.22	80820.67	21.30	7.84	0.94	186.71	13.36
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.32	51.10	10.42	9.60	1.23	80311.53	21.72	8.06	0.95	186.64	13.47
最大值	2.01	54.39	13.04	9.99	1.29	81612.25	22.67	9.03	1.00	189.26	13.78
發生日期											
最小值	0.73	48.58	8.35	8.69	1.19	78158.86	20.72	7.26	0.92	183.22	13.17
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年06月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	3.09	43.43	11.83	9.54	1.29	79158.23	20.30	6.82	1.00	188.23	12.96
02	2.81	41.78	13.19	9.43	1.22	79055.69	20.37	6.79	0.94	187.30	12.82
03	2.30	45.26	12.67	9.55	1.19	80186.10	19.93	7.09	0.92	191.62	13.18
04	2.93	43.79	12.15	9.59	1.18	79104.01	19.81	7.67	0.90	187.01	12.89
05	3.03	44.91	11.65	9.58	1.19	79822.08	20.10	7.17	0.92	188.34	123.11
06	2.18	45.98	11.96	9.46	1.24	80272.02	20.71	7.59	0.95	192.31	13.24
07	2.58	46.70	12.24	9.34	1.26	79671.51	20.74	7.53	0.97	188.30	12.90
08	2.95	45.25	11.50	9.40	1.22	78953.95	20.98	7.65	0.94	187.78	12.87
09	3.31	45.26	11.79	9.40	1.18	78407.26	20.76	7.25	0.91	186.24	12.71
10	2.32	41.43	12.69	9.38	1.18	78657.63	20.83	6.94	0.91	187.03	12.76
11	2.94	42.30	12.86	9.39	1.18	77847.75	20.44	7.71	0.91	185.71	12.54
12	3.11	44.01	13.39	9.42	1.21	78443.29	20.22	7.38	0.93	185.24	12.63
13	2.65	47.15	10.98	9.58	1.22	78778.07	20.49	7.66	0.94	188.28	12.98
14	3.29	49.24	11.00	9.76	1.21	76765.32	20.15	7.27	0.93	185.86	12.73
15	2.88	43.13	12.66	9.07	1.20	80303.60	21.83	7.75	0.92	188.36	12.89
16	3.72	45.42	11.89	8.93	1.17	81511.53	21.44	7.17	0.90	188.34	12.87
17	3.06	48.52	12.58	9.44	1.19	81694.97	20.60	7.70	0.91	191.30	13.42
18	3.48	45.28	11.65	9.34	1.17	79345.19	20.70	7.39	0.90	188.60	12.85
19	3.74	43.62	10.67	9.38	1.14	78362.08	20.38	7.44	0.88	187.42	12.65
20	3.00	51.05	10.55	9.70	1.15	80465.20	20.41	7.93	0.89	192.43	13.52
21	2.98	51.46	10.08	9.64	1.19	80189.56	20.39	7.20	0.92	192.00	13.39
22	3.23	44.61	12.45	9.22	1.21	80527.35	21.52	7.32	0.93	190.71	13.11
23	3.21	44.60	10.87	9.16	1.18	79247.12	21.18	7.24	0.91	188.14	12.71
24	2.54	48.79	12.67	9.41	1.13	80189.98	20.69	7.14	0.87	190.07	13.11
25	2.44	49.62	12.31	9.40	1.10	81027.32	20.91	6.73	0.85	192.57	13.35
26	3.28	44.34	11.25	9.38	1.07	80168.66	20.61	7.36	0.82	189.79	13.06
27	3.23	47.14	11.93	9.63	1.07	80930.25	19.99	7.52	0.83	190.35	13.38
28	3.50	51.03	12.30	9.69	1.10	81100.21	19.98	7.55	0.85	190.05	13.46
29	3.14	47.48	13.26	9.70	1.10	82456.22	20.61	7.04	0.85	193.99	13.93
30	3.88	47.28	12.51	9.58	1.08	82452.43	20.13	6.99	0.83	193.09	13.69
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.03	46.00	11.98	9.45	1.17	79836.49	20.57	7.33	0.90	189.22	16.72
最大值	3.88	51.46	13.39	9.76	1.29	82456.22	21.83	7.93	1.00	193.99	123.11
發生日期											
最小值	2.18	41.43	10.08	8.93	1.07	76765.32	19.81	6.73	0.82	185.24	12.54
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管