

連續自動監測紀錄月報表

中華民國111年4月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.62	57.82	8.98	10.40	1.53	81336.59	16.71	11.68	1.02	181.49	13.57
02	3.29	55.95	8.34	10.48	1.56	81375.70	16.41	12.55	1.04	180.84	13.62
03	2.78	56.06	8.87	10.34	1.55	81936.06	17.05	12.27	1.03	181.84	13.67
04	3.17	54.60	6.57	10.29	1.59	81397.51	16.92	12.07	1.06	181.49	13.48
05	2.59	56.17	8.84	10.24	1.67	81202.28	17.56	12.07	1.11	183.02	13.54
06	3.06	55.86	8.05	10.31	1.67	80450.01	17.26	11.02	1.12	183.35	13.46
07	3.31	49.42	7.05	10.38	1.65	80458.48	16.71	11.38	1.10	181.76	13.41
08	3.16	48.82	8.11	10.41	1.66	79831.56	16.70	12.28	1.11	180.87	13.32
09	2.97	49.82	7.98	10.42	1.73	79533.89	16.45	12.49	1.15	178.94	13.19
10	3.15	51.05	7.24	10.34	1.76	80404.08	16.94	12.95	1.17	181.12	13.37
11	3.64	52.18	9.40	10.57	1.75	79478.46	16.60	12.52	1.17	177.42	13.36
12	2.79	52.46	8.87	10.18	1.75	79765.31	17.52	10.92	1.17	182.62	13.23
13	4.54	44.94	8.91	10.25	1.74	79413.17	16.55	12.36	1.16	179.16	12.99
14	3.51	49.23	7.95	10.13	1.73	80439.65	17.27	12.47	1.15	180.01	13.13
15	3.26	51.96	8.94	10.51	1.69	81582.32	16.98	11.93	1.12	179.43	13.77
16	3.43	52.65	9.00	10.25	1.67	81661.27	16.57	12.61	1.12	180.94	13.40
17	3.50	50.75	7.55	10.28	1.70	81613.43	16.65	12.05	1.14	181.14	13.45
18	3.10	49.55	7.93	10.23	1.69	80913.12	17.10	11.71	1.13	181.17	13.35
19	2.90	51.74	8.28	10.19	1.67	82157.90	17.43	11.90	1.12	182.30	13.60
20	3.60	46.60	8.92	10.15	1.72	81906.37	17.08	11.48	1.15	181.45	13.43
21	3.02	51.73	8.55	10.08	1.75	81539.35	17.52	12.34	1.16	182.11	13.37
22	3.14	53.02	7.46	10.08	1.76	80716.17	18.59	11.53	1.17	183.02	13.43
23	3.35	58.30	9.24	10.13	1.75	79407.62	18.35	12.09	1.17	182.59	13.22
24	3.49	56.62	7.92	10.01	1.72	79738.69	18.43	12.23	1.15	182.07	13.14
25	2.98	54.00	7.21	10.05	1.68	79804.08	18.40	11.86	1.12	182.72	13.20
26	2.43	49.65	8.45	9.87	1.65	81197.45	18.49	11.95	1.10	182.88	13.23
27	3.32	48.77	8.31	9.92	1.65	80304.79	17.77	12.37	1.10	181.29	13.00
28	3.23	49.02	8.28	9.77	1.59	80693.14	18.03	12.40	1.06	181.79	13.00
29	3.08	52.40	8.81	10.01	1.55	80141.51	17.82	11.98	1.03	182.70	13.19
30	3.43	50.63	7.91	9.93	1.56	81568.74	17.81	12.20	1.04	182.30	13.31
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.23	52.06	8.26	10.21	1.67	80732.29	17.32	12.06	1.11	181.46	13.35
最大值	4.54	58.30	9.40	10.57	1.76	82157.90	18.59	12.95	1.17	183.35	13.77
發生日期											
最小值	2.43	44.94	6.57	9.77	1.53	79407.62	16.41	10.92	1.02	177.42	12.99
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年4月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.74	58.15	7.27	10.84	1.59	83368.00	16.79	12.15	1.06	184.48	14.64
02	4.16	60.61	7.88	11.17	1.63	82639.25	16.44	12.63	1.09	187.39	15.00
03	3.94	61.41	8.56	11.07	1.62	83025.28	16.95	12.63	1.08	187.82	15.06
04	4.49	56.92	9.75	10.97	1.64	82850.85	16.63	12.33	1.09	187.41	14.79
05	3.61	59.41	9.58	11.11	1.69	81479.77	17.28	12.39	1.13	189.59	14.97
06	4.56	54.44	9.99	11.02	1.67	81362.58	17.26	12.25	1.12	183.35	13.46
07	4.31	56.32	11.50	11.07	1.63	79903.06	16.64	11.89	1.08	186.85	14.40
08	4.27	57.25	8.84	11.31	1.60	81601.14	16.56	12.48	1.07	184.43	14.98
09	4.60	51.49	7.78	10.92	1.59	80196.14	16.71	12.92	1.06	183.83	14.15
10	5.13	51.29	7.29	10.93	1.59	79871.73	16.94	12.77	1.05	183.92	14.16
11	4.75	50.34	7.24	10.95	1.52	79939.32	16.85	12.63	1.02	183.92	14.16
12	4.70	54.34	7.29	11.15	1.45	80230.80	16.90	12.79	0.97	186.66	14.61
13	4.53	55.72	12.28	11.14	1.45	80592.31	16.93	11.77	0.97	188.17	14.73
14	4.53	52.20	9.41	11.01	1.45	81896.66	16.58	12.69	0.96	186.16	14.63
15	4.00	56.42	8.34	11.27	1.44	81612.58	16.25	12.51	0.96	187.05	14.94
16	4.45	57.45	7.58	11.20	1.47	82842.87	15.82	12.49	0.98	187.30	15.01
17	4.58	55.75	8.09	11.14	1.55	82538.70	16.05	12.37	1.03	186.95	14.87
18	4.14	56.34	7.32	11.04	1.60	82239.85	16.46	12.18	1.06	186.73	14.74
19	3.60	57.31	7.59	11.13	1.58	82834.72	16.59	12.00	1.05	188.60	15.06
20	4.31	54.13	8.70	11.14	1.59	82265.25	16.30	11.98	1.06	188.02	14.90
21	4.06	55.80	8.53	11.00	1.59	81993.73	17.06	12.37	1.06	187.44	14.77
22	2.49	53.60	8.88	11.05	1.55	82332.14	17.32	12.36	1.03	190.63	15.05
23	2.40	49.36	9.06	10.98	1.54	82120.85	17.17	12.52	1.03	189.71	14.86
24	2.83	44.96	7.59	10.88	1.61	82678.75	16.99	12.24	1.07	189.29	14.77
25	2.75	47.82	7.46	10.89	1.63	81684.73	17.41	12.47	1.09	189.08	14.66
26	3.05	53.46	9.48	10.77	1.61	82384.97	18.06	12.53	1.07	190.07	14.76
27	4.30	50.53	8.62	10.73	1.59	82103.08	17.40	12.80	1.06	187.91	14.47
28	3.35	51.37	9.15	10.65	1.51	82234.78	17.73	12.42	1.12	187.78	14.43
29	3.85	55.59	11.16	10.90	1.46	82777.24	17.22	12.38	1.08	189.69	14.86
30	3.70	55.31	9.67	10.86	1.44	82564.86	17.20	12.54	1.07	188.18	14.71
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	4.01	54.50	8.73	11.01	1.56	81872.20	16.88	12.42	1.05	187.28	14.69
最大值	5.13	61.41	12.28	11.31	1.69	83368.00	18.06	12.92	1.13	190.63	15.06
發生日期											
最小值	2.40	44.96	7.24	10.65	1.44	79871.73	15.82	11.77	0.96	183.35	13.46
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管