

連續自動監測紀錄月報表

中華民國109年11月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.03	59.96	7.54	10.08	2.61	80425.50	16.93	17.34	1.09	175.24	12.88
02	4.45	59.59	3.23	9.82	2.64	81838.46	17.85	16.21	1.10	176.83	12.99
03	4.60	60.58	3.36	10.13	2.62	82211.68	17.55	15.39	1.09	179.05	13.46
04	4.81	59.92	4.62	10.09	2.60	82019.78	17.37	15.84	1.08	178.13	13.30
05	4.47	59.52	4.17	10.04	2.61	81606.90	17.14	14.96	1.09	177.29	13.12
06	4.33	58.46	3.55	9.98	2.60	81364.25	18.14	15.00	1.08	178.83	13.21
07	4.67	60.13	4.20	9.89	2.51	82365.67	17.99	16.10	1.05	179.65	13.27
08	4.81	59.25	3.80	9.98	2.31	82294.49	17.32	15.30	0.96	177.53	13.19
09	4.90	58.74	3.77	9.93	2.29	82188.16	17.24	17.15	0.95	177.05	13.09
10	4.82	60.48	2.36	10.31	2.31	80016.91	17.09	16.83	0.96	178.00	13.21
11	4.80	58.18	5.24	9.92	2.44	81702.76	17.53	17.23	1.02	177.28	13.06
12	4.66	60.19	6.57	9.88	2.46	82534.92	17.46	16.93	1.03	177.85	13.15
13	4.39	59.35	5.17	9.80	2.46	82340.17	18.19	16.31	1.03	178.35	13.16
14	4.52	60.78	4.85	9.90	2.48	82847.37	17.95	16.72	1.03	179.69	13.34
15	4.77	58.82	3.96	9.91	2.54	82216.09	17.72	16.73	1.06	179.91	13.22
16	4.65	57.43	4.19	9.86	2.53	81879.01	17.64	16.21	1.05	178.96	13.07
17	4.62	58.97	3.21	9.92	2.56	80733.54	17.59	16.62	1.07	178.00	12.92
18	4.18	59.72	4.05	9.90	2.53	80554.59	17.89	16.51	1.05	177.78	12.92
19	4.34	59.27	4.33	9.79	2.54	82129.18	18.14	17.01	1.06	179.33	13.12
20	4.44	59.72	4.17	9.92	2.50	80871.78	18.26	16.87	1.04	178.05	13.06
21	4.93	61.03	5.36	9.99	2.48	81388.34	17.56	16.51	1.03	176.70	13.07
22	4.60	57.93	4.21	9.79	2.47	81710.24	18.41	16.58	1.03	177.38	13.04
23	4.72	61.54	4.37	9.95	2.42	81512.74	17.26	17.16	1.01	176.28	12.98
24	4.51	59.35	4.03	10.02	2.46	81328.95	17.70	15.94	1.03	177.09	13.14
25	4.56	58.97	4.08	9.90	2.49	82489.12	18.06	16.59	1.04	177.60	13.25
26	4.55	56.45	5.79	9.82	2.46	81464.36	17.54	15.80	1.02	174.55	12.82
27	4.65	60.18	3.83	10.02	2.39	81866.74	17.76	15.48	1.00	175.46	13.19
28	4.84	60.28	3.24	10.13	2.38	81713.02	17.35	15.85	0.99	175.46	13.23
29	4.93	58.88	3.87	9.87	2.39	83043.64	17.67	16.81	0.99	174.81	13.15
30	4.90	56.95	4.35	9.86	2.36	82647.77	17.40	16.67	0.98	173.63	13.00
監測日數	30	30	30	30	30	30	30	30	30	30	29
平均值	4.65	59.35	4.32	9.95	2.48	81776.87	17.66	16.36	1.03	177.39	13.13
最大值	5.03	61.54	7.54	10.31	2.64	83043.64	18.41	17.34	1.10	179.91	13.46
發生日期											
最小值	4.18	56.45	2.36	9.79	2.29	80016.91	16.93	14.96	0.95	173.63	12.88
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國109年11月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.73	58.37	9.18	10.46	2.23	79150.20	16.94	16.95	0.93	183.59	13.38
02	3.39	59.95	7.16	10.44	2.23	78748.12	17.44	16.38	0.93	184.42	13.40
03	3.44	62.31	5.83	10.64	2.39	79130.62	17.48	15.33	1.00	185.52	13.79
04	3.83	60.76	9.01	10.56	2.50	79271.77	17.23	16.14	1.04	185.49	13.64
05	3.61	55.71	8.61	10.47	2.44	78348.59	17.09	15.10	1.02	182.40	13.25
06	3.34	57.84	9.43	10.42	2.50	79085.42	18.02	15.00	1.04	185.00	13.54
07	3.35	57.26	9.13	10.33	2.46	79200.38	17.97	15.32	1.03	185.38	13.45
08	3.66	58.18	7.84	10.36	2.42	79531.13	17.36	15.21	1.01	183.46	13.39
09	3.70	58.58	8.29	10.43	2.52	80001.97	17.17	16.90	1.05	184.88	13.56
10	3.78	60.85	7.41	10.88	2.57	76656.02	16.92	15.60	1.07	184.45	13.50
11	3.74	58.68	8.08	10.39	2.62	78771.48	17.65	16.51	1.09	183.27	13.33
12	3.58	57.29	8.49	10.20	2.71	79728.31	17.90	15.22	1.13	183.36	13.29
13	3.25	57.32	9.14	10.27	2.75	78682.45	18.35	15.75	1.15	183.41	13.28
14	3.55	58.75	8.31	10.38	2.72	79704.98	17.97	15.78	1.13	184.91	13.58
15	3.71	56.56	7.27	10.35	2.68	79981.85	17.59	16.66	1.12	185.82	13.56
16	3.28	57.52	10.07	10.32	2.66	79541.78	17.65	16.00	1.11	184.72	13.42
17	3.62	57.35	7.73	10.46	2.60	78862.44	17.49	16.63	1.08	184.77	13.45
18	3.41	59.05	9.29	10.47	2.60	78602.85	17.58	16.47	1.08	184.02	13.42
19	3.62	60.43	8.47	10.48	2.57	79317.90	17.75	16.49	1.07	184.88	13.61
20	3.78	61.87	7.47	10.52	2.55	79394.45	17.75	16.59	1.06	184.06	13.65
21	4.22	60.37	8.43	10.53	2.50	78741.86	17.34	16.48	1.04	182.65	13.44
22	3.71	59.49	7.51	10.37	2.50	79883.15	18.28	16.36	1.04	183.38	13.62
23	4.15	59.99	8.17	10.57	2.53	79673.91	17.08	17.22	1.05	183.89	13.65
24	4.08	61.97	6.15	10.60	2.59	79236.21	17.51	16.18	1.08	184.12	13.69
25	3.89	61.48	7.40	10.51	2.57	80259.62	17.55	16.08	1.07	185.65	13.81
26	4.42	58.89	10.48	10.47	2.41	79713.17	16.78	15.16	1.01	182.86	13.44
27	4.03	63.40	7.32	10.79	2.44	78912.04	16.87	14.96	1.02	184.26	13.78
28	4.04	64.01	7.13	10.80	2.45	79645.75	16.71	14.61	1.02	184.85	13.92
29	4.47	60.41	7.38	10.67	2.47	80388.27	16.89	16.40	1.03	184.56	13.54
30	4.32	61.04	6.85	10.72	2.46	80234.38	16.45	15.80	1.03	184.67	13.87
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.76	59.52	8.10	10.50	2.52	79280.04	17.43	15.98	1.05	184.29	13.54
最大值	4.47	64.01	10.48	10.88	2.75	80388.27	18.35	17.22	1.15	185.82	13.92
發生日期											
最小值	3.25	55.71	5.83	10.20	2.23	76656.02	16.45	14.61	0.93	182.40	13.25
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管