

連續自動監測紀錄月報表

中華民國114年09月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	2.45	42.66	11.16	9.66	1.22	81436.44	20.70	9.78	0.94	186.09	13.49
02	1.22	40.48	9.94	9.67	1.24	82214.04	21.17	9.77	0.96	188.87	13.80
03	1.39	39.38	11.35	9.65	1.25	82289.22	20.63	10.06	0.97	187.87	13.67
04	1.14	43.43	9.29	9.61	1.26	82194.54	20.97	9.98	0.97	188.05	13.66
05	0.94	45.66	10.62	9.68	1.27	82801.40	20.87	9.19	0.98	189.98	13.88
06	1.36	42.13	10.58	9.70	1.25	80764.22	20.26	7.53	0.97	187.35	13.39
07	0.69	44.42	10.06	9.54	1.23	81900.30	21.03	7.60	0.95	188.94	13.56
08	1.06	45.66	7.91	9.64	1.21	80539.34	20.15	8.71	0.93	187.81	13.27
09	0.57	45.20	9.10	9.67	1.20	81781.13	21.03	9.14	0.93	192.06	13.80
10	1.12	41.28	11.50	9.74	1.19	81797.50	20.83	8.39	0.92	189.62	13.78
11	1.66	47.54	10.58	9.70	1.20	81187.79	20.52	8.80	0.92	187.54	13.51
12	1.06	45.92	10.84	9.68	1.19	81302.81	21.03	8.97	0.92	188.32	13.61
13	1.78	45.37	12.12	9.68	1.21	81298.18	20.65	8.69	0.93	187.55	13.54
14	1.67	42.22	11.08	9.58	1.19	80538.45	20.78	9.27	0.92	186.31	13.28
15	1.38	43.70	8.10	9.37	1.19	80260.61	21.00	6.11	0.92	185.09	12.98
16	0.79	42.26	9.54	9.50	1.17	81564.57	21.17	4.48	0.90	188.25	13.48
17	1.98	47.19	11.51	9.68	1.08	81169.21	20.29	5.81	1.08	180.03	13.42
18	2.33	51.29	9.09	9.52	1.10	83089.64	19.90	4.55	0.85	188.75	13.54
19	2.61	51.39	11.60	9.72	1.08	83264.56	19.69	5.42	0.83	189.76	13.78
20	2.76	52.16	10.68	9.79	1.10	84092.38	19.21	8.64	0.84	186.81	13.61
21	2.72	51.34	11.22	9.70	1.15	83312.07	19.50	7.56	0.88	186.67	13.66
22	2.29	50.59	9.96	9.58	1.14	82549.90	19.64	6.80	0.88	184.40	13.34
23	1.48	49.58	10.39	9.67	1.14	83471.40	20.38	5.74	0.87	186.89	13.81
24	1.57	49.38	11.57	9.71	1.12	83047.49	19.85	6.24	0.86	187.75	13.73
25	1.92	50.78	11.24	9.70	1.11	82539.59	19.78	6.56	0.86	186.40	13.58
26	1.90	49.41	14.07	9.90	1.17	83277.50	19.58	5.55	0.90	187.17	13.94
27	1.70	52.56	11.02	9.82	1.17	83405.21	20.21	5.73	0.90	187.82	13.98
28	1.76	50.88	10.75	9.85	1.14	83038.75	19.84	5.13	0.88	187.88	13.89
29	1.84	51.88	7.88	9.64	1.11	82960.52	20.45	6.81	0.85	186.78	13.68
30	1.84	51.29	10.28	9.86	1.12	82574.42	19.91	8.62	0.86	189.19	13.88
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.63	46.90	10.50	9.67	1.17	82188.77	20.37	7.52	0.91	187.53	13.62
最大值	2.76	52.56	14.07	9.90	1.27	84092.38	21.17	10.06	1.08	192.06	13.98
發生日期											
最小值	0.57	39.38	7.88	9.37	1.08	80260.61	19.21	4.48	0.83	180.03	12.98
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年09月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	5.01	37.69	8.69	10.77	1.12	78051.09	15.34	8.25	0.86	191.68	13.57
02	4.11	34.11	9.53	10.74	1.11	77694.19	15.61	8.76	0.85	192.76	13.54
03	4.45	37.51	10.47	10.74	1.12	78086.45	15.41	9.85	0.86	192.80	13.59
04	3.52	38.02	9.21	10.62	1.14	78788.05	16.01	8.96	0.87	193.00	13.64
05	2.37	42.32	9.69	10.61	1.14	80974.81	16.07	7.99	0.87	196.82	14.14
06	2.69	38.37	12.29	10.70	1.14	77929.48	15.21	5.73	0.87	192.33	13.47
07	2.62	40.98	10.70	10.53	1.14	79609.96	16.07	7.30	0.88	193.13	13.70
08	2.98	41.77	10.14	10.48	1.15	78431.62	15.50	8.03	0.88	190.43	13.25
09	2.40	44.34	9.04	10.59	1.16	81019.17	16.04	8.74	0.89	195.81	14.10
10	3.22	42.09	10.08	10.57	1.18	80015.12	15.85	8.30	0.91	193.72	13.80
11	3.78	42.82	9.74	10.52	1.16	78075.33	15.92	8.08	0.89	190.87	13.33
12	3.05	42.38	10.04	10.56	1.18	80125.68	16.22	8.30	0.91	194.01	13.87
13	3.44	43.02	10.08	10.58	1.18	80114.03	15.94	8.80	0.91	194.21	13.86
14	2.92	40.65	10.11	10.46	1.15	79204.63	16.13	6.58	0.88	192.31	13.52
15	1.97	41.88	8.42	10.42	1.11	78424.57	16.15	4.99	0.85	191.00	13.30
16	0.80	40.30	9.15	10.69	1.06	79341.37	15.67	4.49	0.81	193.87	13.82
17	1.79	42.35	9.95	11.41	1.05	75734.26	13.67	4.31	0.81	190.82	13.83
18	2.01	45.41	8.91	11.30	1.12	75657.41	13.11	4.52	0.86	192.45	13.54
19	1.81	47.66	10.63	10.95	1.12	78460.82	13.54	4.67	0.86	193.03	13.64
20	1.31	53.37	11.77	9.75	1.13	85661.79	15.94	6.53	0.87	191.22	13.65
21	0.69	52.78	11.68	8.95	1.09	88505.73	18.28	7.67	0.84	190.46	13.53
22	0.38	49.00	10.90	8.82	1.07	88666.85	18.71	6.13	0.82	189.24	13.42
23	0.41	49.76	10.93	9.11	1.08	88960.60	18.70	5.11	0.83	192.37	13.88
24	0.32	54.15	10.08	9.16	1.09	89073.90	18.52	7.80	0.84	193.73	13.97
25	0.41	54.58	11.93	9.79	1.11	84782.35	18.14	5.79	0.85	193.05	13.97
26	0.39	53.70	11.55	9.72	1.14	85726.08	18.15	5.79	0.87	192.57	13.91
27	0.35	52.51	10.89	9.41	1.14	86528.11	19.17	4.63	0.88	193.89	13.99
28	0.35	50.57	10.46	9.42	1.12	85888.41	18.93	4.34	0.86	193.51	13.84
29	0.53	51.64	10.02	9.28	1.06	85575.34	19.29	6.15	0.82	192.06	13.66
30	0.56	52.92	10.54	9.45	1.03	86847.02	18.95	8.79	0.79	194.37	14.06
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.02	45.29	10.25	10.20	1.12	81731.81	16.54	6.85	0.86	192.72	13.71
最大值	5.01	54.58	12.29	11.41	1.18	89073.90	19.29	9.85	0.91	196.82	14.14
發生日期											
最小值	0.32	34.11	8.42	8.82	1.03	75657.41	13.11	4.31	0.79	189.24	13.25
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管