

連續自動監測紀錄月報表

中華民國113年6月30日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	1.08	31.34	11.92	10.33	1.17	78635.16	18.68	9.05	0.90	186.29	13.50
02	1.25	30.98	11.90	10.34	1.14	79481.03	18.55	8.59	0.88	185.51	13.61
03	1.13	26.70	10.69	10.26	1.11	79795.10	18.72	7.73	0.85	184.61	13.56
04	1.02	28.08	10.46	10.29	1.14	79718.41	18.67	7.70	0.88	185.88	13.63
05	1.15	32.29	10.92	10.33	1.14	79659.78	18.60	8.25	0.88	186.02	13.65
06	1.41	34.45	10.70	10.38	1.12	78415.80	18.36	9.21	0.86	184.35	13.41
07	1.26	23.10	11.45	10.49	1.14	78089.95	18.67	8.68	0.88	185.68	13.59
08	0.90	23.99	12.02	10.38	1.16	77648.74	18.90	8.66	0.90	184.91	13.39
09	0.84	28.27	11.14	10.24	1.17	78912.01	19.47	8.69	0.90	186.29	13.57
10	0.86	29.91	10.94	10.21	1.16	78806.71	19.42	8.21	0.89	185.77	13.48
11	0.89	28.80	11.12	10.25	1.18	77550.02	19.44	7.94	0.91	185.43	13.32
12	1.09	28.12	11.73	10.20	1.19	77864.91	19.19	8.14	0.92	184.61	13.24
13	1.04	30.14	11.12	10.25	1.18	77298.82	19.14	7.73	0.91	184.39	13.20
14	0.90	29.97	11.30	10.39	1.19	76997.43	18.86	7.75	0.92	184.51	13.27
15	1.11	29.52	11.92	10.35	1.21	76100.16	18.59	8.47	0.93	182.96	12.98
16	0.89	29.74	11.02	10.14	1.22	77290.54	19.37	8.23	0.94	183.41	13.07
17	0.89	29.70	10.97	10.34	1.19	77453.57	19.01	7.94	0.92	184.72	13.31
18	0.79	30.04	10.23	10.33	1.21	78234.96	19.28	8.35	0.94	186.79	13.54
19	0.77	26.74	11.59	10.26	1.21	76985.80	19.14	7.98	0.93	188.93	13.28
20	0.89	27.22	11.06	10.28	1.18	74059.28	19.00	8.76	0.91	186.92	12.72
21	0.95	31.05	10.77	10.42	1.17	74513.72	18.93	8.70	0.90	186.56	12.94
22	1.06	29.44	11.40	10.45	1.17	73088.04	18.60	9.14	0.90	184.81	12.63
23	0.98	27.39	10.62	10.31	1.16	73343.59	19.14	9.01	0.90	183.88	12.57
24	0.92	30.52	11.11	10.09	1.17	73814.00	19.36	8.93	0.90	182.75	12.40
25	1.51	38.70	12.48	10.34	1.17	73279.12	19.02	8.58	0.88	184.37	12.57
26	2.20	39.51	12.93	10.23	1.12	73968.48	18.91	8.53	0.87	184.36	12.56
27	2.00	37.06	12.61	9.93	1.15	74397.41	19.41	8.27	0.89	183.31	12.34
28	1.94	40.24	11.74	10.20	1.15	74757.87	19.34	8.82	0.88	185.22	12.75
29	1.80	42.10	12.90	10.20	1.14	79154.72	19.43	8.97	0.87	186.61	13.56
30	1.68	41.21	11.73	10.11	1.14	80246.83	19.81	8.85	0.87	187.09	13.70
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.17	31.21	11.42	10.28	1.17	76985.40	19.03	8.46	0.90	185.23	13.18
最大值	2.20	42.10	12.93	10.49	1.22	80246.83	19.81	9.21	0.94	188.93	13.70
發生日期											
最小值	0.77	23.10	10.23	9.93	1.11	73088.04	18.36	7.70	0.85	182.75	12.34
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年6月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	1.36	27.23	13.04	11.58	0.96	74741.70	17.39	8.94	0.74	198.57	14.68
02	1.59	27.54	13.26	11.66	0.93	75708.95	17.18	8.57	0.71	197.77	14.94
03	1.61	26.38	11.91	11.60	0.90	76178.61	17.16	7.79	0.69	196.79	14.90
04	1.69	28.16	13.03	11.64	0.90	75655.67	17.04	7.32	0.70	197.33	14.85
05	1.61	28.76	12.77	11.53	0.91	76385.86	17.11	7.38	0.70	197.28	14.83
06	1.35	32.06	12.56	11.18	0.97	79118.02	17.46	8.70	0.75	200.21	14.98
07	1.33	28.72	12.11	11.30	1.01	77225.84	17.61	8.22	0.78	198.74	14.78
08	1.55	29.65	12.42	11.48	0.99	75424.38	17.09	8.05	0.76	196.64	14.55
09	1.35	27.60	12.33	11.40	0.94	76053.69	17.48	7.81	0.72	197.68	14.64
10	1.35	27.68	12.21	11.35	0.98	76334.48	17.42	7.26	0.75	197.10	14.60
11	1.46	30.68	12.99	11.47	1.00	75228.75	17.30	7.03	0.77	197.27	14.55
12	1.72	30.02	12.98	11.36	1.02	75267.84	17.00	7.56	0.79	197.67	14.35
13	1.73	31.67	12.21	11.42	1.05	75158.92	16.98	7.10	0.81	196.65	14.38
14	1.32	29.41	12.98	11.21	0.99	76096.17	17.54	7.42	0.76	195.25	14.33
15	1.98	27.99	13.11	11.27	0.93	74816.79	17.07	8.00	0.71	193.39	14.01
16	1.76	29.20	11.39	11.38	0.91	75284.51	17.21	7.78	0.70	196.07	14.38
17	1.56	31.27	11.62	11.33	0.91	75844.45	17.16	7.45	0.70	195.83	14.39
18	1.26	32.98	11.26	11.31	0.92	77032.94	17.60	8.02	0.71	198.12	14.73
19	1.58	26.29	13.43	11.23	0.89	75766.48	17.73	7.51	0.68	194.10	14.28
20	1.50	24.80	11.57	11.25	0.91	74142.22	17.41	9.00	0.70	196.12	14.00
21	1.21	25.42	12.46	11.26	0.93	74007.94	17.70	8.53	0.71	196.29	14.04
22	1.28	25.18	13.37	11.04	0.93	74719.34	18.05	9.43	0.71	195.13	13.89
23	1.20	23.29	12.87	11.12	0.91	74122.91	18.05	8.72	0.70	195.32	13.89
24	1.26	28.94	12.84	11.18	0.91	73909.87	17.74	8.72	0.70	194.77	13.87
25	2.77	44.27	12.85	11.41	0.89	72394.96	18.11	8.63	0.67	196.41	14.01
26	5.05	52.22	13.27	11.77	0.90	70191.27	17.59	8.52	0.69	196.60	14.05
27	4.40	47.75	13.28	11.85	0.90	68676.46	17.40	8.17	0.69	195.33	13.79
28	3.35	47.74	12.99	11.84	0.90	69781.11	17.91	8.70	0.69	197.46	14.15
29	3.30	47.35	13.06	11.86	0.89	70250.46	17.71	9.21	0.68	198.45	14.28
30	3.56	47.12	12.39	11.88	0.90	69892.65	17.93	8.56	0.69	199.21	14.29
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	1.93	32.25	12.62	11.44	0.94	74513.77	17.47	8.14	0.72	196.79	14.38
最大值	5.05	52.22	13.43	11.88	1.05	79118.02	18.11	9.43	0.81	200.21	14.98
發生日期											
最小值	1.20	23.29	11.26	11.04	0.89	68676.46	16.98	7.03	0.67	193.39	13.79
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管