

連續自動監測紀錄月報表

中華民國114年08月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	2.53	44.41	10.47	9.42	1.17	82710.34	21.19	8.71	0.90	185.83	13.50
02	2.08	46.48	11.08	9.54	1.15	83177.39	21.08	8.44	0.88	186.56	13.71
03	2.21	47.07	9.72	9.32	1.13	84056.51	21.61	9.14	0.87	188.26	13.74
04	2.34	44.59	9.37	9.09	1.11	84502.59	22.00	8.40	0.86	188.21	13.61
05	2.49	44.25	9.07	9.41	1.13	83237.58	21.27	8.30	0.87	187.02	13.61
06	2.45	47.29	9.82	9.39	1.09	84257.51	21.26	9.63	0.84	188.45	13.79
07	2.69	48.03	9.46	9.31	1.05	83360.13	21.32	8.95	0.81	187.69	13.55
08	2.21	47.59	10.99	9.47	1.07	83159.21	20.86	8.79	0.83	187.39	13.62
09	2.61	47.85	10.56	9.53	1.13	83285.41	20.90	10.20	0.87	188.26	13.74
10	2.50	47.22	10.42	9.45	1.17	83358.15	20.97	10.57	0.90	188.15	13.66
11	2.18	48.43	10.42	9.32	1.15	83353.79	21.34	8.57	0.88	187.43	13.56
12	1.96	49.92	10.64	9.38	1.17	83876.99	21.34	8.81	0.90	188.64	13.75
13	2.26	48.70	11.47	9.59	1.21	83636.39	20.43	8.92	0.93	187.35	13.75
14	2.17	46.56	10.57	9.45	1.28	82819.95	20.51	9.54	0.99	186.27	13.44
15	1.50	46.64	11.47	9.73	1.27	81690.52	20.28	8.96	0.98	186.55	13.56
16	1.48	46.67	11.61	9.75	1.26	80991.73	20.27	9.67	0.97	186.01	13.45
17	1.32	48.12	9.57	9.57	1.23	82035.81	20.94	10.00	0.95	187.64	13.57
18	1.09	45.70	8.61	9.53	1.19	81944.31	21.17	7.74	0.92	187.72	13.54
19	0.86	43.25	11.71	9.71	1.20	81311.52	20.58	8.42	0.92	189.62	13.61
20	0.88	41.93	11.28	9.81	1.19	81526.02	20.57	7.53	0.92	194.35	13.90
21	1.86	40.61	12.15	9.60	1.20	80813.56	20.68	9.72	0.93	184.84	13.27
22	1.64	42.69	11.50	9.56	1.22	81140.72	20.92	10.12	0.95	186.18	13.36
23	1.65	42.74	11.59	9.60	1.19	80822.21	20.87	9.41	0.92	186.01	13.35
24	1.66	43.62	10.54	9.55	1.20	80788.67	20.97	8.34	0.92	186.19	13.30
25	1.42	43.13	9.94	9.56	1.20	81123.86	20.47	6.73	0.92	184.97	13.25
26	1.66	41.81	10.46	9.72	1.18	81156.61	20.25	8.24	0.91	186.06	13.44
27	1.70	44.45	12.25	9.83	1.18	81422.66	20.00	6.96	0.91	186.71	13.59
28	2.72	43.64	11.92	9.59	1.20	81546.62	20.32	9.13	0.92	185.82	13.35
29	2.30	41.82	11.82	9.78	1.21	80976.63	19.99	9.04	0.93	186.18	13.44
30	2.23	41.92	12.23	9.80	1.21	80705.47	19.96	9.93	0.93	185.64	13.40
31	3.42	41.16	11.25	9.85	1.21	80341.67	19.59	10.29	0.94	184.81	13.31
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.00	45.11	10.77	9.56	1.18	82230.02	20.77	8.94	0.91	187.12	13.54
最大值	3.42	49.92	12.25	9.85	1.28	84502.59	22.00	10.57	0.99	194.35	13.90
發生日期											
最小值	0.86	40.61	8.61	9.09	1.05	80341.67	19.59	6.73	0.81	184.81	13.25
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年08月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	2.48	49.59	11.40	10.65	1.20	77239.69	19.56	8.34	0.92	194.22	14.06
02	2.44	49.30	11.44	10.58	1.18	76786.49	19.80	8.35	0.91	193.34	13.89
03	2.60	52.30	11.66	10.47	1.13	76823.38	20.06	7.64	0.87	192.61	13.79
04	2.84	54.11	11.28	10.60	1.11	78543.10	19.64	7.49	0.85	191.83	14.17
05	2.47	53.95	11.04	10.51	1.12	78452.29	19.88	7.46	0.86	192.61	14.11
06	2.46	54.55	10.62	10.23	1.13	78097.99	20.05	8.62	0.87	193.22	13.72
07	2.83	55.78	9.86	10.22	1.17	77547.83	19.92	7.78	0.90	192.62	13.56
08	2.49	54.18	10.80	10.42	1.18	77841.28	19.69	7.63	0.91	194.63	13.90
09	2.94	52.39	11.05	10.57	1.17	76862.43	19.27	8.84	0.90	193.66	13.82
10	3.00	51.94	11.44	10.48	1.19	77152.51	19.48	9.73	0.91	193.76	13.80
11	2.41	51.28	10.94	10.41	1.21	77813.90	19.95	8.29	0.94	194.29	13.91
12	2.09	54.70	10.09	10.51	1.17	77711.71	19.80	8.09	0.90	195.51	14.03
13	2.38	52.87	10.97	10.64	1.16	77020.12	19.19	7.65	0.90	193.64	13.91
14	2.78	49.54	11.47	10.50	1.20	76194.73	19.19	7.82	0.93	192.93	13.56
15	2.40	48.91	11.90	10.82	1.15	75492.57	18.88	8.95	0.89	193.39	13.83
16	2.53	48.29	11.92	10.88	1.15	74747.80	18.95	9.67	0.88	193.37	13.79
17	2.74	45.79	12.05	10.82	1.20	74247.03	19.07	8.26	0.93	193.12	13.63
18	2.76	43.23	10.62	10.84	1.23	73367.15	19.14	7.74	0.95	191.61	13.47
19	2.97	44.86	13.22	11.52	1.21	70440.73	17.96	7.70	0.93	192.70	13.68
20	4.04	45.92	13.11	12.03	1.21	67590.79	16.82	7.82	0.93	192.62	13.68
21	4.39	44.72	13.45	12.08	1.22	67016.60	16.65	8.02	0.94	191.73	13.58
22	4.02	45.53	12.08	12.19	1.18	65726.96	16.53	8.49	0.91	192.23	13.48
23	4.22	47.29	10.91	12.40	1.19	64708.57	16.33	7.50	0.91	193.54	13.61
24	4.57	48.88	10.08	12.54	1.14	63899.28	16.01	7.26	0.88	193.55	13.61
25	4.99	43.28	10.65	12.47	1.07	64150.95	15.73	7.34	0.83	192.29	13.46
26	4.63	39.82	11.23	12.70	1.11	63412.17	15.42	6.98	0.85	193.74	13.67
27	5.39	37.35	12.89	12.88	1.12	62272.48	14.92	5.94	0.86	193.19	13.63
28	6.78	46.10	12.25	12.75	1.13	63038.99	15.07	8.27	0.87	192.23	13.59
29	5.52	38.06	11.59	11.84	1.13	71340.80	14.72	6.89	0.87	192.34	13.77
30	5.31	33.30	10.89	10.82	1.11	77599.72	14.84	9.34	0.85	191.58	13.48
31	5.92	33.58	12.18	10.76	1.10	76652.52	14.76	10.32	0.85	189.90	13.19
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.53	47.46	11.45	11.20	1.16	72896.53	17.98	8.07	0.89	192.97	13.72
最大值	6.78	55.78	13.45	12.88	1.23	78543.10	20.06	10.32	0.95	195.51	14.17
發生日期											
最小值	2.09	33.30	9.86	10.22	1.07	62272.48	14.72	5.94	0.83	189.90	13.19
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管