

連續自動監測紀錄月報表

中華民國115年4月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.10	46.96	11.20	10.60	1.14	77486.31	20.15	9.19	0.88	180.40	13.73
02	3.93	50.96	12.49	10.57	1.14	79357.03	19.66	10.29	0.88	181.69	13.96
03	2.98	51.19	13.52	10.92	1.14	76483.08	19.46	8.01	0.88	181.25	13.87
04	2.79	47.97	11.01	10.77	1.17	76607.91	20.25	8.45	0.90	180.94	13.82
05	2.41	47.52	11.50	10.61	1.14	76999.34	20.79	7.60	0.88	182.24	13.81
06	2.37	50.76	11.80	10.70	1.16	77091.39	20.63	7.27	0.89	182.85	13.93
07	2.19	50.28	12.00	10.66	1.17	77288.73	20.79	7.79	0.90	183.48	13.97
08	2.38	51.02	12.20	10.61	1.17	78163.86	20.52	8.43	0.90	184.79	14.04
09	2.34	55.66	12.08	10.53	1.20	77933.27	20.61	8.31	0.92	184.33	13.91
10	2.43	59.38	12.08	10.75	1.20	77250.77	19.92	8.65	0.93	185.08	13.98
11	2.43	57.34	13.08	10.83	1.16	77577.16	19.70	6.46	0.89	185.65	14.13
12	2.70	58.33	12.84	10.59	1.12	77726.58	20.55	8.12	0.86	185.71	13.98
13	2.37	59.64	12.14	10.41	1.12	78470.57	20.56	5.80	0.86	185.50	13.87
14	2.80	53.02	12.98	10.62	1.12	76489.29	19.88	5.26	0.86	183.12	13.61
15	3.16	60.07	11.81	10.64	1.10	77428.23	20.02	8.67	0.85	184.49	13.86
16	2.73	60.97	11.73	10.66	1.11	77820.54	20.14	8.61	0.85	185.32	14.01
17	2.58	64.93	11.51	10.63	1.15	77844.47	20.40	8.03	0.88	185.90	14.04
18	3.15	57.80	12.55	10.52	1.14	79259.02	20.16	11.01	0.87	186.36	14.12
19	2.88	59.61	12.05	10.40	1.12	79872.71	20.23	10.61	0.86	186.01	14.07
20	2.72	59.54	12.46	10.30	1.08	79777.27	20.28	9.03	0.83	185.23	13.91
21	2.77	58.53	12.43	10.40	1.07	79859.07	20.56	9.35	0.82	186.91	14.15
22	3.15	56.91	11.25	10.51	1.07	78691.66	20.08	10.52	0.83	186.27	13.99
23	2.88	62.86	11.44	10.53	1.10	79565.83	20.05	9.58	0.84	186.36	14.17
24	3.24	58.15	11.74	10.47	1.12	78987.21	20.09	10.53	0.86	184.09	13.93
25	2.66	62.43	11.92	10.44	1.15	79239.83	20.35	9.75	0.91	184.19	13.98
26	3.07	61.76	11.44	10.51	1.18	78940.50	19.81	11.14	0.93	185.22	13.96
27	2.82	62.56	12.25	10.41	1.14	79552.50	20.14	9.11	0.87	185.39	13.98
28	2.42	60.32	11.81	10.45	1.15	79404.94	20.55	9.53	0.88	187.17	14.14
29	3.12	60.01	10.85	10.30	1.13	78955.42	20.57	10.44	0.87	185.03	13.81
30	2.52	56.60	11.40	10.36	1.11	79444.20	20.36	9.23	0.86	184.25	13.91
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.80	56.77	11.99	10.56	1.14	78318.96	20.24	8.83	0.87	184.51	13.95
最大值	4.10	64.93	13.52	10.92	1.20	79872.71	20.79	11.14	0.93	187.17	14.17
發生日期											
最小值	2.19	46.96	10.85	10.30	1.07	76483.08	19.46	5.26	0.82	180.40	13.61
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年4月30日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.20	45.02	12.51	9.79	1.04	77943.94	21.95	7.85	0.80	184.54	12.73
02	2.47	44.57	12.73	9.77	1.09	77849.64	21.60	7.67	0.84	183.91	12.61
03	2.45	46.64	13.01	10.04	1.11	76487.75	21.54	7.92	0.86	184.98	12.72
04	2.39	44.56	11.44	10.01	1.07	77260.26	21.88	7.77	0.83	185.86	12.90
05	1.94	47.59	11.97	9.71	1.07	77057.31	22.68	7.46	0.82	185.72	12.64
06	1.91	47.76	11.71	9.67	1.09	77354.22	22.92	7.25	0.84	185.71	12.68
07	2.16	48.13	11.39	9.88	1.09	78330.88	22.45	7.59	0.84	187.70	13.05
08	1.49	49.23	11.81	9.84	1.02	79573.34	22.43	7.57	0.78	192.17	13.34
09	1.48	51.26	12.76	9.89	0.99	79714.63	22.38	8.05	0.76	191.92	13.41
10	1.78	52.99	13.33	9.93	1.03	79890.42	21.71	8.49	0.79	193.16	13.41
11	2.01	56.40	13.52	9.91	1.05	79076.68	21.57	7.82	0.80	190.91	13.16
12	2.33	55.08	12.29	9.50	1.04	78737.67	22.72	7.82	0.80	187.45	12.73
13	2.30	56.64	11.89	9.42	1.07	79029.86	22.70	7.71	0.82	187.96	12.71
14	2.12	52.84	12.38	9.71	1.05	77094.16	21.91	4.99	0.81	186.29	12.54
15	2.89	53.57	12.09	9.80	1.01	78194.46	21.80	9.15	0.78	187.89	12.86
16	2.27	52.90	13.03	9.59	0.97	78618.68	22.38	7.58	0.75	189.20	12.79
17	1.88	53.53	12.25	9.75	1.02	78699.04	22.53	7.86	0.78	190.56	13.07
18	2.11	51.77	11.52	9.94	1.01	78829.57	21.88	8.68	0.78	190.57	13.19
19	2.39	50.81	12.77	9.76	0.97	78629.33	21.99	8.57	0.75	188.96	12.94
20	1.78	55.18	12.42	9.80	0.98	78324.42	21.71	7.52	0.76	188.54	12.86
21	1.64	57.63	12.49	10.01	1.00	78722.09	21.87	7.50	0.77	191.67	13.30
22	1.90	53.91	12.74	9.66	1.00	77731.07	22.42	7.92	0.77	188.18	12.72
23	1.92	50.66	12.40	9.51	1.01	78017.10	22.35	7.38	0.77	186.11	12.54
24	1.75	53.49	12.30	9.97	1.02	79019.28	21.92	8.76	0.78	190.25	13.27
25	1.55	55.25	13.69	9.98	1.08	78197.92	22.14	7.28	0.83	189.55	13.14
26	1.94	53.62	13.05	9.79	1.07	78726.81	21.91	7.60	0.83	189.50	12.98
27	1.92	53.07	13.01	9.67	1.01	76137.36	22.16	6.10	0.78	186.63	12.36
28	1.81	55.41	12.59	9.82	0.95	78774.55	22.37	6.95	0.74	190.48	13.15
29	2.06	52.68	12.38	9.80	0.95	77554.71	22.25	8.15	0.74	188.11	12.82
30	1.51	47.99	12.38	9.61	0.97	78705.15	22.54	6.28	0.75	187.18	12.81
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.05	51.67	12.46	9.78	1.03	78276.08	22.16	7.64	0.79	188.39	12.91
最大值	3.20	57.63	13.69	10.04	1.11	79890.42	22.92	9.15	0.86	193.16	13.41
發生日期											
最小值	1.48	44.56	11.39	9.42	0.95	76137.36	21.54	4.99	0.74	183.91	12.36
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管