

連續自動監測紀錄月報表

中華民國108年4月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	9.53	80.66	6.44	10.02	1.55	81584.31	18.97	8.45	0.65	149.33	12.52
02	8.33	78.38	4.13	9.97	1.56	82346.17	19.85	8.96	0.65	151.23	12.80
03	6.88	78.99	9.79	10.22	1.59	80360.44	19.39	8.92	0.66	151.13	12.71
04	8.15	79.69	8.60	9.94	1.60	80740.36	19.07	8.41	0.67	150.73	12.39
05	8.11	84.39	3.21	10.12	1.56	80918.90	19.57	6.67	0.65	151.09	12.71
06	8.93	83.55	5.09	10.06	1.54	81640.94	19.04	8.80	0.64	151.37	12.67
07	9.33	74.75	11.58	9.81	1.56	81656.25	19.02	10.26	0.65	151.47	12.40
08	8.93	74.34	9.40	9.81	1.58	81113.20	18.90	9.44	0.66	151.30	12.29
09	8.84	79.55	6.81	10.01	1.62	81278.88	19.16	9.04	0.67	152.04	12.60
10	9.20	83.46	4.66	10.04	1.61	81427.37	19.08	10.49	0.67	151.89	12.65
11	8.70	82.42	3.63	10.15	1.60	80951.78	18.53	10.03	0.67	151.04	12.60
12	9.32	85.18	5.74	10.17	1.53	81446.36	18.61	11.52	0.64	150.92	12.71
13	9.48	82.06	6.01	10.09	1.51	81229.68	18.51	11.51	0.63	150.45	12.55
14	8.80	79.22	6.17	10.02	1.53	81874.01	18.91	9.40	0.64	150.69	12.63
15	8.69	79.83	7.22	10.02	1.51	81635.47	18.64	8.52	0.63	149.96	12.53
16	8.70	81.60	5.51	10.01	1.55	82136.70	19.52	7.80	0.65	150.89	12.76
17	8.88	83.86	5.95	10.09	1.55	81691.18	18.86	9.80	0.65	151.25	12.70
18	8.78	82.70	6.45	10.06	1.57	81407.58	18.74	10.54	0.65	151.60	12.60
19	8.76	82.74	7.84	10.08	1.57	80047.20	19.22	9.64	0.65	151.01	12.46
20	8.70	81.71	6.19	10.01	1.61	79837.27	19.32	9.84	0.67	151.04	12.38
21	8.63	84.37	6.04	10.12	1.62	80655.31	19.36	9.32	0.68	152.05	12.66
22	8.68	83.16	5.53	10.00	1.58	80881.58	19.21	9.17	0.66	152.18	12.54
23	8.39	81.60	7.23	9.92	1.50	80860.02	19.88	9.49	0.62	152.13	12.55
24	8.70	77.48	11.47	9.71	1.39	81102.08	19.69	10.65	0.58	151.87	12.33
25	8.20	81.69	10.21	9.87	1.38	81719.61	18.99	10.86	0.57	152.36	12.50
26	8.29	85.05	7.10	10.21	1.34	81415.31	19.10	9.38	0.56	153.03	12.89
27	9.39	85.77	7.67	10.07	1.28	82637.47	19.08	11.66	0.53	152.62	12.89
28	9.54	79.29	11.84	9.87	1.32	83741.56	19.25	12.62	0.55	153.17	12.87
29	8.36	81.04	6.06	9.93	1.37	82474.57	19.45	9.19	0.57	153.10	12.77
30	8.97	79.46	6.48	9.99	1.34	82043.97	19.86	8.75	0.56	153.84	12.86
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	8.74	81.27	7.00	10.01	1.51	81428.52	19.16	9.64	0.63	151.56	12.62
最大值	9.54	85.77	11.84	10.22	1.62	83741.56	19.88	12.62	0.68	153.84	12.89
發生日期											
最小值	6.88	74.34	3.21	9.71	1.28	79837.27	18.51	6.67	0.53	149.33	12.29
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年4月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	18.94	65.06	15.89	14.87	3.27	65892.48	11.29	2.09	1.36	106.63	14.89
02	19.87	61.32	17.59	14.79	3.32	64667.06	12.06	1.28	1.38	108.40	14.65
03	19.85	61.86	23.42	14.90	3.29	63347.46	11.61	1.39	1.37	108.27	14.51
04	20.03	60.57	19.93	14.90	3.33	62949.68	11.92	1.53	1.39	109.90	14.54
05	19.33	58.33	22.61	14.96	3.23	65269.38	12.42	0.81	1.34	109.00	15.29
06	18.28	64.22	13.38	15.01	3.20	65194.66	11.69	1.11	1.33	109.23	15.25
07	19.43	57.57	22.62	14.86	3.22	66174.63	11.90	1.64	1.34	110.14	15.17
08	19.05	58.37	23.19	14.92	3.25	65447.35	11.65	0.98	1.35	110.56	15.14
09	18.47	68.07	22.54	15.05	3.28	63955.35	11.93	1.18	1.37	111.09	15.18
10	20.71	61.51	21.75	14.88	3.29	65947.96	12.16	1.57	1.37	110.86	15.24
11	15.17	63.59	31.99	15.27	3.12	63229.35	10.67	2.76	1.30	108.77	15.28
12	19.65	65.34	15.62	14.98	3.09	66626.95	11.38	1.25	1.29	107.97	15.42
13	18.53	68.52	12.69	15.13	3.04	64513.11	11.37	1.67	1.27	108.67	15.35
14	18.26	62.19	18.42	14.98	3.05	65613.55	11.72	1.13	1.27	109.06	15.29
15	21.31	57.13	23.95	14.97	3.10	66773.86	10.89	1.35	1.29	107.92	15.34
16	21.28	59.97	22.13	14.99	3.25	65553.39	11.83	0.68	1.35	107.82	15.26
17	19.57	65.69	17.65	15.08	3.26	64965.20	11.30	0.87	1.36	108.16	15.30
18	21.12	63.13	20.69	15.02	3.22	65087.28	11.36	1.20	1.34	108.24	15.15
19	18.90	69.12	15.20	15.30	3.21	62921.35	11.59	0.66	1.34	107.61	15.40
20	21.11	65.52	19.50	15.20	3.15	63721.04	11.46	0.95	1.31	107.69	15.33
21	25.01	62.85	23.27	15.10	3.10	64219.72	11.70	1.14	1.29	108.01	15.23
22	19.77	63.34	20.51	15.12	3.13	63841.39	11.71	0.86	1.30	108.58	15.20
23	21.29	61.12	23.00	14.88	3.14	66409.42	12.41	0.69	1.31	108.59	15.34
24	21.54	59.82	24.28	14.76	3.06	67366.24	11.99	1.27	1.27	108.02	15.17
25	22.29	59.15	26.94	14.94	3.01	66844.29	11.31	1.58	1.25	105.74	15.28
26	21.93	60.04	26.34	15.16	2.94	66544.97	11.14	0.58	1.23	101.79	15.59
27	21.67	60.60	23.13	15.21	2.98	66344.05	10.86	0.67	1.24	100.62	15.58
28	22.62	57.74	26.50	15.08	2.99	66627.27	11.46	0.62	1.24	101.82	15.44
29	23.97	53.83	30.41	15.17	2.98	65383.54	11.16	0.73	1.24	101.87	15.34
30	28.38	53.42	33.04	15.05	2.99	65891.57	11.77	1.88	1.25	102.69	15.27
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	20.58	61.63	21.94	15.02	3.15	65244.12	11.59	1.20	1.31	107.46	15.21
最大值	28.38	69.12	33.04	15.30	3.33	67366.24	12.42	2.76	1.39	111.09	15.59
發生日期											
最小值	15.17	53.42	12.69	14.76	2.94	62921.35	10.67	0.58	1.23	100.62	14.51
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管