

連續自動監測紀錄月報表

中華民國114年01月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.28	48.84	9.15	10.94	1.24	81917.81	17.10	8.74	0.96	188.78	14.70
02	3.96	45.32	6.95	10.79	1.24	81975.62	17.87	8.79	0.96	189.00	14.65
03	4.30	44.00	8.02	10.94	1.23	81875.77	17.42	8.85	0.95	190.53	14.81
04	4.78	44.71	8.73	11.12	1.25	80482.64	17.00	8.86	0.97	190.20	14.74
05	4.38	44.71	7.78	11.09	1.30	80556.03	17.41	9.08	1.00	190.06	14.77
06	4.55	43.43	6.09	11.05	1.27	80832.90	17.41	9.10	0.98	189.46	14.75
07	5.19	43.31	7.89	11.44	1.27	81844.17	16.02	9.15	0.99	183.82	15.11
08	4.46	42.76	7.82	11.28	1.29	81509.63	16.92	9.13	1.00	188.18	15.10
09	3.41	35.99	13.21	11.49	1.35	78342.08	16.52	8.89	1.04	189.92	14.82
10	4.13	41.10	10.54	11.84	1.35	76500.12	16.43	9.48	1.04	193.27	15.11
11	4.50	38.53	10.45	11.94	1.31	75780.29	16.54	9.28	1.01	191.63	15.11
12	4.73	36.43	9.13	11.89	1.31	75968.79	16.53	9.01	1.01	191.61	15.05
13	4.78	38.92	6.02	12.02	1.26	75975.23	16.23	7.54	0.98	186.13	15.03
14	4.39	39.19	10.35	11.80	1.24	74982.66	16.57	9.14	0.96	193.25	14.76
15	4.78	44.26	6.63	11.77	1.24	75888.27	16.98	9.33	0.96	190.97	14.90
16	4.77	57.18	5.56	11.72	1.25	75849.10	16.77	9.17	0.97	188.73	14.69
17	4.50	50.36	8.41	11.92	1.26	75080.41	16.47	9.17	0.98	189.72	14.84
18	4.62	51.13	8.54	11.92	1.28	75144.67	16.80	9.02	0.99	190.61	14.95
19	4.68	52.77	7.13	11.84	1.32	75019.66	17.27	9.46	1.01	189.96	14.85
20	4.60	49.37	6.52	11.69	1.31	75192.31	17.19	8.48	1.01	189.19	14.62
21	4.65	50.56	7.73	11.78	1.31	74932.94	16.87	9.43	1.00	189.52	14.66
22	4.85	51.10	8.72	11.82	1.26	74705.20	16.93	10.13	0.97	190.15	14.71
23	4.77	50.12	8.33	11.67	1.24	75603.71	16.90	9.93	0.96	188.74	14.60
24	4.66	50.35	8.97	11.45	1.26	77250.14	17.01	10.76	0.97	188.95	14.59
25	5.43	54.56	9.06	11.62	1.28	76186.94	16.54	11.09	0.99	188.32	14.56
26	4.90	53.18	7.49	11.69	1.24	76199.36	16.23	10.36	0.96	188.49	14.62
27	4.79	47.83	7.46	11.48	1.27	79180.08	16.21	10.50	0.98	187.77	14.82
28	4.35	48.78	6.87	11.50	1.28	80047.82	15.90	10.39	0.99	189.19	15.00
29	4.33	45.13	7.75	11.23	1.25	77927.66	16.54	10.13	0.97	184.90	14.19
30	3.95	46.22	5.62	11.30	1.25	76352.14	16.82	9.47	0.97	186.18	14.09
31	4.21	47.64	7.91	11.37	1.25	75990.33	16.75	9.98	0.97	186.86	14.12
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.54	46.38	8.09	11.53	1.27	77583.69	16.78	9.41	0.98	189.16	14.75
最大值	5.43	57.18	13.21	12.02	1.35	81975.62	17.87	11.09	1.04	193.27	15.11
發生日期											
最小值	3.41	35.99	5.56	10.79	1.23	74705.20	15.90	7.54	0.95	183.82	14.09
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年01月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	2.55	43.61	12.61	10.80	0.99	80716.70	17.82	8.49	0.76	193.71	14.58
02	2.54	43.38	12.16	10.77	1.03	80642.82	18.00	8.66	0.79	193.45	14.53
03	2.29	46.26	11.35	10.78	1.02	81579.40	18.06	8.81	0.78	195.71	14.81
04	2.84	47.01	11.08	10.94	0.97	80070.79	17.87	8.83	0.75	195.06	14.71
05	2.90	49.38	12.76	10.98	1.02	78944.85	17.87	8.76	0.78	194.03	14.52
06	2.88	46.22	11.09	10.70	1.01	79683.64	18.06	8.79	0.78	192.71	14.25
07	3.24	47.08	12.97	10.94	0.99	79968.01	17.00	9.30	0.76	192.95	14.46
08	2.21	47.26	13.94	10.74	1.05	79343.04	18.27	9.16	0.81	192.04	14.27
09	2.61	49.39	12.84	10.84	1.09	79964.27	17.61	8.48	0.84	192.93	14.44
10	2.12	41.27	13.07	11.07	1.12	79326.77	18.22	8.84	0.87	195.14	14.82
11	2.30	42.60	12.18	10.81	1.16	81482.70	17.95	9.16	0.90	194.80	14.78
12	2.77	42.80	12.46	10.87	1.18	80640.72	17.73	8.93	0.91	193.85	14.64
13	2.28	42.63	12.90	10.78	1.15	80550.90	18.13	8.26	0.89	193.42	14.56
14	2.80	47.19	13.16	11.23	1.16	80168.78	16.88	7.95	0.89	191.04	14.87
15	2.30	45.01	13.99	10.79	1.17	79836.53	18.13	8.70	0.90	193.37	14.45
16	2.32	39.27	13.60	10.72	1.16	80527.16	17.95	8.56	0.89	192.80	14.42
17	2.59	44.51	12.40	10.88	1.14	80187.54	17.31	8.73	0.87	192.26	14.46
18	2.86	41.32	14.46	10.96	1.10	79481.75	17.44	8.59	0.85	192.40	14.47
19	2.71	46.83	14.03	10.87	1.13	80608.24	18.24	8.64	0.87	193.83	14.72
20	2.97	43.83	13.79	10.73	1.14	80549.18	17.96	8.70	0.88	192.22	14.43
21	2.90	43.94	13.85	10.92	1.11	79609.12	17.54	9.22	0.86	192.55	14.47
22	2.80	43.67	14.66	10.97	1.13	78956.92	17.60	8.87	0.87	193.09	14.45
23	2.75	44.72	14.20	10.95	1.18	78971.03	17.43	9.36	0.91	191.89	14.35
24	3.13	47.87	13.58	11.00	1.15	77837.24	17.12	9.98	0.89	191.41	14.14
25	5.11	44.73	14.17	11.19	1.15	77318.22	16.59	10.08	0.89	191.73	14.24
26	4.35	42.89	14.54	11.00	1.16	78349.99	16.86	9.68	0.89	191.08	14.18
27	3.35	39.16	14.41	11.25	1.16	78312.51	15.90	10.12	0.89	190.40	14.35
28	3.28	42.74	13.20	11.44	1.15	78348.91	15.29	9.65	0.88	191.08	14.55
29	2.98	44.62	13.32	11.21	1.08	80182.98	16.00	9.59	0.83	192.13	14.71
30	2.61	44.92	11.42	11.10	1.01	79141.07	16.62	8.82	0.78	191.93	14.46
31	2.74	49.85	12.84	11.09	0.99	79091.45	16.63	9.73	0.76	193.32	14.47
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.84	44.71	13.13	10.95	1.10	79690.10	17.42	9.01	0.85	192.85	14.50
最大值	5.11	49.85	14.66	11.44	1.18	81579.40	18.27	10.12	0.91	195.71	14.87
發生日期											
最小值	2.12	39.16	11.08	10.70	0.97	77318.22	15.29	7.95	0.75	190.40	14.14
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管