

# 連續自動監測紀錄月報表

中華民國109年6月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	3.30	61.98	6.27	9.78	2.37	83548.00	19.68	14.24	0.99	177.75	13.54
02	3.55	67.05	4.41	9.91	2.38	83495.62	19.28	15.19	0.99	177.49	13.62
03	4.25	67.59	5.10	9.87	2.37	83431.33	19.14	15.25	0.99	177.63	13.53
04	4.74	66.00	5.82	9.76	2.35	82487.72	19.45	14.58	0.98	176.62	13.28
05	4.89	65.57	7.12	9.80	2.30	82824.29	19.53	15.89	0.96	177.34	13.42
06	3.73	67.01	6.90	9.71	2.26	82767.51	19.02	15.53	0.94	175.23	13.15
07	3.77	65.91	5.23	9.79	2.19	82157.42	19.40	16.85	0.91	174.60	13.20
08	3.56	65.33	6.22	9.72	2.17	83754.57	19.43	15.29	0.91	176.95	13.44
09	3.53	65.25	6.36	9.86	2.20	83574.86	19.14	15.51	0.92	177.92	13.57
10	3.81	66.63	4.01	9.84	2.28	83675.28	18.61	15.54	0.95	177.79	13.46
11	3.50	66.44	5.22	9.83	2.31	83415.48	19.04	15.83	0.96	177.61	13.48
12	3.55	65.60	7.18	9.74	2.27	83910.17	19.34	15.84	0.95	178.15	13.52
13	3.66	65.13	6.81	9.67	2.24	84230.20	19.78	16.74	0.93	178.90	13.58
14	3.44	64.84	6.32	9.71	2.20	84258.31	19.85	15.81	0.91	179.75	13.67
15	3.32	63.92	4.71	9.59	2.22	83305.11	19.72	14.95	0.92	177.48	13.28
16	3.31	63.68	6.24	9.65	2.23	82575.78	19.63	15.38	0.93	176.89	13.20
17	3.76	64.30	6.45	9.75	2.18	82970.39	19.12	15.83	0.91	178.80	13.36
18	3.53	65.33	7.06	9.68	2.18	83987.23	19.13	15.82	0.91	180.72	13.50
19	3.23	65.00	6.16	9.68	2.25	84598.95	19.33	15.52	0.94	182.94	13.69
20	3.60	65.54	8.05	9.87	2.24	83772.56	18.73	15.18	0.93	182.20	13.68
21	3.30	66.58	7.04	9.77	2.22	84005.86	18.99	15.93	0.92	182.74	13.63
22	3.39	65.02	5.34	9.58	2.21	83639.00	18.66	15.40	0.92	182.37	13.28
23	3.54	59.05	8.31	9.64	2.23	83830.43	18.70	15.55	0.93	181.14	13.37
24	3.73	66.27	7.42	9.64	2.25	84158.12	18.41	16.27	0.94	181.23	13.37
25	3.55	64.20	7.31	9.50	2.27	84007.62	19.02	16.07	0.94	180.60	13.26
26	3.47	66.14	4.48	9.86	2.20	82480.24	18.39	16.08	0.91	180.65	13.34
27	3.65	66.01	5.41	9.74	2.24	83390.80	18.63	15.72	0.93	181.77	13.43
28	3.47	65.64	4.93	9.77	2.23	82544.14	18.68	15.75	0.93	180.49	13.28
29	3.37	64.49	4.46	9.64	2.19	82640.79	18.55	14.48	0.91	179.82	13.10
30	3.30	63.88	6.38	9.58	2.19	82321.68	18.55	15.41	0.91	179.07	12.98
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.63	65.18	6.09	9.73	2.25	83391.98	19.10	15.58	0.94	179.09	13.41
最大值	4.89	67.59	8.31	9.91	2.38	84598.95	19.85	16.85	0.99	182.94	13.69
發生日期											
最小值	3.23	59.05	4.01	9.50	2.17	82157.42	18.39	14.24	0.91	174.60	12.98
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國109年6月30日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	4.28	64.73	10.74	9.90	2.58	78393.13	19.97	12.58	1.07	181.57	13.00
02	4.29	68.73	9.80	10.06	2.55	77396.03	19.69	15.34	1.06	180.65	12.95
03	4.86	69.03	10.12	10.09	2.56	76822.54	19.44	14.64	1.07	181.40	12.87
04	5.03	67.69	9.40	9.89	2.52	76926.25	19.86	14.73	1.05	179.43	12.67
05	4.74	67.44	9.60	10.11	2.38	75812.13	19.42	15.29	0.99	180.02	12.70
06	3.85	64.82	10.59	9.95	2.36	75649.80	19.31	14.11	0.98	177.76	12.41
07	3.79	66.28	8.73	10.08	2.39	75424.34	19.22	16.29	0.99	177.25	12.49
08	3.62	63.28	10.05	9.81	2.49	77390.44	19.46	14.44	1.04	178.67	12.58
09	3.26	66.25	11.09	10.04	2.57	76658.25	19.05	13.95	1.07	178.97	12.66
10	3.43	66.77	10.07	10.03	2.60	77660.61	19.19	14.05	1.08	181.71	12.91
11	3.44	67.38	10.20	10.05	2.57	76380.06	18.94	15.01	1.07	179.32	12.63
12	3.48	65.92	10.66	10.02	2.62	76485.00	19.33	14.16	1.09	179.99	12.69
13	3.73	65.22	12.08	9.90	2.64	76951.32	19.53	15.60	1.10	179.80	12.66
14	2.95	64.87	10.70	9.91	2.59	76175.66	19.95	13.70	1.08	180.12	12.61
15	3.27	61.83	9.98	9.73	2.49	77204.12	19.86	12.13	1.04	179.33	12.54
16	3.22	62.15	11.88	9.81	2.52	77124.54	19.95	14.18	1.05	180.30	12.66
17	3.66	61.31	11.19	9.82	2.56	77760.12	19.60	14.93	1.06	179.08	12.69
18	2.89	64.31	10.27	10.03	2.55	77284.73	19.31	14.14	1.06	179.64	12.81
19	3.43	66.46	9.31	10.13	2.60	78682.25	19.08	13.55	1.08	183.17	13.24
20	3.36	66.09	9.90	10.19	2.57	77266.78	18.65	14.27	1.07	181.49	12.96
21	2.92	66.44	9.17	9.99	2.49	77202.11	19.32	14.37	1.04	180.17	12.78
22	3.04	64.40	10.81	9.84	2.45	77641.31	18.88	13.79	1.02	178.90	12.57
23	3.90	63.85	12.24	9.84	2.47	77344.04	18.84	14.17	1.03	178.71	12.52
24	4.09	65.50	12.03	9.75	2.44	76702.35	18.65	16.00	1.01	179.59	12.31
25	3.67	65.17	11.10	9.69	2.48	77742.63	19.15	15.34	1.03	179.26	12.46
26	3.51	68.47	9.78	10.06	2.49	77509.50	18.70	14.92	1.04	181.89	12.86
27	3.31	64.74	10.29	9.95	2.47	77013.04	18.75	14.18	1.03	180.45	12.61
28	3.26	67.39	10.32	10.05	2.51	76372.77	18.94	14.30	1.05	181.48	12.68
29	3.35	66.60	11.87	9.88	2.47	77125.04	18.88	13.70	1.03	180.69	12.58
30	2.92	65.87	11.31	9.95	2.41	76253.72	19.08	13.99	1.00	180.86	12.56
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.62	65.63	10.51	9.95	2.51	77011.82	19.27	14.40	1.05	180.06	12.69
最大值	5.03	69.03	12.24	10.19	2.64	78682.25	19.97	16.29	1.10	183.17	13.24
發生日期											
最小值	2.89	61.31	8.73	9.69	2.36	75424.34	18.65	12.13	0.98	177.25	12.31
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管