

連續自動監測紀錄月報表

中華民國115年2月28日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	0.91	48.22	9.84	10.60	1.32	78075.01	19.32	8.81	1.02	198.24	14.21
02	0.77	49.20	9.61	10.52	1.32	78133.69	19.37	8.75	1.02	197.39	14.09
03	0.70	51.92	7.99	10.55	1.28	78607.08	19.30	8.64	0.99	198.75	14.25
04	0.62	50.16	8.51	10.56	1.25	77271.39	19.99	8.67	0.97	195.34	14.04
05	0.90	48.41	9.24	10.56	1.23	76801.54	20.00	8.74	0.95	189.93	13.80
06	1.03	49.26	10.34	10.60	1.23	77182.47	19.67	8.92	0.95	188.58	13.83
07	1.19	51.74	7.90	10.65	1.22	78281.74	18.91	8.83	0.94	187.52	13.93
08	1.21	50.53	6.18	10.63	1.21	79102.87	18.25	8.70	0.94	186.10	13.89
09	1.08	48.64	8.95	10.49	1.20	78628.77	18.65	8.35	0.92	185.40	13.66
10	1.04	50.87	8.50	10.61	1.22	78246.69	18.80	8.90	0.95	187.91	13.86
11	0.97	50.64	8.88	10.54	1.25	78017.23	19.13	8.70	0.97	186.19	13.73
12	1.51	51.22	10.31	10.67	1.22	77524.88	18.48	10.81	0.94	186.20	13.70
13	1.53	48.50	11.77	10.73	1.23	76935.12	18.66	10.87	0.95	186.76	13.72
14	1.58	51.04	11.48	10.90	1.24	75945.68	17.73	9.43	0.96	185.37	13.58
15	1.36	49.62	10.79	10.85	1.23	76023.86	17.99	9.26	0.95	186.35	13.60
16	1.22	50.18	11.18	10.94	1.22	76090.21	17.98	8.89	0.94	186.64	13.74
17	1.23	49.56	8.91	11.00	1.24	77916.84	17.85	8.33	0.96	189.32	14.20
18	1.43	49.23	10.19	10.92	1.21	78167.55	17.29	8.55	0.93	187.93	14.00
19	1.14	48.89	9.56	10.95	1.24	77621.80	17.79	7.83	0.96	189.08	14.06
20	0.76	45.28	10.74	11.02	1.25	76903.84	18.89	6.27	0.97	190.04	14.25
21	0.41	37.77	9.81	10.85	1.24	78585.65	19.92	4.79	0.96	192.86	14.61
22	0.31	32.90	9.61	10.81	1.24	78435.86	20.54	5.03	0.96	193.91	14.68
23	0.46	39.53	10.28	10.95	1.21	76939.66	19.99	5.80	0.93	192.25	14.43
24	0.46	40.30	9.33	11.24	1.19	75989.43	19.91	5.77	0.92	191.18	14.63
25	0.59	40.02	10.33	11.26	1.21	76139.00	19.50	7.78	0.94	190.16	14.58
26	0.50	36.47	9.55	11.19	1.18	75424.81	19.68	7.65	0.91	189.06	14.35
27	0.51	35.97	11.16	11.32	1.20	74728.31	20.12	8.35	0.93	188.35	14.47
28	0.94	34.51	11.04	11.40	1.23	74641.45	19.52	7.27	0.95	186.46	14.39
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	0.94	46.09	9.71	10.83	1.23	77227.23	19.04	8.17	0.95	189.76	14.08
最大值	1.58	51.92	11.77	11.40	1.32	79102.87	20.54	10.87	1.02	198.75	14.68
發生日期											
最小值	0.31	32.90	6.18	10.49	1.18	74641.45	17.29	4.79	0.91	185.37	13.58
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國115年2月28日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	2.27	49.10	12.42	11.32	1.21	79760.50	18.72	7.99	0.93	203.82	15.08
02	1.83	46.51	13.52	11.25	1.15	79307.90	18.81	8.09	0.89	203.58	14.93
03	1.70	47.35	12.75	11.37	1.17	78684.93	18.70	8.03	0.90	203.62	14.92
04	1.78	45.62	12.32	11.24	1.19	79069.23	19.44	8.01	0.92	205.59	15.00
05	2.24	45.31	14.67	11.32	1.17	78046.72	19.18	7.62	0.90	200.69	14.74
06	2.21	47.02	13.79	11.29	1.15	83059.36	19.08	8.32	0.89	200.60	14.88
07	2.54	47.15	12.34	11.33	1.12	80241.06	18.41	8.38	0.86	199.59	14.99
08	2.57	49.39	12.61	11.35	1.10	81705.64	17.75	8.37	0.84	199.99	15.18
09	2.58	46.34	11.98	11.31	1.08	81104.34	18.11	8.23	0.83	198.58	15.02
10	2.81	45.64	12.23	11.29	1.10	80144.95	18.68	8.49	0.84	198.46	14.93
11	2.52	46.26	13.30	11.32	1.07	79922.21	18.70	8.38	0.82	195.26	14.84
12	3.06	49.55	14.09	11.50	1.08	79118.56	18.14	8.72	0.83	193.47	14.79
13	3.93	46.05	13.64	11.43	1.09	78520.89	18.23	9.53	0.84	191.87	14.55
14	3.59	48.16	13.63	11.58	1.07	77506.71	17.54	9.04	0.83	190.70	14.42
15	3.36	49.98	12.14	11.53	1.08	77867.19	17.70	9.18	0.83	192.79	14.51
16	3.21	50.83	11.75	11.54	1.06	77550.81	17.50	9.01	0.82	191.61	14.39
17	2.95	49.18	12.56	11.53	1.02	78519.42	17.53	8.24	0.78	192.28	14.56
18	3.56	48.76	12.13	11.44	1.06	78679.80	17.17	8.51	0.82	190.98	14.36
19	2.40	48.99	11.27	11.24	1.14	79819.17	18.03	7.24	0.88	196.01	14.57
20	1.91	45.82	11.78	11.16	1.17	79070.89	19.29	7.97	0.90	194.04	14.51
21	1.31	43.58	12.15	11.17	1.15	79492.89	20.51	5.96	0.88	196.24	14.89
22	1.31	34.29	13.66	10.95	1.13	79852.26	21.33	5.24	0.87	196.37	14.79
23	1.11	33.42	12.39	10.91	1.14	80537.74	20.92	5.60	0.88	200.32	14.90
24	1.16	36.05	11.53	10.92	1.12	79765.32	21.15	6.46	0.86	198.21	14.75
25	1.59	38.42	11.27	11.09	1.09	79104.59	20.48	7.35	0.84	192.97	14.60
26	1.33	38.22	11.89	11.07	1.12	79214.69	20.55	7.19	0.86	193.94	14.62
27	1.45	39.75	11.99	11.09	1.14	79643.03	20.86	8.02	0.88	195.89	14.83
28	1.82	39.99	11.94	11.05	1.13	80180.48	20.57	7.58	0.87	196.03	14.84
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	2.29	44.88	12.56	11.27	1.12	79481.83	19.04	7.88	0.86	196.91	14.76
最大值	3.93	50.83	14.67	11.58	1.21	83059.36	21.33	9.53	0.93	205.59	15.18
發生日期											
最小值	1.11	33.42	11.27	10.91	1.02	77506.71	17.17	5.24	0.78	190.70	14.36
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管