

連續自動監測紀錄月報表

中華民國112年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫 ppm	氮氧化物 ppm	一氧化碳 ppm	氧氣 %	粉塵濃度 mg/m ³	排放流率 Nm ³ /hr	水份 %	鹽酸 ppm	不透光率 %	溫度 ℃	流速 m/s
01	4.48	56.47	9.06	11.33	1.19	74134.12	16.34	8.60	1.98	181.30	13.50
02	4.60	55.29	6.81	11.24	1.17	74563.02	16.88	8.29	1.95	181.49	13.54
03	5.29	55.78	6.95	11.39	1.21	73187.87	16.04	9.02	2.02	180.18	13.33
04	4.56	56.36	8.21	11.29	1.25	73072.15	16.45	8.91	2.08	180.74	13.25
05	4.69	57.03	8.04	11.33	1.26	73515.88	16.49	8.44	2.10	181.79	13.43
06	4.70	57.12	7.90	11.28	1.23	73561.76	16.36	8.36	2.05	180.74	13.31
07	4.54	57.26	7.49	11.21	1.21	73973.88	16.48	8.35	2.02	181.05	13.32
08	5.06	57.05	7.87	11.39	1.19	72637.93	15.85	8.40	1.98	181.02	13.22
09	5.00	57.44	7.72	11.41	1.19	72772.87	15.83	8.48	1.98	180.69	13.26
10	5.35	58.08	7.97	11.40	1.16	71785.15	15.47	9.50	1.94	178.31	12.95
11	4.89	58.07	7.33	11.47	1.16	72606.42	15.72	8.65	1.93	179.49	13.26
12	5.21	55.75	8.58	11.78	1.18	69774.24	15.47	8.16	1.97	178.45	13.10
13	5.37	56.82	8.74	11.64	1.21	71138.72	15.20	8.38	2.02	178.75	13.13
14	5.09	57.42	8.30	11.22	1.22	73399.55	15.77	8.49	2.04	179.12	13.06
15	5.28	57.14	7.57	11.35	1.18	73027.10	15.29	8.34	1.97	179.79	13.13
16	5.48	57.02	8.45	11.30	1.18	73691.90	15.75	8.60	1.96	179.38	13.23
17	5.37	56.52	7.48	11.31	1.14	73576.21	15.56	8.41	1.89	179.35	13.20
18	5.04	55.63	8.41	11.46	1.14	72558.96	15.63	8.52	1.89	179.51	13.24
19	5.50	56.14	8.40	11.62	1.14	71567.61	15.23	8.75	1.89	179.09	13.19
20	5.44	55.89	7.81	11.50	1.11	72058.98	15.65	8.13	1.85	179.57	13.20
21	5.03	55.34	7.74	11.54	1.11	72231.33	15.42	8.05	1.84	182.74	13.34
22	4.85	55.91	7.91	11.58	1.12	71658.78	15.61	7.46	1.86	180.90	13.27
23	5.09	56.90	7.51	11.56	1.11	71496.86	15.65	8.39	1.86	179.74	13.18
24	4.99	56.36	8.71	11.42	1.11	72160.31	15.72	8.66	1.85	182.16	13.19
25	4.97	55.86	8.84	11.49	1.13	72151.80	15.67	8.78	1.89	180.80	13.24
26	5.26	55.61	8.32	11.59	1.13	70866.05	14.98	8.40	1.89	180.62	13.04
27	5.63	54.76	8.15	11.72	1.15	70188.23	15.26	8.24	1.91	179.36	13.09
28	5.28	55.66	7.57	11.80	1.12	70360.53	15.16	8.68	1.86	180.28	13.24
29	5.39	56.51	6.95	11.78	1.12	70005.92	15.18	8.14	1.87	179.88	13.15
30	5.62	55.19	8.19	11.67	1.13	71240.91	15.16	8.22	1.88	180.42	13.22
31	5.29	55.37	8.20	11.61	1.13	70766.93	15.06	8.50	1.88	179.01	13.01
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	5.11	56.38	7.97	11.47	1.16	72249.42	15.69	8.46	1.94	180.18	13.22
最大值	5.63	58.08	9.06	11.80	1.26	74563.02	16.88	9.50	2.10	182.74	13.54
發生日期											
最小值	4.48	54.76	6.81	11.21	1.11	69774.24	14.98	7.46	1.84	178.31	12.95
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國112年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.51	51.06	10.45	11.17	1.48	77105.44	17.87	8.04	2.47	188.80	14.32
02	3.56	51.37	8.71	10.98	1.44	78082.81	18.74	8.84	2.41	189.32	14.38
03	4.82	50.72	8.50	11.02	1.39	77734.36	18.06	11.20	2.31	188.16	14.21
04	3.55	51.89	8.93	10.92	1.37	77909.92	18.55	9.39	2.29	189.60	14.23
05	3.55	51.84	8.61	10.96	1.38	78245.86	18.59	8.57	2.30	190.59	14.40
06	4.24	51.19	8.90	10.98	1.40	77448.81	18.21	8.46	2.33	189.15	14.16
07	3.95	51.69	9.93	10.90	1.42	78635.50	18.60	7.61	2.37	189.29	14.34
08	4.76	50.84	9.28	10.96	1.46	77894.04	18.09	8.12	2.43	188.63	14.19
09	5.02	51.13	9.20	10.90	1.44	78123.35	17.99	10.60	2.40	188.91	14.14
10	5.15	51.62	8.62	10.94	1.38	76346.77	17.53	10.45	2.29	185.72	13.70
11	4.49	56.13	9.18	11.13	1.35	76557.59	17.33	8.75	2.24	187.10	14.01
12	4.49	53.61	10.41	11.12	1.38	77007.31	17.55	8.92	2.30	186.97	14.12
13	4.34	53.97	9.54	11.06	1.39	77261.86	17.76	8.80	2.32	187.61	14.13
14	4.02	51.60	9.90	10.80	1.40	78289.95	17.69	8.22	2.33	189.86	13.99
15	3.90	53.84	8.83	10.97	1.35	77858.17	17.49	7.16	2.26	189.66	14.13
16	5.42	52.59	7.96	11.12	1.34	76777.68	17.28	9.19	2.23	187.56	14.04
17	4.43	53.40	8.36	11.01	1.28	77607.28	17.57	8.34	2.14	187.39	14.07
18	4.35	53.97	10.18	11.10	1.27	77010.81	17.53	8.21	2.12	187.58	14.10
19	4.66	54.71	8.40	11.19	1.32	76385.84	17.07	9.60	2.19	187.16	14.01
20	4.59	52.61	8.07	10.94	1.35	77619.56	17.88	8.11	2.25	187.88	14.04
21	3.69	53.49	7.83	10.91	1.39	77809.70	17.84	7.45	2.31	188.46	14.05
22	3.87	52.78	8.70	10.99	1.37	77225.77	17.74	5.93	2.28	188.45	14.04
23	3.92	53.51	8.36	11.05	1.36	77150.98	17.68	7.69	2.27	188.61	14.11
24	4.32	51.88	9.71	10.78	1.37	77913.17	17.98	9.20	2.29	187.72	13.89
25	4.47	53.63	8.76	11.01	1.37	76768.01	17.56	8.60	2.28	188.05	13.94
26	4.43	52.67	8.38	11.10	1.32	75550.45	16.96	9.40	2.21	187.91	13.74
27	4.15	52.74	7.30	11.00	1.35	76034.84	17.77	6.86	2.25	187.88	13.83
28	3.88	52.40	7.81	11.06	1.38	76281.79	17.48	7.27	2.30	187.49	13.88
29	3.79	53.37	8.24	11.19	1.39	75959.03	17.46	5.52	2.32	188.39	14.06
30	4.81	51.00	9.52	10.99	1.40	77320.18	17.21	7.23	2.34	187.46	13.96
31	4.74	51.84	8.07	10.77	1.41	77350.22	17.50	7.90	2.34	185.61	13.64
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.29	52.55	8.86	11.00	1.38	77266.68	17.76	8.38	2.30	188.16	14.06
最大值	5.42	56.13	10.45	11.19	1.48	78635.50	18.74	11.20	2.47	190.59	14.40
發生日期											
最小值	3.51	50.72	7.30	10.77	1.27	75550.45	16.96	5.52	2.12	185.61	13.64
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管