

連續自動監測紀錄月報表

中華民國114年05月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	1.81	54.67	7.21	9.94	1.33	79026.63	20.36	8.35	1.03	182.41	13.25
02	2.11	54.57	9.91	10.10	1.32	78881.37	19.72	8.14	1.02	182.32	13.31
03	2.18	56.37	8.09	10.05	1.32	78694.72	20.20	8.32	1.02	182.45	13.30
04	2.29	56.48	6.97	9.95	1.37	79845.88	21.12	8.47	1.06	184.58	13.59
05	2.28	55.36	8.23	9.88	1.36	78866.72	21.05	8.64	1.05	183.14	13.28
06	2.06	55.18	9.41	9.92	1.34	79755.19	20.94	8.28	1.04	184.38	13.51
07	2.00	55.40	9.25	10.21	1.30	80087.46	20.17	8.17	1.00	184.16	13.77
08	1.27	57.78	9.11	9.93	1.32	80577.23	20.80	7.92	1.02	191.80	13.84
09	1.80	55.04	10.98	9.95	1.31	79977.72	21.24	7.72	1.01	186.82	13.71
10	1.79	53.96	8.91	9.98	1.33	80048.46	20.94	8.29	1.02	185.19	13.65
11	2.22	52.74	9.00	9.98	1.31	89037.14	20.63	8.02	1.01	184.41	13.63
12	2.34	53.97	8.16	9.91	1.30	80267.14	20.19	7.88	1.00	183.17	13.42
13	1.59	55.60	8.62	10.11	1.32	80855.90	20.70	7.45	1.02	187.52	14.00
14	1.67	52.22	9.75	9.81	1.32	80348.16	21.30	7.79	1.02	185.36	13.57
15	1.42	53.78	10.07	9.85	1.33	80681.91	21.32	7.29	1.03	187.31	13.74
16	1.53	55.54	9.37	9.82	1.33	79051.79	21.12	7.68	1.03	184.49	13.30
17	1.43	58.70	9.59	9.88	1.34	78642.57	21.11	7.68	1.03	184.18	13.29
18	1.82	61.99	8.57	9.68	1.34	80297.84	21.54	8.12	1.04	184.85	13.42
19	2.02	56.86	7.48	9.73	1.27	79693.65	21.60	7.73	0.98	184.90	13.39
20	2.18	54.86	7.66	9.78	1.29	80101.43	21.61	7.70	0.99	186.38	13.58
21	1.65	54.16	8.69	9.93	1.25	80189.47	21.32	6.57	0.97	186.84	13.73
22	2.12	47.15	10.07	9.61	1.27	79552.97	21.52	7.50	0.98	184.12	13.21
23	2.38	48.99	10.65	9.93	1.27	79498.12	21.12	10.34	0.98	184.90	13.53
24	2.70	47.72	10.84	9.92	1.23	79230.48	20.91	9.35	0.95	183.61	13.40
25	2.92	46.71	10.61	9.78	1.19	80250.32	20.80	9.95	0.92	183.41	13.36
26	2.54	43.70	10.74	10.12	1.19	80378.58	20.39	8.02	0.92	180.10	13.66
27	1.22	49.23	8.76	9.79	1.24	79645.48	21.42	7.70	0.96	185.41	13.44
28	1.01	54.14	8.95	9.91	1.26	80544.17	21.43	7.78	0.97	187.51	13.80
29	1.47	52.60	11.19	9.91	1.24	80429.06	21.17	8.96	0.96	185.77	13.70
30	1.03	49.11	11.31	9.87	1.27	80340.65	20.94	8.07	0.98	184.99	13.57
31	1.03	49.50	11.42	9.80	1.27	79899.09	21.21	7.54	0.98	185.21	13.46
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.87	53.36	9.34	9.90	1.29	80151.53	20.96	8.11	1.00	184.89	13.53
最大值	2.92	61.99	11.42	10.21	1.37	89037.14	21.61	10.34	1.06	191.80	14.00
發生日期											
最小值	1.01	43.70	6.97	9.61	1.19	78642.57	19.72	6.57	0.92	180.10	13.21
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年05月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H2O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	3.70	49.17	12.32	10.38	0.98	72874.19	19.41	8.14	0.76	184.88	12.66
02	4.02	51.41	12.51	10.57	0.94	73090.85	18.87	7.82	0.72	185.55	12.87
03	4.09	53.69	12.22	10.61	0.92	73419.61	19.06	7.90	0.71	187.04	13.04
04	4.15	52.03	11.72	10.38	0.88	73750.48	19.96	7.36	0.67	186.87	12.96
05	4.03	51.44	13.30	10.12	0.87	73294.42	20.17	7.30	0.67	184.08	12.51
06	3.52	50.51	13.61	10.29	0.83	73591.90	20.10	7.49	0.63	185.83	12.81
07	3.92	49.67	13.36	10.64	0.75	73283.98	19.28	7.73	0.57	185.59	13.05
08	3.80	51.95	13.15	10.35	1.07	73638.48	19.84	7.53	0.83	186.95	12.87
09	3.47	51.08	12.49	10.54	1.33	73082.94	19.95	7.39	1.02	187.96	13.06
10	3.57	50.12	12.77	10.46	1.30	73602.43	20.04	7.49	1.00	187.18	13.05
11	4.54	50.80	12.58	10.60	1.31	73157.48	19.28	7.54	1.01	185.76	12.98
12	4.50	51.88	12.90	10.48	1.38	73798.18	19.09	7.48	1.06	185.01	12.90
13	3.58	53.70	11.73	10.64	1.42	74852.25	19.61	6.12	1.10	189.86	13.51
14	3.40	51.92	12.26	10.46	1.41	73894.84	19.84	6.97	1.08	188.19	13.07
15	2.92	52.19	12.54	10.43	1.35	74978.29	20.04	7.07	1.04	190.85	13.36
16	3.10	54.90	13.15	10.52	1.32	73670.13	19.62	7.56	1.01	188.81	13.12
17	2.89	54.62	12.73	10.43	1.31	73658.16	19.98	7.63	1.00	187.81	13.03
18	3.35	58.36	11.67	10.26	1.33	74255.39	20.37	7.40	1.02	187.51	12.98
19	3.76	52.41	11.09	10.12	1.28	74340.49	20.61	7.40	0.99	186.61	12.85
20	3.27	54.53	11.49	10.33	1.28	73856.34	20.38	7.36	0.99	188.33	13.01
21	3.17	51.27	12.61	10.38	1.29	74448.27	20.43	6.89	0.99	189.58	13.22
22	3.39	47.33	13.14	10.24	1.30	74177.44	20.35	6.31	1.00	188.41	12.97
23	3.92	52.46	14.79	10.83	1.38	72911.72	19.25	8.72	1.06	189.51	13.33
24	4.21	51.94	13.10	10.80	1.39	73003.92	19.34	8.76	1.07	188.84	13.30
25	4.35	47.48	14.05	10.59	1.38	73852.93	19.40	9.12	1.06	187.98	13.17
26	4.32	45.07	12.92	10.61	1.38	74861.01	19.55	8.96	1.06	188.62	13.42
27	3.59	52.01	12.10	11.13	1.34	76673.20	19.00	7.88	1.03	188.92	14.38
28	3.84	52.61	12.57	10.66	1.33	75284.35	19.48	8.51	1.03	191.84	13.64
29	3.01	49.95	13.37	10.29	1.35	76867.97	19.51	7.98	1.04	189.41	13.38
30	2.90	47.86	11.31	9.91	1.36	80791.42	19.33	7.33	1.05	191.45	13.62
31	3.00	47.87	11.32	9.72	1.35	79440.66	19.67	7.14	1.04	188.88	13.14
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.65	51.36	12.61	10.44	1.23	74400.12	19.70	7.62	0.95	187.87	13.14
最大值	4.54	58.36	14.79	11.13	1.42	80791.42	20.61	9.12	1.10	191.84	14.38
發生日期											
最小值	2.89	45.07	11.09	9.72	0.75	72874.19	18.87	6.12	0.57	184.08	12.51
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管