

連續自動監測紀錄月報表

中華民國110年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.07	59.88	8.26	9.65	1.08	82771.29	18.67	11.65	0.72	181.51	13.22
02	3.22	54.02	9.34	9.46	1.00	83513.56	19.18	11.76	0.67	181.69	13.20
03	2.66	60.17	6.70	9.61	0.98	83142.29	18.76	11.83	0.65	181.93	13.25
04	2.67	55.73	7.41	9.46	1.01	82800.68	19.39	11.68	0.67	181.88	13.13
05	3.11	58.52	7.86	9.38	1.02	83874.24	19.26	12.18	0.68	180.81	13.15
06	2.56	62.18	6.47	9.64	0.96	83086.55	18.82	11.94	0.64	181.40	13.27
07	2.40	64.65	5.67	9.76	0.89	82992.62	18.29	11.73	0.59	180.78	13.29
08	2.50	64.84	5.26	9.48	0.94	83569.80	19.30	11.89	0.63	181.88	13.25
09	3.18	64.91	5.60	9.45	0.99	83433.68	18.78	11.99	0.66	181.44	13.10
10	2.33	64.28	6.89	9.61	0.99	83711.71	18.62	11.67	0.66	183.00	13.35
11	2.89	62.14	6.76	9.53	0.99	84123.62	19.02	11.81	0.66	182.66	13.38
12	3.12	59.27	7.44	9.36	0.97	83886.05	19.25	12.13	0.65	181.48	13.15
13	2.36	62.07	8.28	9.62	1.22	82520.18	18.87	12.15	0.80	181.04	13.16
14	2.87	59.23	6.66	9.58	1.52	82230.75	18.49	12.00	1.01	180.70	12.99
15	2.83	63.49	5.71	9.58	1.52	82092.88	19.06	11.70	1.01	181.65	13.09
16	3.09	63.81	7.36	9.84	1.49	83840.30	18.55	11.63	0.99	178.73	13.51
17	2.88	63.31	7.03	9.61	1.47	83816.71	18.90	10.89	0.98	182.93	13.41
18	3.35	62.52	7.79	9.56	1.44	83423.99	18.56	11.16	0.96	181.97	13.22
19	3.22	65.96	7.24	9.52	1.37	83266.96	18.29	12.10	0.92	180.97	13.08
20	2.79	64.53	7.53	9.51	1.42	83392.67	18.71	11.56	0.95	182.20	13.19
21	2.86	59.94	6.65	9.50	1.41	82843.93	18.65	11.90	0.94	180.92	13.04
22	2.98	63.14	7.26	9.49	1.41	82811.23	19.08	11.89	0.94	182.02	13.12
23	3.41	65.13	7.03	9.43	1.46	83251.74	18.90	11.58	0.97	181.83	13.08
24	3.20	64.53	7.09	9.45	1.47	83504.80	18.99	11.72	0.98	182.74	13.19
25	3.30	61.62	6.85	9.44	1.42	83447.69	18.96	11.66	0.94	182.02	13.15
26	3.39	65.78	7.29	9.60	1.42	83690.17	18.22	11.86	0.94	182.64	13.26
27	3.33	64.86	8.62	9.67	1.39	82504.79	18.25	11.94	0.93	181.95	13.15
28	3.86	63.14	8.00	9.45	1.42	82415.26	18.42	12.22	0.95	179.98	12.85
29	3.48	63.96	9.26	9.83	1.43	81902.18	17.33	11.89	0.96	176.81	12.96
30	3.50	63.69	7.37	10.23	1.41	83113.30	17.32	11.59	0.94	172.61	13.49
31	3.02	65.75	7.65	10.18	1.39	82276.59	17.28	11.62	0.93	173.79	13.33
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.01	62.49	7.24	9.60	1.25	83137.17	18.65	11.78	0.84	180.90	13.19
最大值	3.86	65.96	9.34	10.23	1.52	84123.62	19.39	12.22	1.01	183.00	13.51
發生日期											
最小值	2.33	54.02	5.26	9.36	0.89	81902.18	17.28	10.89	0.59	172.61	12.85
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年8月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.20	63.55	9.95	10.22	1.43	82707.55	18.37	11.85	0.95	192.87	14.21
02	4.56	60.96	11.75	10.40	1.39	83438.01	18.20	12.04	0.93	189.83	14.44
03	4.33	64.09	9.69	10.69	1.43	83096.97	17.98	11.74	0.95	189.67	14.77
04	5.35	59.14	9.47	10.01	1.50	82517.61	19.08	11.98	1.00	192.64	14.01
05	4.08	58.96	9.87	10.08	1.53	83003.28	19.21	11.83	1.02	193.76	14.25
06	3.96	62.74	9.96	10.10	1.53	83114.07	18.98	11.79	1.02	194.22	14.27
07	3.83	62.81	9.35	10.13	1.50	83055.74	18.75	11.88	1.00	193.27	14.22
08	3.12	63.08	8.27	9.99	1.47	83323.62	19.46	11.28	0.98	195.11	14.27
09	4.09	65.43	8.85	10.01	1.49	82934.54	18.91	11.67	1.00	193.62	14.07
10	3.90	63.24	9.99	10.07	1.51	82761.63	18.79	11.61	1.00	193.62	14.11
11	3.90	63.74	10.61	10.03	1.50	82872.35	18.90	11.49	1.00	194.66	14.13
12	4.37	63.65	10.28	9.94	1.54	82666.74	18.93	11.78	1.02	194.02	13.96
13	3.65	66.06	9.80	10.15	1.56	82336.00	19.20	11.94	1.04	195.25	14.28
14	4.32	61.32	9.32	10.11	1.59	82474.40	18.79	11.89	1.06	193.66	14.12
15	4.25	65.29	8.83	10.01	1.58	82289.66	19.19	11.47	1.05	193.78	14.03
16	4.78	66.10	10.27	10.02	1.59	83622.15	18.95	11.53	1.06	194.67	14.25
17	4.83	68.11	11.36	10.54	1.60	83211.12	18.17	11.13	1.07	193.83	14.72
18	5.25	66.40	10.02	10.20	1.61	83322.52	18.51	11.95	1.07	194.41	14.35
19	4.95	66.67	12.73	10.20	1.60	82778.02	18.13	12.20	1.07	193.12	14.15
20	4.37	64.95	10.81	10.15	1.55	82829.35	18.75	12.03	1.03	194.29	14.25
21	4.49	62.07	10.34	10.20	1.51	82389.48	18.70	12.00	1.01	194.29	14.23
22	4.81	62.84	10.25	10.25	1.52	82857.40	18.58	11.52	1.01	195.11	14.38
23	5.39	65.85	9.52	10.21	1.52	83157.56	18.50	11.53	1.01	194.41	14.35
24	4.61	64.24	11.28	10.29	1.56	83115.38	18.40	11.49	1.04	195.82	14.47
25	4.66	63.94	10.44	10.31	1.61	83538.95	18.40	11.64	1.07	195.95	14.57
26	5.04	63.82	10.74	10.29	1.60	84608.53	18.13	12.00	1.07	196.40	14.69
27	5.08	61.07	11.25	10.41	1.58	83241.54	17.94	12.38	1.06	194.98	14.55
28	4.87	56.66	11.84	10.26	1.54	82621.60	18.11	12.73	1.02	193.31	14.21
29	5.30	55.81	10.17	10.57	1.50	81636.27	17.24	12.23	1.00	188.87	14.17
30	4.50	61.98	10.76	10.88	1.52	83663.20	17.51	10.70	1.01	185.71	14.91
31	4.51	62.56	9.80	10.73	1.50	83573.23	17.86	12.17	1.00	187.05	14.78
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.50	63.13	10.24	10.24	1.53	82992.21	18.54	11.79	1.02	193.30	14.33
最大值	5.39	68.11	12.73	10.88	1.61	84608.53	19.46	12.73	1.07	196.40	14.91
發生日期											
最小值	3.12	55.81	8.27	9.94	1.39	81636.27	17.24	10.70	0.93	185.71	13.96
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管