

連續自動監測紀錄月報表

中華民國111年10月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	5.06	61.65	7.93	9.91	1.07	79151.01	17.42	10.20	0.71	179.97	12.71
02	4.89	60.22	7.23	9.78	1.06	79165.69	17.91	10.32	0.71	179.93	12.64
03	4.84	59.75	7.32	9.59	1.08	80072.21	18.16	10.75	0.72	180.09	12.60
04	4.71	60.46	9.77	9.91	1.08	79371.50	17.71	10.60	0.72	181.08	12.81
05	4.85	59.51	8.80	9.91	1.07	79151.06	17.56	10.12	0.71	180.28	12.74
06	5.09	61.43	8.40	10.41	0.99	79206.18	16.93	9.58	0.67	175.56	13.13
07	4.27	59.92	8.90	9.78	1.02	80123.89	18.75	10.56	0.68	180.79	12.93
08	4.49	60.19	8.95	9.85	1.01	80261.84	18.47	10.55	0.67	181.17	13.01
09	4.57	60.76	6.48	9.85	0.98	80358.47	18.41	11.15	0.65	181.32	13.01
10	4.75	61.44	6.46	9.90	0.94	80331.95	17.67	10.90	0.63	180.26	12.93
11	4.71	63.44	9.38	10.18	0.97	79918.55	17.23	10.07	0.65	183.21	13.21
12	4.02	59.84	10.45	10.46	1.04	78806.68	16.92	9.04	0.69	180.29	13.25
13	3.43	51.25	9.59	10.08	1.00	78710.95	17.71	11.55	0.67	179.97	12.87
14	3.15	51.76	8.19	10.04	0.95	79804.58	18.57	11.25	0.64	182.51	13.21
15	3.25	50.37	7.68	9.95	0.92	79638.93	18.69	11.14	0.62	181.51	13.08
16	3.20	50.74	7.74	9.87	0.83	79427.07	18.82	11.74	0.55	180.79	12.94
17	3.31	49.30	7.34	9.80	0.72	78935.96	18.62	11.73	0.48	178.85	12.70
18	3.28	54.55	7.45	10.12	0.71	80067.66	17.94	11.67	0.47	181.17	13.22
19	3.35	52.06	7.24	10.01	0.85	79914.47	18.01	12.20	0.56	180.73	13.05
20	3.06	48.14	5.96	9.88	0.94	79747.05	18.47	11.64	0.63	181.39	12.97
21	3.42	47.48	7.17	10.04	0.99	78819.04	18.01	11.60	0.66	181.18	12.93
22	3.61	48.74	7.80	9.97	0.92	78780.67	18.34	12.10	0.62	180.88	12.87
23	3.53	49.18	7.05	9.97	0.87	79492.39	18.32	11.42	0.58	181.66	13.03
24	3.67	49.49	8.02	9.98	1.25	78764.48	17.42	11.62	0.84	179.12	12.70
25	3.79	50.93	8.35	10.08	1.63	79278.77	17.06	11.72	1.09	180.03	12.88
26	3.93	48.11	7.94	10.11	1.66	78602.39	16.89	12.14	1.10	179.12	12.74
27	3.42	48.94	7.29	10.01	1.64	78527.63	17.31	11.72	1.09	179.43	12.68
28	3.36	49.88	7.54	10.06	1.58	78743.12	17.87	11.41	1.05	181.11	12.92
29	3.54	48.63	8.28	10.00	1.56	78292.24	17.76	12.18	1.04	179.70	12.72
30	3.24	48.87	7.57	9.87	1.59	79595.66	18.62	11.64	1.06	181.34	12.95
31	3.56	51.19	5.85	10.07	1.47	79355.66	17.86	11.87	0.98	181.73	13.04
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.91	54.14	7.87	9.98	1.11	79368.31	17.92	11.17	0.74	180.52	12.92
最大值	5.09	63.44	10.45	10.46	1.66	80358.47	18.82	12.20	1.10	183.21	13.25
發生日期											
最小值	3.06	47.48	5.85	9.59	0.71	78292.24	16.89	9.04	0.47	175.56	12.60
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國111年10月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	4.19	60.98	8.51	10.76	1.18	80506.18	16.80	11.67	0.78	192.59	14.27
02	3.66	60.61	6.81	10.61	1.21	80488.21	17.52	10.95	0.80	192.16	14.17
03	3.73	60.09	8.66	10.50	1.23	81468.82	17.64	10.40	0.82	193.63	14.25
04	3.66	58.91	11.17	10.80	1.29	80388.97	17.06	11.26	0.86	194.09	14.40
05	4.27	61.15	10.01	11.10	1.29	81085.72	16.73	10.52	0.87	189.15	14.76
06	3.85	58.78	7.73	10.63	1.27	81345.92	17.18	11.03	0.85	190.92	14.25
07	3.23	61.81	8.05	10.67	1.31	81519.12	18.08	10.74	0.88	192.88	14.57
08	3.89	61.59	7.99	10.70	1.31	81590.50	17.74	11.62	0.88	192.47	14.55
09	3.94	61.46	7.41	10.62	1.34	81912.26	17.84	11.38	0.90	191.83	14.48
10	4.12	59.58	6.05	10.49	1.34	83110.31	17.59	11.51	0.90	191.55	14.45
11	4.27	61.69	6.99	11.01	1.35	81098.39	16.67	10.90	0.90	192.73	14.71
12	4.66	58.92	8.93	11.14	1.38	79053.08	16.51	11.55	0.92	190.69	14.46
13	3.91	58.96	7.57	10.97	1.40	79856.32	17.28	11.36	0.93	192.47	14.53
14	3.68	59.00	7.30	10.94	1.46	79883.46	17.93	10.96	0.97	193.28	14.64
15	3.64	58.82	7.11	10.91	1.50	79589.73	17.98	11.55	1.00	191.65	14.50
16	3.50	55.72	7.46	10.64	1.50	79334.50	18.51	11.72	1.00	190.11	14.12
17	3.46	56.42	8.68	10.56	1.51	79700.21	18.25	11.80	1.01	188.61	13.98
18	3.92	60.38	6.36	10.95	1.44	79976.09	17.39	12.06	0.96	190.96	14.50
19	4.28	58.76	8.40	10.90	1.38	80206.92	17.42	11.92	0.92	191.14	14.48
20	3.66	57.14	6.38	10.75	1.41	80637.48	17.88	11.59	0.94	191.20	14.42
21	3.60	56.77	7.83	10.79	1.46	79467.96	17.70	11.93	0.97	192.04	14.26
22	3.81	54.88	6.67	10.65	1.50	79143.00	18.09	11.93	0.99	189.83	14.01
23	3.97	55.78	7.28	10.65	1.44	79669.97	18.04	11.87	0.96	190.06	14.11
24	4.22	59.23	7.29	10.92	1.67	79863.33	16.74	11.94	1.12	190.71	14.32
25	4.34	61.96	8.36	11.24	1.91	79532.79	16.05	11.62	1.27	192.12	14.64
26	4.38	60.41	6.74	11.26	1.88	79278.03	16.10	12.04	1.25	192.62	14.65
27	4.19	60.87	8.35	11.10	1.78	79591.33	16.64	11.56	1.19	192.78	14.58
28	3.88	60.11	6.89	11.11	1.70	79604.68	17.17	11.70	1.13	193.52	14.72
29	4.26	60.66	8.53	11.12	1.65	79026.78	16.93	12.48	1.10	191.98	14.53
30	4.35	58.35	8.24	10.91	1.60	80577.89	17.79	12.00	1.07	193.11	14.70
31	4.62	58.95	8.56	10.84	1.59	81051.58	17.64	12.15	1.06	193.20	14.64
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.97	59.31	7.82	10.85	1.46	80308.37	17.38	11.54	0.97	191.81	14.44
最大值	4.66	61.96	11.17	11.26	1.91	83110.31	18.51	12.48	1.27	194.09	14.76
發生日期											
最小值	3.23	54.88	6.05	10.49	1.18	79026.78	16.05	10.40	0.78	188.61	13.98
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長 維修組長 操作組長 值班主管