

連續自動監測紀錄月報表

中華民國107年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P001			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	1.62	73.57	19.56	14.66	0.82	66387.77	24.05	11.09	0.41	114.76	11.54
02	4.72	70.57	22.82	14.57	1.33	66980.90	25.09	8.45	0.66	116.43	11.52
03	6.67	68.98	27.91	14.55	1.60	67175.86	24.91	9.07	0.80	116.82	11.55
04	7.03	68.90	28.38	14.58	1.79	66616.87	25.00	12.28	0.89	116.68	11.49
05	3.47	72.64	23.09	14.69	1.61	65980.74	24.84	13.89	0.80	115.38	11.53
06	3.74	74.77	19.45	14.72	1.62	65692.12	24.06	15.53	0.81	114.70	11.52
07	5.83	76.98	16.22	14.62	1.88	67071.61	24.58	13.65	0.94	115.16	11.59
08	4.87	73.92	20.71	14.58	2.00	67042.40	24.86	9.96	1.00	114.97	11.51
09	0.82	77.72	20.82	14.77	1.40	65450.26	23.38	10.31	0.70	111.68	11.49
10	3.78	83.03	21.39	14.81	1.19	65098.75	23.03	14.25	0.60	111.05	11.49
11	1.60	85.73	22.42	14.89	1.17	64273.54	22.44	12.60	0.58	110.38	11.47
12	1.80	86.90	22.67	14.91	1.14	64490.62	22.27	13.06	0.57	111.23	11.56
13	2.71	88.69	19.17	14.91	1.24	64498.56	22.18	13.79	0.62	111.99	11.58
14	4.01	82.33	24.29	14.72	1.39	66245.74	23.09	11.54	0.69	114.13	11.61
15	4.43	81.24	26.46	14.65	1.50	66915.77	23.60	8.42	0.75	114.95	11.62
16	4.52	79.62	26.59	14.66	1.55	66801.45	23.91	8.63	0.78	114.97	11.62
17	6.29	76.81	29.59	14.59	1.71	67544.66	23.99	9.41	0.85	115.55	11.63
18	7.57	72.84	28.87	14.52	1.88	67921.75	24.38	7.51	0.94	116.30	11.60
19	8.84	79.08	24.25	14.60	2.08	67619.29	24.22	11.61	1.04	115.65	11.67
20	8.68	79.57	22.80	14.63	2.07	67428.05	24.24	11.64	1.04	115.41	11.69
21	8.04	73.16	23.85	14.56	2.12	68052.24	24.77	10.97	1.06	115.42	11.66
22	3.84	63.22	23.55	14.63	2.06	67024.70	24.78	8.87	1.03	113.76	11.56
23	5.60	70.08	21.14	14.57	1.87	68027.57	24.85	8.55	0.94	114.25	11.65
24	4.56	72.17	22.68	14.63	1.86	67793.56	24.40	12.11	0.93	113.42	11.68
25	5.62	73.02	23.38	14.69	1.75	67320.19	24.31	11.40	0.87	113.09	11.70
26	4.83	78.49	25.17	14.85	1.76	65461.78	23.89	11.55	0.88	112.09	11.66
27	5.73	73.74	26.73	14.75	1.65	66328.17	23.80	12.50	0.82	112.45	11.63
28	3.39	72.26	24.06	14.76	1.78	66417.24	24.24	11.18	0.89	112.27	11.65
29	1.38	64.56	23.90	14.68	1.63	67310.23	23.99	7.64	0.82	109.98	11.59
30	1.31	64.65	19.27	14.70	1.51	66967.41	24.21	8.14	0.76	110.46	11.60
31	3.07	64.71	26.68	14.64	1.68	67313.58	24.76	8.46	0.84	111.95	11.59
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	4.53	74.97	23.48	14.68	1.63	66621.08	24.07	10.91	0.82	113.78	11.59
最大值	8.84	88.69	29.59	14.91	2.12	68052.24	25.09	15.53	1.06	116.82	11.70
發生日期											
最小值	0.82	63.22	16.22	14.52	0.82	64273.54	22.18	7.51	0.41	109.98	11.47
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國107年1月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	7.80	67.33	16.07	14.13	2.49	72148.28	21.14	10.16	1.24	120.01	11.82
02	8.56	67.04	17.45	14.09	2.49	73783.65	20.03	12.28	1.25	121.65	12.06
03	8.76	66.38	18.08	14.13	2.47	74159.88	20.40	10.03	1.23	122.29	12.21
04	8.44	68.22	19.38	14.20	2.43	73707.22	20.10	4.05	1.21	121.62	12.24
05	7.76	69.64	23.85	14.36	2.47	72524.49	19.76	5.55	1.24	120.74	12.31
06	8.97	72.39	25.70	14.35	2.48	71627.49	21.18	8.32	1.24	120.36	12.13
07	8.00	70.36	17.16	14.20	2.47	73133.57	20.13	6.03	1.23	120.62	12.11
08	7.85	68.37	22.55	14.11	2.50	73746.18	19.80	3.12	1.25	120.61	12.06
09	7.98	75.62	16.86	14.45	2.54	71401.97	21.16	8.27	1.27	117.92	12.19
10	6.70	76.01	14.64	14.42	2.55	71548.13	21.79	7.12	1.27	116.60	12.12
11	6.60	76.29	14.98	14.44	2.58	71866.21	21.75	6.67	1.29	117.04	12.24
12	6.50	74.78	18.85	14.47	2.59	71601.00	21.70	7.39	1.29	117.05	12.23
13	7.77	74.53	19.32	14.47	2.58	70653.70	22.89	10.47	1.29	117.49	12.10
14	7.73	65.88	25.59	14.24	2.60	72878.07	21.18	6.48	1.30	119.17	12.09
15	7.90	61.32	24.35	14.17	2.55	73225.72	20.77	5.52	1.27	119.80	12.06
16	7.73	66.54	22.18	14.37	2.58	72475.30	20.75	5.03	1.29	119.47	12.28
17	8.60	66.73	19.64	14.28	2.61	73056.51	20.50	13.57	1.30	120.56	12.24
18	8.70	65.29	19.87	14.23	2.58	72970.20	20.19	9.67	1.29	121.56	12.16
19	9.16	69.19	20.64	14.23	2.53	72102.58	20.72	6.25	1.27	120.72	12.01
20	9.06	65.55	22.05	14.26	2.57	71682.64	20.44	4.93	1.29	120.52	11.99
21	8.89	63.61	19.65	14.29	2.60	72275.55	20.09	4.10	1.30	120.72	12.13
22	7.77	65.13	21.70	14.15	2.61	74085.47	19.95	2.87	1.31	119.96	12.18
23	8.54	62.55	18.59	14.14	2.62	73807.60	19.98	2.95	1.31	120.34	12.12
24	8.34	67.80	20.92	14.24	2.61	73032.61	21.12	2.68	1.31	119.98	12.15
25	8.82	67.91	20.99	14.25	2.64	72599.40	20.72	4.15	1.32	119.96	12.09
26	8.35	70.39	17.96	14.38	2.63	71229.62	20.92	2.37	1.31	119.27	12.08
27	8.99	67.00	17.99	14.25	2.63	72667.69	20.75	3.83	1.32	119.79	12.10
28	7.91	65.31	24.66	14.33	2.64	72378.12	20.50	2.23	1.32	119.38	12.19
29	7.01	66.53	18.85	14.35	2.67	72633.48	20.09	1.91	1.33	117.97	12.22
30	7.01	63.11	22.55	14.29	2.69	73294.16	19.82	2.22	1.35	117.67	12.21
31	7.64	60.98	27.88	14.24	2.72	73768.47	19.56	1.45	1.36	119.01	12.26
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	8.06	67.99	20.35	14.27	2.57	72647.26	20.64	5.86	1.29	119.67	12.14
最大值	9.16	76.29	27.88	14.47	2.72	74159.88	22.89	13.57	1.36	122.29	12.31
發生日期											
最小值	6.50	60.98	14.64	14.09	2.43	70653.70	19.56	1.45	1.21	116.60	11.82
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管