

連續自動監測紀錄月報表

中華民國110年2月28日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.51	58.42	5.52	10.63	1.77	81759.61	16.12	17.40	1.18	174.53	13.64
02	3.56	57.32	5.37	10.58	1.74	80711.54	16.34	17.77	1.16	171.51	13.34
03	3.62	59.30	6.32	10.62	1.71	81323.62	15.65	17.15	1.14	173.62	13.45
04	3.59	60.69	6.45	10.71	1.70	80995.01	15.51	16.43	1.14	173.01	13.46
05	3.63	62.28	7.64	10.66	1.69	80749.10	15.79	17.06	1.13	174.60	13.46
06	4.19	64.99	9.09	10.82	1.68	80161.38	14.84	17.08	1.12	170.92	13.30
07	4.13	65.47	8.97	11.02	1.68	78677.18	14.64	16.62	1.12	171.88	13.33
08	4.02	63.37	10.38	10.87	1.64	80006.39	15.42	16.99	1.09	171.82	13.47
09	4.01	62.32	10.35	10.85	1.63	81185.32	15.70	17.19	1.09	171.74	13.69
10	3.15	52.46	11.42	10.32	1.67	83234.27	19.03	17.07	1.11	174.45	14.01
11	2.31	38.05	15.17	10.64	1.69	80622.62	22.95	16.65	1.12	178.07	14.85
12	6.17	65.69	7.55	11.81	1.56	75413.76	12.06	16.28	1.04	169.75	13.41
13	4.56	66.00	11.64	11.46	1.58	76279.62	14.87	16.35	1.05	171.67	13.54
14	4.28	62.70	7.48	10.87	1.62	78958.71	15.51	17.93	1.08	170.26	13.28
15	3.77	65.91	4.45	11.07	1.65	79132.60	15.65	15.98	1.10	170.84	13.59
16	3.35	63.46	4.13	10.89	1.63	79232.41	16.80	14.79	1.09	173.80	13.64
17	4.02	64.48	3.83	11.06	1.59	78063.62	15.76	14.45	1.06	173.72	13.50
18	4.66	65.93	7.31	11.43	1.58	76570.86	13.90	14.50	1.05	169.47	13.33
19	4.32	66.68	5.03	10.92	1.60	80913.68	15.39	14.94	1.06	172.36	13.70
20	4.64	66.23	5.75	10.72	1.56	81539.08	15.44	15.54	1.04	171.93	13.52
21	3.90	65.59	4.88	10.78	1.56	80866.75	16.44	13.87	1.04	173.40	13.69
22	3.65	64.78	5.00	10.65	1.55	80827.72	16.63	13.01	1.04	173.54	13.56
23	3.48	64.12	4.74	10.45	1.60	81180.30	17.40	14.80	1.06	174.78	13.52
24	3.93	61.67	4.27	10.32	1.63	80619.72	17.47	16.16	1.08	173.91	13.25
25	3.83	59.93	5.53	10.24	1.65	80038.73	17.55	16.52	1.10	172.88	13.04
26	3.37	61.65	4.87	10.50	1.64	78731.69	18.12	14.54	1.09	172.88	13.24
27	3.30	60.25	5.29	10.35	1.63	81430.51	18.41	15.05	1.08	174.51	13.59
28	3.55	61.32	5.55	10.42	1.62	82036.48	17.96	14.72	1.08	175.88	13.76
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	3.88	61.82	6.93	10.77	1.64	80045.08	16.33	15.96	1.09	172.92	13.54
最大值	6.17	66.68	15.17	11.81	1.77	83234.27	22.95	17.93	1.18	178.07	14.85
發生日期											
最小值	2.31	38.05	3.83	10.24	1.55	75413.76	12.06	13.01	1.04	169.47	13.04
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國110年2月28日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	4.46	60.80	10.11	12.24	1.70	72358.50	15.08	16.57	1.14	181.79	14.35
02	4.87	64.46	9.27	12.59	1.62	70377.54	14.51	17.57	1.08	181.40	14.40
03	5.09	61.18	9.08	12.53	1.54	71539.51	13.83	16.68	1.03	181.51	14.44
04	5.45	63.44	10.11	12.79	1.52	70129.75	13.50	16.31	1.01	183.63	14.60
05	5.54	62.98	11.38	12.72	1.54	69909.75	13.52	16.69	1.02	180.47	14.35
06	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
07	6.05	61.88	10.15	12.26	1.46	70481.27	13.66	17.21	0.98	181.46	13.76
08	5.33	63.45	11.23	12.16	1.51	71585.26	13.94	16.97	1.00	181.62	13.88
09	5.00	63.34	11.80	11.92	1.51	72657.07	14.52	16.65	1.01	177.26	13.67
10	4.84	62.45	10.94	11.93	1.54	71978.57	15.39	16.30	1.02	178.50	13.72
11	4.73	59.90	8.74	11.85	1.62	72865.24	14.95	15.47	1.08	176.64	13.64
12	4.65	60.19	9.34	11.68	1.66	75154.58	14.75	15.85	1.11	180.10	13.90
13	4.59	62.05	11.88	11.77	1.66	74115.01	15.22	16.24	1.11	182.28	13.99
14	4.87	65.18	10.65	11.68	1.60	74577.66	15.51	17.01	1.06	180.85	13.93
15	4.08	64.27	9.52	11.81	1.55	73326.45	15.86	14.85	1.03	180.78	13.94
16	3.91	61.64	8.59	11.75	1.49	73889.28	16.16	14.41	0.99	182.63	14.07
17	4.24	63.41	8.12	11.74	1.52	74732.05	15.62	14.70	1.01	181.03	14.07
18	4.79	64.33	9.55	12.13	1.49	73125.63	13.81	13.57	1.00	179.37	14.01
19	4.34	67.06	7.42	11.86	1.49	75679.66	15.05	13.55	0.99	182.72	14.40
20	4.96	63.98	9.43	11.51	1.54	76729.03	15.35	15.10	1.03	184.19	14.15
21	4.28	65.13	8.15	11.75	1.55	75578.55	15.46	12.77	1.04	185.79	14.37
22	3.89	66.11	6.89	11.68	1.53	76215.67	15.74	11.28	1.02	184.47	14.39
23	3.92	64.55	8.70	11.56	1.49	75943.09	16.29	13.73	0.99	183.72	14.23
24	4.12	59.51	9.75	11.40	1.45	76031.43	16.73	15.60	0.97	183.46	14.07
25	4.50	64.63	9.67	11.49	1.42	75553.18	16.45	16.22	0.95	182.79	14.05
26	3.80	62.86	9.45	11.76	1.40	74095.78	16.71	13.75	0.93	182.87	14.23
27	3.97	61.36	9.86	11.52	1.39	76261.27	16.65	13.93	0.93	182.58	14.24
28	4.19	61.53	8.81	11.49	1.45	77053.42	16.36	12.99	0.97	183.40	14.32
監測日數	27	27	27	27	27	27	27	27	27	27	27
平均值	4.61	63.02	9.58	11.91	1.53	73775.71	15.21	15.26	1.02	181.75	14.12
最大值	6.05	67.06	11.88	12.79	1.70	77053.42	16.73	17.57	1.14	185.79	14.60
發生日期											
最小值	3.80	59.51	6.89	11.40	1.39	69909.75	13.50	11.28	0.93	176.64	13.64
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管