

# 連續自動監測紀錄月報表

中華民國111年5月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	3.20	51.86	7.45	10.03	1.53	81814.36	17.22	12.18	1.02	182.51	13.40
02	3.27	52.12	9.26	9.93	1.55	82087.98	17.35	12.30	1.03	182.19	13.33
03	2.35	52.36	8.87	9.98	1.60	82205.44	17.62	11.54	1.06	182.20	13.45
04	2.97	51.71	8.27	10.00	1.66	82080.57	17.50	11.95	1.11	182.39	13.36
05	2.70	50.51	8.38	9.92	1.67	81276.49	17.96	11.62	1.12	182.84	13.22
06	2.36	49.65	8.33	9.90	1.67	81639.87	18.15	11.70	1.11	183.50	13.31
07	3.10	50.24	9.20	9.96	1.66	81535.30	17.49	12.14	1.10	182.46	13.22
08	2.97	50.51	8.84	9.83	1.63	81822.79	18.21	12.09	1.09	182.56	13.23
09	2.88	48.83	7.70	9.77	1.62	81470.65	18.19	12.30	1.08	182.04	13.09
10	2.37	50.04	9.03	9.89	1.60	81898.83	18.25	10.91	1.06	182.32	13.27
11	2.92	48.25	8.34	9.99	1.55	80959.19	17.56	11.44	1.03	180.30	13.10
12	2.64	46.99	7.72	9.79	1.53	81395.22	18.15	11.41	1.02	179.27	13.02
13	2.56	49.90	8.00	9.88	1.52	81546.99	18.38	11.54	1.01	181.28	13.26
14	2.73	49.36	9.55	9.88	1.49	82364.23	18.07	11.72	0.99	180.74	13.30
15	3.36	53.44	7.94	11.17	1.52	75468.68	16.07	15.19	1.01	180.21	13.49
16	2.96	55.79	10.08	9.85	1.47	82642.78	18.21	10.72	0.98	179.06	13.30
17	2.51	55.56	8.90	9.94	1.49	82419.37	18.08	11.82	0.99	181.11	13.40
18	2.54	50.13	8.03	9.85	1.54	82133.35	18.24	11.27	1.02	180.61	13.25
19	2.62	50.15	7.90	9.73	1.51	82007.70	18.69	11.83	1.01	180.80	13.16
20	2.64	49.95	9.24	9.86	1.57	81195.32	18.52	11.59	1.04	180.50	13.15
21	3.03	48.60	8.38	9.99	1.59	80624.74	17.54	11.85	1.06	179.03	13.02
22	2.78	48.03	7.07	9.87	1.57	82023.81	18.21	12.10	1.04	180.97	13.26
23	2.78	49.28	7.07	9.87	1.57	82023.81	18.21	11.68	1.04	180.97	13.26
24	2.60	50.20	8.77	9.84	1.56	82523.10	18.67	11.88	1.04	182.15	13.42
25	2.81	49.69	8.52	9.86	1.50	82101.15	18.45	11.93	1.00	181.42	13.32
26	2.30	49.76	7.31	9.83	1.42	82373.71	18.39	11.76	0.95	180.90	13.30
27	1.77	50.56	9.71	9.71	1.42	83580.71	19.42	11.76	0.94	182.89	13.58
28	2.24	48.79	7.94	9.66	1.47	82652.82	19.11	11.50	0.98	181.98	13.29
29	2.40	48.02	7.59	9.51	1.51	82117.04	19.60	12.08	1.00	180.96	13.11
30	2.22	46.60	6.36	9.49	1.49	82174.57	19.28	12.00	0.99	180.79	13.02
31	2.24	47.72	8.58	9.86	1.36	80468.08	18.59	11.79	0.90	180.40	13.05
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	2.67	50.15	8.33	9.89	1.54	81697.70	18.17	11.86	1.03	181.33	13.26
最大值	3.36	55.79	10.08	11.17	1.67	83580.71	19.60	15.19	1.12	183.50	13.58
發生日期											
最小值	1.77	46.60	6.36	9.49	1.36	75468.68	16.07	10.72	0.90	179.03	13.02
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國111年5月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	4.10	55.88	8.17	10.98	1.52	83710.80	16.56	12.05	1.12	189.58	15.02
02	3.84	55.50	7.74	10.79	1.59	84379.36	16.96	12.40	1.17	188.40	14.89
03	2.96	57.17	8.83	10.97	1.57	83737.76	16.88	11.70	1.17	191.00	15.12
04	3.71	54.18	9.50	10.88	1.54	82941.72	17.07	12.43	1.03	189.34	14.82
05	3.71	52.82	8.65	10.68	1.49	82820.28	17.72	12.23	0.99	188.69	14.61
06	3.24	53.99	9.39	10.79	1.48	83146.14	17.64	11.95	0.99	190.35	14.87
07	3.99	51.61	10.99	10.82	1.51	82056.55	17.01	12.49	1.01	188.33	14.53
08	3.89	52.03	10.47	10.69	1.52	83135.03	17.73	12.41	1.01	189.07	14.69
09	4.22	51.74	8.45	10.74	1.49	82830.07	17.41	12.58	0.99	189.07	14.65
10	3.63	53.49	9.36	10.91	1.53	82283.69	17.31	11.92	1.02	189.43	14.79
11	4.02	51.48	8.80	10.82	1.59	81961.79	17.18	12.46	1.06	188.49	14.54
12	3.48	52.12	9.35	10.82	1.61	81306.02	17.46	12.06	1.07	187.78	14.47
13	3.67	52.14	8.71	10.79	1.60	82555.58	17.93	11.89	1.07	189.94	14.80
14	3.95	52.34	9.26	10.84	1.62	82505.35	17.32	11.86	1.08	188.53	14.71
15	4.00	53.20	9.20	10.79	1.63	83227.36	17.37	11.72	1.08	188.39	14.75
16	3.79	54.97	8.99	10.86	1.64	83672.45	16.85	12.09	1.10	188.69	14.86
17	3.06	56.91	8.30	10.89	1.70	83806.86	17.32	11.98	1.13	190.67	15.06
18	3.36	54.78	6.54	10.74	1.67	83602.51	17.64	12.10	1.12	190.21	14.87
19	3.56	52.45	8.34	10.67	1.64	82833.59	17.90	11.98	1.09	189.36	14.65
20	3.09	55.37	10.33	10.89	1.60	82501.31	17.74	12.12	1.07	190.99	14.92
21	3.49	53.51	9.22	10.86	1.52	82820.40	17.24	12.10	1.01	189.58	14.81
22	3.50	52.29	8.24	10.76	1.51	83073.86	17.48	12.55	1.01	189.24	14.73
23	3.80	51.56	8.11	10.72	1.52	83051.22	17.67	12.22	1.01	189.87	14.73
24	3.22	53.56	9.44	10.76	1.58	83110.80	18.00	12.24	1.05	190.93	14.89
25	3.38	50.69	7.53	10.67	1.59	83591.20	18.20	12.14	1.06	190.69	14.88
26	3.44	51.58	9.07	10.79	1.53	83002.18	17.71	12.08	1.02	189.67	14.82
27	2.55	56.37	8.41	10.77	1.47	84416.30	18.50	11.97	0.98	192.26	15.27
28	2.83	54.38	8.80	10.69	1.45	83697.05	18.41	12.12	0.97	191.61	14.98
29	3.10	52.27	9.20	10.56	1.47	84066.84	18.81	11.88	0.98	191.53	14.97
30	2.92	50.31	7.39	10.41	1.50	83350.36	18.71	12.13	1.00	189.40	14.52
31	3.51	50.64	9.42	10.64	1.50	81396.32	18.22	11.89	1.00	187.98	14.36
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.52	53.27	8.85	10.77	1.55	83051.31	17.61	12.12	1.05	189.65	14.79
最大值	4.22	57.17	10.99	10.98	1.70	84416.30	18.81	12.58	1.17	192.26	15.27
發生日期											
最小值	2.55	50.31	6.54	10.41	1.45	81306.02	16.56	11.70	0.97	187.78	14.36
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管