

# 連續自動監測紀錄月報表

中華民國111年8月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	1.87	45.52	7.99	9.30	1.13	81383.11	18.58	11.80	0.75	178.81	12.51
02	1.82	46.49	9.38	9.61	1.06	81297.90	18.50	11.68	0.70	180.54	12.89
03	1.81	48.09	7.30	9.50	1.11	82419.51	18.58	11.25	0.74	181.31	12.97
04	1.82	48.97	24.56	9.75	1.07	79108.65	17.80	11.05	0.71	178.18	12.47
05	1.78	50.06	7.13	9.67	1.08	80484.02	17.92	11.00	0.72	179.05	12.69
06	2.00	49.08	8.22	9.75	1.12	80153.41	17.61	11.61	0.74	178.27	12.66
07	1.77	49.14	7.43	9.69	1.09	81693.69	17.87	11.55	0.73	179.82	12.91
08	2.95	47.75	7.86	9.43	1.07	80819.50	18.16	11.77	0.71	177.73	12.48
09	3.23	51.16	7.29	9.91	1.08	79239.49	17.92	10.63	0.72	180.06	12.79
10	3.78	49.54	9.27	9.83	1.08	79563.18	17.96	11.14	0.72	179.74	12.76
11	3.09	50.41	8.09	9.61	1.04	80264.38	18.33	11.49	0.69	178.95	12.65
12	3.16	51.68	8.06	9.82	1.07	79969.63	18.14	10.05	0.71	180.29	12.85
13	3.37	50.73	7.43	9.75	1.08	79111.74	17.89	11.16	0.72	178.29	12.54
14	3.32	50.67	7.45	9.64	1.12	79460.19	18.20	11.04	0.74	178.30	12.52
15	3.10	50.87	5.73	9.56	1.07	79542.58	18.54	11.61	0.71	178.04	12.49
16	2.74	52.83	7.60	9.66	1.09	79948.42	18.75	10.42	0.73	179.95	12.76
17	3.56	48.91	7.91	9.77	1.10	79566.24	18.04	11.10	0.73	179.33	12.68
18	3.50	47.27	6.92	9.60	1.09	79668.55	18.56	10.66	0.73	178.33	12.57
19	3.82	53.23	8.82	9.90	1.10	78509.11	18.56	11.32	0.73	180.01	12.76
20	3.65	55.67	7.91	9.90	1.13	78600.29	18.57	11.64	0.75	180.59	12.79
21	3.97	53.34	9.85	9.76	1.12	78917.06	18.67	11.27	0.75	179.78	12.68
22	4.22	47.94	7.96	9.61	1.11	78360.24	18.38	11.01	0.74	178.08	12.34
23	3.99	53.07	7.55	9.89	1.17	77302.18	18.64	10.29	0.78	179.32	12.56
24	4.62	51.16	8.19	9.60	1.22	78271.54	18.78	11.13	0.82	178.13	12.38
25	3.87	52.26	7.10	9.80	1.11	77820.40	18.33	11.21	0.74	177.86	12.43
26	3.94	54.53	7.75	9.93	1.13	78341.71	18.66	11.01	0.75	179.18	12.76
27	3.99	51.30	8.20	9.76	1.05	78586.09	18.52	11.36	0.70	178.75	12.58
28	4.19	51.37	7.84	9.80	1.03	78753.50	18.50	11.31	0.68	179.14	12.66
29	4.82	51.70	6.35	9.65	1.03	78162.06	18.21	11.90	0.69	177.39	12.30
30	4.42	57.60	6.25	9.94	1.04	78097.54	18.06	11.16	0.69	179.42	12.64
31	4.19	57.12	8.63	9.88	1.07	78896.45	18.08	11.56	0.71	179.68	12.73
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.30	50.95	8.32	9.72	1.09	79429.43	18.30	11.20	0.73	179.11	12.64
最大值	4.82	57.60	24.56	9.94	1.22	82419.51	18.78	11.90	0.82	181.31	12.97
發生日期											
最小值	1.77	45.52	5.73	9.30	1.03	77302.18	17.61	10.05	0.68	177.39	12.30
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國111年8月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化 硫	氮氧化 物	一氧化 碳	氧氣	粉塵濃 度	排放流率	水份	鹽酸	不透光 率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	℃	m/s
01	2.90	46.74	8.43	10.18	1.36	83045.04	18.47	11.94	0.91	191.35	14.18
02	2.64	46.17	9.00	10.42	1.38	82556.12	18.37	12.05	0.92	192.43	14.43
03	2.75	48.51	8.44	10.41	1.42	83257.54	18.29	11.93	0.94	193.52	14.56
04	3.40	46.22	17.80	10.66	1.33	79649.35	17.37	11.28	0.89	189.55	13.92
05	2.82	50.72	8.12	10.58	1.33	82138.90	17.62	11.94	0.89	191.59	14.42
06	2.96	49.90	9.45	10.52	1.35	82206.64	17.49	12.41	0.90	191.23	14.32
07	2.87	49.39	8.23	10.45	1.32	82926.49	17.79	11.82	0.88	192.65	14.44
08	3.67	49.40	7.15	10.31	1.27	82212.08	17.93	11.94	0.85	190.77	14.11
09	3.68	50.01	7.61	10.75	1.19	80167.06	17.66	11.64	0.79	192.14	14.34
10	3.91	47.83	8.45	10.70	1.18	79780.54	17.66	11.65	0.78	191.09	14.17
11	3.55	47.25	9.32	10.64	0.17	79760.42	17.61	11.59	0.78	190.28	14.04
12	3.49	48.61	9.76	10.72	0.80	79855.30	18.29	10.49	0.80	193.29	14.39
13	3.70	47.60	9.35	10.67	0.80	78435.61	17.56	11.38	0.80	189.33	13.81
14	3.67	46.58	8.01	10.54	1.20	79219.23	17.89	11.33	0.80	189.75	13.85
15	3.40	47.93	8.33	10.40	1.25	79741.85	18.26	11.56	0.83	190.16	13.93
16	3.21	51.37	7.08	10.76	1.36	79663.09	18.15	11.39	0.91	192.95	14.36
17	3.88	50.40	10.01	10.74	1.39	79560.91	17.74	11.16	0.93	191.82	14.22
18	3.47	50.84	7.07	10.62	1.40	80019.28	18.08	11.42	0.93	191.50	14.18
19	3.31	52.08	8.75	10.58	1.33	80700.39	18.57	11.56	0.89	193.99	14.40
20	3.56	50.81	9.30	10.61	1.29	80033.97	18.39	11.74	0.87	192.45	14.25
21	3.75	50.94	8.23	10.57	1.33	79935.06	18.18	11.95	0.89	192.90	14.16
22	3.30	50.46	8.47	10.48	1.33	79990.61	17.80	10.48	0.89	191.27	13.93
23	3.31	53.18	7.50	10.83	1.34	78957.26	18.15	11.15	0.89	193.94	14.37
24	3.75	53.11	6.99	10.67	1.34	80452.92	18.24	11.32	0.89	194.35	14.45
25	4.21	49.75	8.43	10.53	1.30	79356.56	18.02	10.77	0.87	190.81	13.91
26	3.17	51.44	6.47	10.58	1.31	80311.90	18.54	11.27	0.88	193.50	14.32
27	3.67	51.00	7.59	10.66	1.27	79412.06	17.91	12.25	0.85	192.07	14.12
28	3.83	50.75	7.32	10.58	1.25	80515.53	18.07	11.65	0.84	192.92	14.25
29	4.14	47.25	7.19	10.34	1.23	80235.32	18.04	11.70	0.82	190.45	13.79
30	3.70	47.05	7.24	10.59	1.27	79508.37	17.93	11.47	0.85	192.47	14.05
31	4.11	48.03	7.72	10.60	1.29	80918.92	18.04	11.60	0.87	193.57	14.37
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	3.48	49.40	8.48	10.57	1.24	80468.53	18.00	11.54	0.87	191.94	14.19
最大值	4.21	53.18	17.80	10.83	1.42	83257.54	18.57	12.41	0.94	194.35	14.56
發生日期											
最小值	2.64	46.17	6.47	10.18	0.17	78435.61	17.37	10.48	0.78	189.33	13.79
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管