

連續自動監測紀錄月報表

中華民國114年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	0.91	47.11	8.97	10.00	1.18	81346.78	20.43	7.67	0.91	189.30	13.92
02	0.77	45.91	9.48	10.07	1.20	81519.98	20.48	7.58	0.93	189.27	14.05
03	0.86	40.84	12.11	9.86	1.20	82504.81	20.41	7.63	0.92	189.65	13.96
04	1.00	43.02	10.09	9.97	1.19	81405.80	19.54	7.02	0.92	186.10	13.65
05	0.77	40.01	9.63	10.13	1.21	81348.91	20.28	5.73	0.94	188.39	14.04
06	0.64	38.92	10.36	9.96	1.21	81303.59	20.99	6.04	0.94	189.25	13.96
07	1.01	43.29	9.54	9.99	1.20	81392.54	20.49	5.62	0.93	189.14	13.92
08	0.88	42.99	8.82	10.01	1.21	81659.13	20.33	5.59	0.94	188.72	13.97
09	1.14	45.02	9.35	10.03	1.18	81274.36	20.39	6.33	0.91	188.84	13.92
10	1.36	47.38	9.39	10.03	1.17	81286.45	20.49	5.25	0.90	189.36	13.97
11	1.39	48.02	8.41	10.02	1.18	80794.29	20.14	4.15	0.91	187.92	13.77
12	1.70	42.92	10.74	9.90	1.21	81071.58	20.70	7.00	0.94	188.41	13.79
13	1.45	44.08	9.19	9.97	1.25	80912.77	20.60	6.62	0.96	187.69	13.81
14	1.59	45.90	7.29	10.11	1.21	81887.60	20.01	6.13	0.94	187.56	14.03
15	1.53	45.70	7.91	10.12	1.23	81293.63	19.62	5.83	0.95	187.24	13.88
16	1.53	46.21	8.52	10.29	1.24	81041.91	19.62	7.15	0.96	188.90	14.10
17	1.32	48.22	8.42	10.16	1.23	81562.22	20.40	6.71	0.95	190.37	14.20
18	1.34	46.79	10.00	9.90	1.23	81917.60	21.08	6.31	0.95	189.24	14.01
19	1.15	45.39	11.08	10.05	1.22	80793.73	21.05	6.64	0.94	190.59	14.04
20	1.27	47.52	8.82	10.10	1.24	80960.01	20.52	7.61	0.96	192.29	14.09
21	1.10	48.45	8.07	9.98	1.24	81487.23	20.69	7.31	0.96	191.50	14.04
22	0.92	48.34	7.90	9.96	1.25	81853.65	20.71	6.93	0.97	191.73	14.09
23	0.92	47.39	8.82	9.93	1.22	81025.19	20.55	6.84	0.94	191.01	13.86
24	0.95	48.24	8.35	9.99	1.20	81755.67	20.85	6.92	0.93	192.43	14.15
25	1.12	47.54	8.00	10.05	1.21	82033.11	20.37	7.76	0.93	191.78	14.17
26	0.88	47.02	7.60	10.08	1.23	82417.12	20.22	7.34	0.95	191.62	14.25
27	0.61	40.36	9.03	9.97	1.23	80839.20	20.61	7.23	0.95	190.27	13.87
28	0.54	43.09	8.51	9.91	1.22	82100.42	21.02	6.72	0.94	192.40	14.14
29	0.68	43.97	8.77	9.83	1.24	80853.10	21.13	6.75	0.96	190.79	13.80
30	0.63	43.29	9.83	9.89	1.24	81214.08	21.23	6.89	0.96	191.63	13.99
31	0.90	43.33	9.78	9.96	1.25	81950.78	21.14	6.95	0.97	192.27	14.18
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.06	45.04	9.12	10.01	1.22	81445.39	20.52	6.65	0.94	189.86	13.99
最大值	1.70	48.45	12.11	10.29	1.25	82504.81	21.23	7.76	0.97	192.43	14.25
發生日期											
最小值	0.54	38.92	7.29	9.83	1.17	80793.73	19.54	4.15	0.90	186.10	13.65
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國114年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂ 二氧化 硫	NO _x 氮氧化 物	CO 一氧化 碳	O ₂ 氧氣	DUST 粉塵濃 度	MASS 排放流率	H2O 水份	HCL 鹽酸	OPAC 不透光 率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	℃	m/s
01	0.67	44.96	13.23	10.41	1.18	83275.61	22.87	7.84	0.91	198.29	14.98
02	0.20	43.70	12.22	10.81	1.22	77950.56	25.40	7.82	0.94	197.55	15.05
03	3.86	22.12	17.38	14.25	1.17	85260.94	17.14	3.62	0.91	155.69	16.59
04	1.68	40.73	33.30	10.67	1.11	84064.30	19.60	5.27	0.85	190.46	14.52
05	1.21	44.85	12.49	10.58	1.06	82121.87	19.79	6.52	0.81	198.13	14.43
06	1.06	44.64	13.19	10.44	1.03	82173.80	20.66	6.60	0.79	195.02	14.31
07	1.23	46.41	13.21	10.32	1.01	81429.67	20.55	5.60	0.78	194.01	13.98
08	1.33	45.59	12.28	10.22	0.98	81168.68	20.68	6.00	0.76	192.22	13.77
09	1.16	49.24	13.77	10.28	1.01	81000.66	20.56	7.12	0.78	191.40	13.80
10	1.22	49.62	13.27	10.35	1.10	81708.11	20.50	6.76	0.85	194.57	14.06
11	1.42	47.22	13.42	10.36	1.09	81654.76	20.15	6.49	0.84	194.26	14.00
12	1.38	44.29	12.74	10.37	1.04	81528.72	20.55	6.84	0.80	195.20	14.10
13	1.20	43.35	12.64	10.28	1.06	81098.70	20.72	6.67	0.81	193.36	13.86
14	1.60	42.24	12.92	10.28	1.03	82640.98	20.29	6.34	0.79	193.36	14.05
15	1.49	46.56	12.04	10.25	1.01	81873.65	19.91	6.47	0.77	191.98	13.79
16	1.82	47.97	13.01	10.56	1.04	80968.13	19.41	7.11	0.79	193.26	13.99
17	1.18	49.29	12.20	10.42	1.06	81603.12	20.40	7.33	0.81	195.15	14.15
18	1.24	48.77	12.63	10.42	1.06	81329.08	20.37	6.60	0.81	195.10	14.10
19	1.67	44.31	15.89	10.41	1.09	79819.33	20.47	7.37	0.84	194.42	13.85
20	1.36	47.34	12.99	10.30	1.09	80243.74	20.42	7.65	0.84	193.75	13.71
21	1.35	47.66	12.10	10.27	1.05	81549.69	20.59	7.28	0.81	195.46	13.98
22	1.31	47.91	11.84	10.31	1.05	81647.69	20.36	6.44	0.81	195.51	14.00
23	1.30	49.06	12.31	10.37	1.07	81028.07	20.18	6.71	0.82	195.83	13.95
24	1.35	49.26	13.62	10.38	1.00	82686.21	20.73	6.51	0.77	196.27	14.37
25	1.39	48.29	13.18	10.47	0.97	84496.25	20.28	6.87	0.75	196.89	14.75
26	1.29	46.79	12.95	10.55	1.02	85110.74	19.91	6.72	0.78	198.23	14.96
27	0.99	41.86	13.22	10.48	1.05	83501.86	20.22	6.61	0.81	195.75	14.53
28	1.13	43.81	13.07	10.43	1.11	84146.43	20.49	6.33	0.85	197.27	14.70
29	1.30	47.82	11.17	10.34	1.08	87439.56	20.73	5.90	0.83	195.77	14.45
30	1.06	46.34	12.03	10.45	1.05	83755.00	20.76	6.75	0.81	196.77	14.67
31	1.42	46.98	12.79	10.47	1.10	84860.56	20.86	7.00	0.85	194.83	14.87
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	1.35	45.45	13.65	10.53	1.06	82359.24	20.50	6.62	0.82	193.73	14.33
最大值	3.86	49.62	33.30	14.25	1.22	87439.56	25.40	7.84	0.94	198.29	16.59
發生日期											
最小值	0.20	22.12	11.17	10.22	0.97	77950.56	17.14	3.62	0.75	155.69	13.71
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管