

連續自動監測紀錄月報表

中華民國113年4月30日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	3.44	30.05	10.97	10.83	1.29	75983.98	16.83	8.27	0.99	178.74	13.15
02	3.31	29.00	12.63	11.00	1.31	75476.83	17.22	9.33	1.01	179.45	13.37
03	3.15	27.03	11.94	11.02	1.32	76701.86	17.15	8.73	1.02	176.40	13.52
04	2.65	24.73	9.75	10.77	1.29	75745.04	17.56	8.78	1.00	177.14	13.10
05	2.99	30.34	9.64	10.90	1.29	76496.15	16.91	8.78	1.00	176.12	13.26
06	2.93	29.59	11.17	11.01	1.35	76473.04	16.94	8.47	1.05	176.79	13.43
07	2.62	30.91	10.95	10.98	1.35	77255.68	17.58	8.33	1.04	179.10	13.70
08	2.67	29.54	10.17	10.90	1.33	76552.86	17.61	8.20	1.02	178.90	13.47
09	2.44	32.48	11.58	10.94	1.23	78755.61	17.12	8.42	0.95	182.51	13.94
10	2.36	30.26	12.16	11.13	1.29	77724.26	17.18	8.15	1.00	182.06	14.03
11	2.31	28.97	12.48	10.91	1.30	77011.97	17.42	8.19	1.01	180.41	13.58
12	2.18	34.64	11.63	11.07	1.27	77134.02	17.53	8.13	0.98	182.21	13.90
13	2.19	27.67	11.38	10.89	1.26	75052.36	17.70	8.16	0.97	178.63	13.20
14	2.71	29.01	11.22	11.00	1.27	75758.70	17.50	8.14	0.98	180.35	13.50
15	2.63	30.19	11.77	11.00	1.27	75567.34	17.55	7.64	0.98	180.62	13.48
16	2.08	26.78	11.74	11.03	1.25	75181.50	18.11	7.88	0.96	181.00	13.55
17	2.60	28.53	12.04	11.07	1.25	75783.65	17.23	9.04	0.96	181.15	13.57
18	2.60	32.64	10.86	11.10	1.25	76107.99	17.08	8.43	0.97	181.38	13.66
19	2.61	32.64	10.04	11.17	1.26	75913.69	17.10	8.62	0.98	181.66	13.72
20	2.56	31.48	11.00	11.17	1.29	75185.16	17.09	8.57	1.00	180.48	13.56
21	2.21	30.37	11.09	11.10	1.27	75607.48	17.40	8.19	0.98	181.47	13.62
22	2.41	33.08	10.81	11.08	1.24	76192.02	17.32	8.41	0.96	182.20	13.71
23	2.47	30.71	11.69	11.09	1.23	76144.36	17.29	8.30	0.95	182.46	13.71
24	2.68	28.79	11.09	11.09	1.20	76694.69	17.11	8.22	0.92	181.11	13.74
25	2.35	29.97	10.07	11.07	1.19	75813.63	17.22	8.34	0.91	181.29	13.58
26	2.34	31.35	10.52	11.12	1.18	74826.96	17.29	8.40	0.91	180.87	13.47
27	2.26	33.90	10.68	11.08	1.19	75045.50	17.41	8.50	0.92	181.27	13.49
28	2.26	32.23	11.32	10.94	1.19	75935.60	17.78	8.37	0.91	181.92	13.53
29	2.17	30.88	11.66	10.94	1.20	75220.36	17.57	8.44	0.93	181.37	13.36
30	2.33	31.34	11.94	11.01	1.19	75510.15	17.45	8.72	0.92	181.86	13.50
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	2.55	30.30	11.20	11.01	1.26	76095.08	17.34	8.41	0.97	180.36	13.55
最大值	3.44	34.64	12.63	11.17	1.35	78755.61	18.11	9.33	1.05	182.51	14.03
發生日期											
最小值	2.08	24.73	9.64	10.77	1.18	74826.96	16.83	7.64	0.91	176.12	13.10
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國113年4月30日

			管制編號		F0501686		煙道排放口編		P002		
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m3	Nm3/hr	%	ppm	%	°C	m/s
01	3.58	34.76	10.97	11.31	0.90	72990.11	17.30	9.80	0.69	186.45	13.56
02	2.93	33.58	11.93	11.39	0.94	72970.57	17.85	9.28	0.73	189.88	13.87
03	3.37	31.22	13.04	11.56	0.98	72954.77	17.10	10.62	0.75	190.23	13.99
04	3.47	28.16	9.88	11.80	0.96	72347.41	16.67	10.33	0.74	189.89	14.15
05	3.88	26.47	8.93	11.96	0.92	72004.70	16.13	8.82	0.71	188.29	14.20
06	4.05	26.05	11.48	11.98	0.92	71609.16	16.08	8.81	0.71	187.89	14.13
07	3.84	26.53	11.79	11.99	0.94	71740.18	16.25	8.07	0.73	189.98	14.26
08	3.31	23.74	11.87	11.69	1.04	74578.78	17.01	8.50	0.80	191.06	14.51
09	3.03	24.12	12.66	11.32	1.11	78130.60	17.11	9.78	0.85	191.69	14.67
10	2.21	27.91	13.29	11.32	1.10	79083.71	17.16	7.91	0.85	193.82	14.92
11	2.44	24.15	12.90	11.23	1.10	78369.72	17.36	8.60	0.85	193.60	14.68
12	2.54	23.69	12.21	11.33	1.08	76909.34	17.58	7.81	0.83	193.01	14.58
13	2.86	24.23	11.64	11.44	1.06	76670.34	17.15	8.10	0.81	192.93	14.63
14	3.10	24.33	12.34	11.43	1.03	77425.06	17.07	7.78	0.79	194.10	14.78
15	3.15	23.24	13.04	11.54	1.00	78287.39	17.05	7.72	0.77	190.21	14.98
16	2.28	25.63	12.41	11.45	1.03	76989.15	17.36	7.74	0.79	196.28	14.84
17	3.17	24.12	12.03	11.51	1.06	76942.83	16.87	9.81	0.82	194.80	14.80
18	2.88	25.86	12.80	11.56	1.07	76519.55	16.71	8.36	0.83	193.65	14.72
19	3.14	29.81	11.45	11.59	1.07	76809.81	16.69	9.30	0.82	195.51	14.89
20	2.86	28.43	12.91	11.63	1.06	76124.31	16.73	8.71	0.81	195.54	14.82
21	2.43	27.34	11.52	11.57	1.09	76424.96	17.02	7.47	0.84	195.59	14.84
22	2.86	30.67	11.95	11.57	1.13	76437.49	16.74	8.16	0.87	195.32	14.77
23	3.41	30.15	12.75	11.67	1.11	75833.74	16.40	8.44	0.86	194.88	14.74
24	3.21	28.03	11.93	11.59	1.09	76792.24	16.67	7.68	0.84	194.83	14.85
25	2.88	33.87	11.11	11.67	1.13	76192.12	16.55	7.99	0.87	196.11	14.89
26	2.72	38.10	10.98	11.76	1.13	75890.98	16.54	8.40	0.87	196.76	14.98
27	2.60	38.70	10.64	11.70	1.09	76602.66	16.58	8.12	0.84	198.06	15.07
28	3.24	37.35	10.88	11.73	1.01	76224.71	16.53	8.21	0.78	198.48	15.05
29	2.92	36.86	11.20	11.77	1.00	75563.82	16.32	8.30	0.77	197.80	14.92
30	3.20	37.23	11.48	11.89	0.98	75376.51	16.10	7.80	0.76	198.20	15.07
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	3.05	29.14	11.80	11.60	1.04	75693.22	16.82	8.55	0.80	193.49	14.64
最大值	4.05	38.70	13.29	11.99	1.13	79083.71	17.85	10.62	0.87	198.48	15.07
發生日期											
最小值	2.21	23.24	8.93	11.23	0.90	71609.16	16.08	7.47	0.69	186.45	13.56
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管