

連續自動監測紀錄月報表

中華民國108年2月28日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	10.13	77.79	11.15	10.38	1.92	77924.43	15.97	14.81	0.80	144.40	11.81
02	9.69	78.25	9.00	10.46	1.89	77286.44	16.44	15.73	0.79	145.96	11.92
03	9.35	79.67	10.78	10.61	1.91	75335.90	16.41	12.72	0.79	145.10	11.75
04	8.45	76.53	9.56	10.43	1.90	75675.89	16.06	11.48	0.79	143.80	11.52
05	9.40	74.38	11.82	10.36	1.83	76655.17	15.87	12.62	0.76	144.18	11.58
06	8.69	73.21	9.87	10.36	1.84	75368.14	15.95	11.96	0.77	144.22	11.40
07	8.27	70.14	13.25	10.26	1.84	75812.34	16.77	11.49	0.77	144.64	11.48
08	7.45	69.43	10.90	10.20	1.87	77184.42	17.92	7.65	0.78	144.12	11.77
09	7.00	67.54	3.78	10.08	1.86	78665.67	18.72	4.79	0.77	145.13	12.01
10	7.17	71.30	2.48	10.15	1.83	78559.94	18.75	4.03	0.76	145.80	12.10
11	7.53	73.14	3.32	10.11	1.82	79056.92	18.29	5.57	0.76	145.48	12.05
12	7.52	72.08	7.23	9.97	1.92	79379.94	19.22	4.92	0.80	147.59	12.15
13	9.53	72.80	8.96	9.94	1.87	78951.24	18.49	8.37	0.78	146.60	11.91
14	8.37	73.50	11.22	10.01	1.87	78287.96	18.43	7.70	0.78	146.54	11.87
15	8.73	75.93	7.57	10.09	1.83	78152.98	19.18	8.25	0.79	147.69	12.09
16	8.70	70.00	10.26	9.97	1.77	79643.90	19.24	9.21	0.74	147.05	12.17
17	8.27	69.37	6.71	10.01	1.75	80372.89	19.28	8.25	0.73	147.04	12.33
18	8.36	73.04	5.94	10.16	1.83	78278.02	19.30	8.37	0.76	148.02	12.21
19	8.17	74.64	7.84	10.28	1.82	78280.53	19.62	7.52	0.76	148.93	12.42
20	8.77	72.36	8.16	10.09	1.77	78959.33	19.44	8.82	0.74	149.28	12.30
21	8.06	72.21	7.94	10.03	1.77	79090.27	19.54	6.01	0.74	148.71	12.25
22	8.89	81.15	5.30	10.38	1.75	77869.68	18.67	7.98	0.73	148.09	12.31
23	8.69	81.21	6.05	10.35	1.76	79137.16	18.01	9.24	0.73	147.13	12.34
24	8.64	72.80	7.53	10.11	1.71	81185.23	19.11	8.40	0.71	147.98	12.57
25	7.92	77.55	5.10	10.18	1.79	80165.85	18.60	7.64	0.74	148.47	12.44
26	8.26	79.17	5.04	10.18	1.85	79611.54	19.20	7.89	0.77	148.61	12.44
27	8.61	78.63	5.02	10.03	1.82	79483.80	19.41	8.12	0.76	148.63	12.29
28	8.65	81.32	5.74	10.38	1.72	78462.17	18.45	8.30	0.72	148.45	12.38
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	8.47	74.61	7.77	10.20	1.83	78315.63	18.23	8.85	0.76	146.70	12.07
最大值	10.13	81.32	13.25	10.61	1.92	81185.23	19.62	15.73	0.80	149.28	12.57
發生日期											
最小值	7.00	67.54	2.48	9.94	1.71	75335.90	15.87	4.03	0.71	143.80	11.40
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年2月28日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	℃	m/s
01	17.45	80.81	24.81	15.24	3.24	64946.01	9.32	23.67	1.35	107.87	15.36
02	17.62	85.71	21.62	15.35	3.31	62320.99	9.86	21.87	1.38	109.96	15.20
03	17.48	82.00	23.69	15.31	3.27	62735.96	9.95	15.29	1.36	109.88	15.20
04	16.23	79.70	27.52	15.38	3.26	63404.81	9.47	13.12	1.36	108.81	15.42
05	16.90	77.38	24.71	15.29	3.25	63518.75	9.54	13.32	1.35	108.80	15.22
06	16.34	79.74	16.12	15.37	3.49	62488.38	9.55	12.99	1.45	109.51	15.22
07	16.41	77.25	25.55	15.21	3.38	63574.68	9.97	13.35	1.41	109.91	15.13
08	15.66	74.22	24.41	15.23	3.38	63609.88	10.33	8.83	1.41	107.86	15.16
09	15.03	70.07	22.59	15.03	3.54	65451.46	11.19	5.73	1.47	107.76	15.22
10	15.13	68.81	24.99	15.04	3.51	64688.55	11.53	3.75	1.46	107.61	15.13
11	15.03	68.48	25.13	15.07	3.39	64843.89	11.27	4.03	1.41	107.25	15.18
12	16.26	71.03	24.83	15.14	3.56	63158.24	11.60	3.64	1.48	109.28	15.10
13	17.33	69.34	30.26	15.10	3.46	63900.28	11.18	4.82	1.44	108.53	15.09
14	17.03	67.26	29.84	15.02	3.34	64594.70	11.18	5.01	1.39	108.51	15.04
15	16.84	69.87	23.17	15.02	3.49	64176.61	11.70	6.38	1.46	109.61	15.09
16	16.70	70.68	23.77	15.11	3.42	64344.40	11.25	5.90	1.43	108.39	15.23
17	15.98	66.28	29.53	15.08	3.30	64864.66	11.24	4.05	1.37	107.58	15.23
18	16.39	62.57	29.32	14.99	3.28	64126.77	12.30	4.09	1.37	109.27	15.08
19	18.36	61.77	33.91	14.91	3.40	61474.37	12.72	4.07	1.42	109.28	14.34
20	20.20	60.41	25.69	14.78	3.36	61188.99	12.02	5.55	1.40	110.72	13.92
21	15.68	67.77	24.27	15.04	3.38	59888.36	11.78	4.45	1.41	110.57	14.19
22	16.57	72.03	27.35	15.15	3.43	59959.80	11.49	1.51	1.43	108.09	14.28
23	16.52	68.95	25.51	15.05	3.32	61754.80	11.06	1.46	1.38	105.94	14.35
24	17.13	65.92	23.11	15.10	3.23	62624.85	11.38	1.47	1.35	106.78	14.75
25	16.20	68.86	21.03	15.26	3.19	62553.31	11.00	1.10	1.33	106.71	15.07
26	17.09	69.01	27.02	15.09	3.41	64034.25	11.74	1.16	1.42	107.65	15.15
27	17.73	67.46	19.00	15.08	3.44	63526.73	11.84	1.30	1.43	107.86	15.01
28	17.13	68.65	22.03	15.11	3.54	63705.58	11.48	1.48	1.47	107.60	15.09
監測日數	28	28	28	28	28	28	28	28	28	28	28
平均值	16.73	71.14	25.03	15.13	3.38	63266.43	11.03	6.91	1.41	108.49	14.98
最大值	20.20	85.71	33.91	15.38	3.56	65451.46	12.72	23.67	1.48	110.72	15.42
發生日期											
最小值	15.03	60.41	16.12	14.78	3.19	59888.36	9.32	1.10	1.33	105.94	13.92
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管