

連續自動監測紀錄日報彙總表

1060909		煙道排放口編號 P001					煙道排放口編號 P002				
時間	監測項目	SO ₂	NO _x	CO	HCL	OPAC	SO ₂	NO _x	CO	HCL	OPAC
		二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率	二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率
		ppm	ppm	ppm	ppm	%	ppm	ppm	ppm	ppm	%
00:00		3.29	99.15	19.14	6.51	1.07	8.03	94.97	13.06	4.00	1.06
01:00		2.47	88.55	16.00	4.66	1.06	7.76	108.73	10.53	4.61	1.06
02:00		2.23	79.27	16.17	3.07	1.05	7.91	106.53	12.18	4.83	1.07
03:00		2.71	71.28	40.91	3.61	1.06	7.58	65.32	50.37	3.98	1.07
04:00		5.16	50.90	17.02	6.51	1.06	7.38	57.07	34.38	3.89	1.07
05:00		3.47	39.60	59.91	4.69	1.06	7.06	55.10	50.21	4.55	1.07
06:00		3.20	45.96	13.55	3.97	1.07	7.08	52.89	27.14	4.48	1.08
07:00		4.84	44.72	24.85	5.32	1.06	7.29	54.27	32.82	4.82	1.08
08:00		4.23	47.74	8.69	4.76	1.08	7.38	58.90	9.10	8.45	1.08
09:00		5.31	49.31	34.42	4.99	1.09	7.50	53.67	22.90	7.28	1.08
10:00		7.91	53.94	43.09	7.90	1.07	保養	保養	保養	10.50	1.08
11:00		10.82	62.08	35.36	12.97	1.11	11.21	68.34	24.95	12.23	1.08
12:00		5.64	66.14	14.40	11.08	1.10	8.35	60.84	18.03	9.78	1.08
13:00		5.26	71.16	28.29	6.73	1.10	8.36	64.25	9.36	8.06	1.08
14:00		6.22	64.53	55.55	8.09	1.11	8.57	61.95	15.37	6.95	1.07
15:00		5.89	63.75	35.77	8.72	1.10	9.80	52.49	20.22	8.02	1.08
16:00		4.10	68.33	13.13	5.68	1.10	10.09	58.69	11.21	9.54	1.08
17:00		3.66	58.97	21.23	5.66	1.09	7.93	65.82	8.90	6.49	1.07
18:00		3.11	60.65	23.35	3.65	1.08	8.02	60.71	30.81	4.85	1.08
19:00		4.69	67.03	41.30	3.97	1.10	8.24	58.55	14.05	5.08	1.08
20:00		5.52	67.48	25.57	7.93	1.09	7.83	65.47	8.73	4.58	1.07
21:00		3.56	79.27	9.91	3.38	1.08	7.64	55.66	16.06	3.79	1.07
22:00		2.98	61.10	31.78	1.46	1.07	7.70	61.97	8.53	4.00	1.07
23:00		2.78	64.00	27.14	1.06	1.07	7.50	45.18	13.43	3.18	1.07