

連續自動監測紀錄日報彙總表

1071003		煙道排放口編號 P001					煙道排放口編號 P002						
時間	監測項目	SO ₂	NO _x	CO	HCL	OPAC	MASS	SO ₂	NO _x	CO	HCL	OPAC	MASS
		二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
		ppm	ppm	ppm	ppm	%	Nm3/hr	ppm	ppm	ppm	ppm	%	Nm3/hr
00:00		7.71	96.58	0.55	6.37	1.57	77924.9	12.13	83.65	1.89	2.12	1.51	74919.4
01:00		7.22	83.02	5.88	4.98	1.56	79266.1	12.68	77.79	2.87	2.05	1.51	77158
02:00		8.73	85.66	1.55	7.46	1.56	82262	12.29	79.98	1.83	2.14	1.51	76994
03:00		7.57	91.91	0.55	6.17	1.57	80217.4	12.59	86.26	2	2.29	1.5	75338.8
04:00		8.71	83.02	1.21	8.83	1.57	83821.3	11.93	86.35	1.72	1.77	1.5	74861.2
05:00		8.02	90.54	0.71	7.34	1.57	80129	11.66	81.31	2.22	1.49	1.52	75568.3
06:00		9.35	90.02	0.76	6.57	1.58	79529.5	11.59	79.02	4.79	1.22	1.5	76540.2
07:00		10.12	81.29	2.48	8.42	1.57	79523.3	11.08	78.91	4.17	1.28	1.52	75869.4
08:00		9.61	94.25	1.36	9.14	1.6	76017.8	11.22	76.5	33.28	1.11	1.54	76190.3
09:00		11.2	79.3	2.26	10.68	1.57	81779.4	12.12	84.86	16.39	1.06	1.52	73641
10:00		11.15	79.86	13.06	12.29	1.55	81004.4	13.07	93.3	14.01	1.03	1.54	69708.2
11:00		維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
12:00		維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
13:00		維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
14:00		9.56	80.86	11.37	17.11	1.59	78309.3	14.72	78.08	11.88	3.31	1.58	71353.5
15:00		8.98	87.46	6.1	13.77	1.59	81157.7	14.13	76.73	18.53	3.79	1.57	74638.6
16:00		8.35	87.73	4.63	10.63	1.59	78872.4	13	76.51	51.23	2.81	1.58	72208.4
17:00		8.8	84.72	5.65	9.49	1.59	81538.2	12.81	73.28	37.44	3.4	1.58	74139.4
18:00		12.02	96.94	9.89	11.6	1.57	76867.7	13.61	77.2	44.11	3.72	1.56	73178.5
19:00		11.21	96.19	5.51	11.08	1.55	76811.8	13.4	74.27	24.48	2.93	1.54	71414
20:00		10.13	90.07	5.54	12.29	1.55	77290.7	12.56	73.51	21.24	2.43	1.53	72329.4
21:00		10.35	91.19	12.06	14.39	1.57	79177.1	13.3	76.38	18.3	2.7	1.56	72686.2
22:00		10.23	91.84	2.37	14.55	1.59	78554.1	13.72	80.55	14.97	2.87	1.57	71096.6
23:00		10.17	89.06	3.72	13.49	1.59	78338.2	22.47	84.24	10.94	12.89	1.59	71723.8