

連續自動監測紀錄日報彙總表

1090722		煙道排放口編號 P001					煙道排放口編號 P002					
監測項目 時間	SO ₂	NO _x	CO	HCL	OPAC	MASS	SO ₂	NO _x	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
	ppm	ppm	ppm	ppm	%	Nm3/hr	ppm	ppm	ppm	ppm	%	Nm3/hr
00:00	2.44	67.05	2.92	13.44	0.79	79728.32	4.61	66.09	11.67	14.87	0.96	73988.63
01:00	2.46	67.43	3.57	13.58	0.78	80644.21	3.24	64.40	13.03	17.12	0.95	74528.22
02:00	2.27	73.65	3.01	13.84	0.77	78241.61	2.41	64.33	7.96	15.94	0.95	72225.71
03:00	2.13	67.19	3.45	14.24	0.76	72384.13	2.20	65.51	7.60	14.92	0.95	74914.16
04:00	2.03	56.68	7.90	13.31	0.76	75471.94	2.26	63.17	9.90	15.26	0.96	75713.16
05:00	2.03	65.64	1.98	12.55	0.76	74792.35	4.37	64.35	10.87	14.57	0.96	78279.64
06:00	1.79	48.58	9.07	11.43	0.76	84186.06	2.25	63.29	11.93	16.17	0.96	75441.78
07:00	1.73	62.34	3.61	11.74	0.79	83568.47	2.80	63.45	6.57	15.52	0.95	75005.97
08:00	1.90	62.72	8.16	11.55	0.76	84221.38	3.40	66.69	17.28	16.09	0.96	79129.79
09:00	2.14	58.61	3.41	11.83	0.79	81656.59	2.83	69.25	15.35	16.33	0.92	79050.86
10:00	3.32	67.23	6.39	14.92	0.77	82375.77	5.29	65.82	12.60	18.90	0.90	75817.76
11:00	3.34	69.09	10.34	18.00	0.79	81477.21	4.90	71.42	7.71	21.05	0.89	75999.76
12:00	6.06	68.20	21.44	34.29	0.82	82887.81	2.75	67.52	11.50	16.96	0.90	78894.93
13:00	2.36	67.83	7.33	16.23	0.82	80544.70	2.12	76.31	3.74	10.80	0.90	65353.98
14:00	1.57	64.45	8.63	12.14	0.82	85379.60	1.47	62.89	15.87	12.69	0.91	79404.65
15:00	維護	維護	維護	維護	0.81	維護	2.08	66.35	8.45	15.33	0.91	79566.00
16:00	維護	維護	維護	維護	0.81	維護	2.26	60.23	14.11	14.67	0.89	77162.95
17:00	維護	維護	維護	維護	0.80	維護	維護	維護	維護	維護	0.88	無效
18:00	維護	維護	維護	維護	0.76	維護	維護	維護	維護	維護	0.89	無效
19:00	2.93	53.25	16.37	9.95	0.76	81099.98	6.42	61.84	12.77	14.78	0.90	74283.22
20:00	2.85	65.48	3.55	10.59	0.78	77714.72	2.63	66.31	14.97	17.73	0.90	75750.58
21:00	2.56	64.90	6.94	10.14	0.75	80150.41	2.26	66.72	9.67	16.74	0.91	77196.93
22:00	2.68	62.77	14.09	10.41	0.74	79767.50	2.80	67.14	9.35	17.04	0.90	75107.83
23:00	2.81	63.81	7.60	9.81	0.75	78103.83	2.60	66.46	8.86	16.35	0.90	74698.29