

連續自動監測紀錄日報彙總表

1090329	煙道排放口編號 P001						煙道排放口編號 P002					
監測項目 時間	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
	ppm	ppm	ppm	ppm	%	Nm3/hr	ppm	ppm	ppm	ppm	%	Nm3/hr
00:00	4.42	67.40	5.68	11.49	0.97	71879.01	停爐	停爐	停爐	停爐	停爐	停爐
01:00	4.40	56.90	7.16	13.36	0.97	80461.57	停爐	停爐	停爐	停爐	停爐	停爐
02:00	4.25	60.55	8.36	13.90	0.97	82665.95	停爐	停爐	停爐	停爐	停爐	停爐
03:00	4.87	64.89	7.97	13.78	0.98	86366.04	停爐	停爐	停爐	停爐	停爐	停爐
04:00	5.20	64.64	6.21	14.17	0.98	80516.06	停爐	停爐	停爐	停爐	停爐	停爐
05:00	5.29	64.83	11.11	13.92	0.98	80506.44	停爐	停爐	停爐	停爐	停爐	停爐
06:00	6.46	65.42	9.80	14.35	0.98	80353.28	停爐	停爐	停爐	停爐	停爐	停爐
07:00	6.44	59.78	9.62	14.51	0.98	80446.81	停爐	停爐	停爐	停爐	停爐	停爐
08:00	5.10	66.12	6.54	14.88	0.98	85628.73	停爐	停爐	停爐	停爐	停爐	停爐
09:00	4.50	57.20	12.54	12.94	0.97	85861.03	6.15	56.93	9.20	13.98	0.73	81632.44
10:00	4.75	65.11	7.77	13.96	0.98	87875.65	6.34	70.04	14.11	14.12	0.76	75096.52
11:00	5.02	58.46	15.40	14.22	0.99	82322.87	6.22	65.16	16.54	14.43	0.75	76635.64
12:00	4.74	63.81	5.20	13.59	1.01	81210.15	6.88	67.38	14.10	12.99	0.76	75480.80
13:00	5.06	68.29	5.90	13.26	1.00	79799.40	6.17	66.21	11.78	13.04	0.76	77220.48
14:00	4.73	63.03	8.32	13.08	0.99	85131.28	6.21	64.00	9.29	14.00	0.76	78026.96
15:00	4.91	66.02	10.68	13.86	0.99	82119.31	6.07	61.54	10.35	13.78	0.74	77074.25
16:00	4.66	63.97	15.25	12.51	1.02	78892.18	6.24	67.56	8.74	14.74	0.74	74413.68
17:00	4.39	64.69	7.27	13.78	1.02	80953.44	6.39	62.42	8.27	14.83	0.76	73117.41
18:00	4.90	63.58	4.64	15.02	1.02	81474.29	5.69	62.50	6.83	14.45	0.75	75675.05
19:00	5.26	63.41	9.27	14.13	1.01	78986.12	5.64	60.27	11.98	14.21	0.74	75476.16
20:00	5.51	65.03	7.74	14.37	1.00	79936.61	4.61	61.78	5.23	11.75	0.74	75396.53
21:00	5.24	62.18	8.26	13.00	0.99	80598.99	5.65	64.86	5.05	14.43	0.73	76821.25
22:00	5.08	65.87	9.36	12.03	0.99	78399.65	5.22	65.20	12.30	12.16	0.73	73879.59
23:00	5.02	64.04	6.32	13.90	0.99	82258.62	4.96	62.32	8.68	13.47	0.74	77040.09