

連續自動監測紀錄日報彙總表

1130304	煙道排放口編號 P001						煙道排放口編號 P002					
監測項目 時間	SO ₂	NO _x	CO	HCL	OPAC	MASS	SO ₂	NO _x	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
	ppm	ppm	ppm	ppm	%	Nm3/hr	ppm	ppm	ppm	ppm	%	Nm3/hr
00:00	1.90	40.72	5.84	10.43	1.00	75929.33	1.68	43.31	9.58	11.98	0.90	83768.18
01:00	2.28	42.15	6.95	10.27	1.01	75427.06	1.55	40.51	7.89	11.61	0.91	82917.79
02:00	3.29	43.21	13.24	11.82	1.02	74699.78	1.63	40.75	5.52	9.66	0.92	79581.28
03:00	2.23	49.00	8.23	9.82	1.03	69968.60	2.50	43.80	7.48	11.62	0.92	80890.99
04:00	3.14	37.70	4.27	10.30	1.01	74819.08	3.83	45.36	8.58	11.31	0.90	84282.28
05:00	3.32	43.58	6.98	11.40	1.00	74549.92	3.45	44.01	9.12	11.57	0.89	82010.88
06:00	2.31	46.99	14.54	9.56	0.99	70726.83	2.94	41.96	6.95	12.07	0.89	83763.58
07:00	2.40	40.33	10.48	10.65	0.99	74210.92	2.47	42.02	8.64	11.46	0.89	85344.84
08:00	2.67	39.80	13.56	11.25	1.01	74259.52	2.60	44.72	12.71	10.91	0.91	83903.78
09:00	1.06	49.04	12.22	9.53	1.01	75667.51	2.02	37.02	4.77	10.91	0.86	81421.30
10:00	1.55	39.72	10.80	9.11	1.01	78117.46	0.97	36.30	10.18	9.89	0.89	79975.22
11:00	1.37	40.95	8.24	10.06	0.91	71926.41	1.48	40.58	12.66	10.88	0.81	81179.34
12:00	2.60	45.78	6.28	8.69	1.06	67600.45	0.59	44.15	6.88	9.09	0.85	78714.05
13:00	1.80	49.16	5.31	10.02	1.09	70646.71	0.51	38.75	6.59	10.34	0.85	78101.06
14:00	2.25	42.21	8.95	9.55	1.09	70102.10	0.83	38.42	7.38	11.43	0.85	77183.59
15:00	2.66	40.68	9.75	9.92	1.06	69734.03	1.49	38.07	9.28	12.27	0.85	78609.55
16:00	2.58	42.33	8.89	9.05	1.04	71546.52	1.67	35.79	9.03	11.16	0.84	78946.64
17:00	2.71	39.51	10.49	10.70	1.04	70247.27	0.98	35.59	9.17	11.78	0.85	77366.36
18:00	1.86	42.87	7.26	9.35	1.05	71524.86	1.28	37.98	8.72	10.34	0.86	78997.42
19:00	1.70	39.91	9.37	10.33	1.09	72404.41	0.66	38.84	7.22	10.80	0.84	77691.36
20:00	1.20	39.44	8.07	9.34	1.04	72321.31	0.48	41.00	7.27	11.20	0.85	79136.63
21:00	2.09	41.73	14.43	11.18	1.02	73132.57	0.69	39.52	8.53	10.67	0.85	78516.48
22:00	2.60	56.55	4.62	10.15	1.03	76467.15	1.29	36.83	10.92	12.88	0.85	80959.17
23:00	歲修停爐	歲修停爐	歲修停爐	歲修停爐	歲修停爐	歲修停爐	0.89	39.69	9.65	13.69	0.86	79469.04