

連續自動監測紀錄日報彙總表

1060814		煙道排放口編號 P001					煙道排放口編號 P002				
時間	監測項目	SO ₂	NO _x	CO	HCL	OPAC	SO ₂	NO _x	CO	HCL	OPAC
		二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率	二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率
		ppm	ppm	ppm	ppm	%	ppm	ppm	ppm	ppm	%
00:00		9.87	54.92	18.89	6.14	1.14	7.95	52.63	20.29	1.30	1.02
01:00		9.52	73.21	10.11	5.85	1.14	7.90	54.26	22.63	1.04	1.03
02:00		9.21	54.32	19.38	5.63	1.15	7.74	56.18	17.13	0.29	1.02
03:00		8.86	43.76	35.57	5.28	1.14	7.55	52.13	15.48	0.73	1.02
04:00		9.02	47.51	47.03	5.51	1.18	7.77	65.23	22.12	0.52	1.05
05:00		8.86	48.80	53.26	6.19	1.14	7.71	61.14	15.42	0.53	1.04
06:00		8.79	49.88	48.96	5.72	1.16	7.85	58.83	25.03	0.42	1.04
07:00		9.84	68.32	18.21	7.09	1.17	7.77	55.62	16.35	0.89	1.05
08:00		10.77	63.51	20.23	5.95	1.15	8.14	65.02	17.88	1.19	1.06
09:00		11.68	58.51	21.29	10.44	1.17	8.87	78.74	12.80	2.05	1.05
10:00		12.94	66.49	22.38	10.58	1.22	10.25	67.74	14.84	4.86	1.05
11:00		14.24	72.25	16.94	12.74	1.21	10.10	80.60	13.73	8.73	1.05
12:00		12.94	72.28	34.44	10.36	1.17	9.61	55.05	22.71	6.63	1.03
13:00		14.35	73.52	24.77	12.39	1.25	11.02	67.68	16.44	6.73	1.04
14:00		15.20	65.99	33.79	13.11	1.25	10.75	65.43	16.11	6.57	1.04
15:00		13.62	68.38	18.40	10.04	1.19	11.72	84.64	10.47	7.98	1.05
16:00		14.53	66.83	29.41	11.64	1.15	10.60	55.42	20.21	5.55	1.03
17:00		12.46	61.92	25.42	7.93	1.13	9.62	73.15	12.61	4.40	1.04
18:00		11.90	61.26	46.71	6.74	1.12	9.06	62.01	27.71	4.60	1.04
19:00		11.48	62.09	24.95	6.81	1.14	8.46	58.39	32.61	3.38	1.04
20:00		10.63	57.10	37.39	6.52	1.14	8.73	61.95	28.22	2.34	1.02
21:00		11.06	69.53	20.68	7.00	1.12	8.44	59.24	22.86	2.91	1.02
22:00		10.66	55.28	38.97	6.31	1.12	8.24	62.90	16.36	3.53	1.02
23:00		10.41	47.79	54.29	6.39	1.11	8.30	75.16	13.80	2.09	1.03