

連續自動監測紀錄日報彙總表

1100205	煙道排放口編號 P001						煙道排放口編號 P002					
監測項目 時間	SO ₂	NO _x	CO	HCL	OPAC	MASS	SO ₂	NO _x	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
	ppm	ppm	ppm	ppm	%	Nm ³ /hr	ppm	ppm	ppm	ppm	%	Nm ³ /hr
00:00	3.04	65.29	3.49	17.81	1.13	81393.28	5.37	65.38	9.01	17.19	0.99	70452.60
01:00	3.20	57.41	4.36	17.52	1.12	82700.55	5.46	64.25	11.32	17.43	0.99	70440.29
02:00	3.43	56.76	10.35	17.32	1.11	82136.04	5.92	63.48	17.09	15.95	0.99	69425.47
03:00	3.09	60.74	5.00	16.81	1.11	81667.70	5.11	65.08	12.84	16.08	1.00	69250.86
04:00	3.35	54.88	7.68	17.65	1.13	80253.49	4.64	63.84	13.58	16.01	1.01	68662.54
05:00	3.29	60.60	4.98	18.57	1.13	81162.06	5.41	63.31	12.94	17.53	1.01	68024.68
06:00	3.31	61.84	4.67	16.86	1.13	80731.98	5.63	68.69	9.86	17.40	1.01	65257.38
07:00	3.04	61.00	4.95	15.65	1.13	82008.73	5.88	66.77	8.12	16.99	1.00	69735.58
08:00	2.93	63.63	4.62	16.83	1.12	81879.90	6.10	61.97	12.23	18.15	0.98	69245.53
09:00	4.10	57.00	6.20	17.37	1.12	84663.90	5.89	62.46	6.64	15.96	1.03	66912.41
10:00	4.16	60.79	6.94	16.58	1.13	77313.07	5.23	57.98	12.98	16.76	1.05	71712.81
11:00	4.19	57.41	11.02	16.81	1.11	82896.29	5.65	54.49	11.24	16.03	1.02	73922.12
12:00	4.05	61.85	13.35	16.69	1.14	82606.94	5.23	60.34	12.32	16.80	1.05	72923.06
13:00	3.96	61.74	10.07	16.44	1.14	77559.82	4.45	61.66	14.40	16.22	1.06	69477.85
14:00	3.06	63.04	5.44	16.77	1.13	83551.18	5.33	59.75	8.26	16.89	1.06	74178.36
15:00	3.56	62.00	6.62	17.34	1.14	81273.35	5.62	61.47	7.80	16.50	1.07	70090.27
16:00	3.54	65.78	7.91	15.63	1.15	80283.95	6.62	65.30	16.35	15.21	1.07	66966.90
17:00	3.79	65.94	10.47	17.48	1.14	79293.22	6.23	67.35	7.94	17.34	1.07	71696.71
18:00	3.61	65.55	11.05	16.71	1.14	79829.51	停爐	停爐	停爐	停爐	停爐	停爐
19:00	4.37	64.83	10.50	18.36	1.13	78502.46	停爐	停爐	停爐	停爐	停爐	停爐
20:00	4.34	67.89	9.63	17.53	1.14	78071.45	停爐	停爐	停爐	停爐	停爐	停爐
21:00	4.12	66.57	8.35	16.43	1.13	78877.24	停爐	停爐	停爐	停爐	停爐	停爐
22:00	3.53	66.97	7.25	16.54	1.15	79705.81	停爐	停爐	停爐	停爐	停爐	停爐
23:00	4.15	65.20	8.41	17.75	1.15	79616.59	停爐	停爐	停爐	停爐	停爐	停爐