

連續自動監測紀錄日報彙總表

| 1061205 | | 煙道排放口編號 P001 | | | | | 煙道排放口編號 P002 | | | | | |
|--------------------|-----------------|-----------------|----------|-------|----------|----------|-----------------|-----------------|----------|------|----------|----------|
| 監測 項目 時間 | SO ₂ | NO _x | CO | HCL | OPAC | MASS | SO ₂ | NO _x | CO | HCL | OPAC | MASS |
| | 二氧化 硫 | 氮氧化 物 | 一氧化 碳 | 鹽酸 | 不透光 率 | 排放流率 | 二氧化 硫 | 氮氧化 物 | 一氧化 碳 | 鹽酸 | 不透光 率 | 排放流率 |
| | ppm | ppm | ppm | ppm | % | Nm3/hr | ppm | ppm | ppm | ppm | % | Nm3/hr |
| 00:00 | 6.20 | 95.10 | 18.96 | 8.12 | 0.86 | 63854.00 | 8.63 | 75.98 | 12.93 | 5.00 | 1.19 | 70106.79 |
| 01:00 | 5.94 | 102.63 | 17.99 | 8.60 | 0.87 | 63666.20 | 8.35 | 78.54 | 13.05 | 4.57 | 1.18 | 68080.00 |
| 02:00 | 4.73 | 87.35 | 17.91 | 7.80 | 0.87 | 63682.00 | 8.00 | 76.05 | 13.73 | 5.00 | 1.18 | 69487.99 |
| 03:00 | 4.26 | 82.33 | 19.51 | 8.26 | 0.85 | 64852.30 | 8.13 | 76.72 | 42.29 | 5.24 | 1.19 | 71284.16 |
| 04:00 | 4.00 | 82.84 | 23.92 | 7.88 | 0.84 | 63688.50 | 7.58 | 63.10 | 38.40 | 4.90 | 1.17 | 72035.34 |
| 05:00 | 3.25 | 80.57 | 19.16 | 8.14 | 0.84 | 63755.00 | 7.35 | 80.76 | 34.07 | 5.85 | 1.19 | 71330.54 |
| 06:00 | 2.26 | 86.69 | 18.25 | 8.59 | 0.82 | 63037.00 | 7.03 | 73.17 | 19.80 | 6.16 | 1.19 | 71269.77 |
| 07:00 | 2.36 | 88.23 | 17.70 | 22.66 | 0.84 | 63482.80 | 6.92 | 72.13 | 19.38 | 5.84 | 1.20 | 70382.36 |
| 08:00 | 2.94 | 84.14 | 18.53 | 15.06 | 0.83 | 63156.50 | 6.98 | 73.96 | 24.53 | 6.82 | 1.20 | 68859.34 |
| 09:00 | 1.70 | 96.83 | 16.75 | 12.75 | 0.72 | 62570.10 | 7.48 | 74.18 | 12.95 | 6.51 | 1.18 | 69086.40 |
| 10:00 | 1.46 | 57.40 | 32.65 | 9.57 | 0.57 | 69256.10 | 6.80 | 59.37 | 29.08 | 5.27 | 0.95 | 70718.11 |
| 11:00 | 1.49 | 78.72 | 18.33 | 11.39 | 維修 | 維修 | 6.69 | 69.09 | 11.08 | 4.06 | 維修 | 71229.23 |
| 12:00 | 1.20 | 86.37 | 17.94 | 9.15 | 0.73 | 維修 | 6.87 | 63.17 | 21.13 | 5.32 | 1.17 | 71261.22 |
| 13:00 | 1.42 | 83.56 | 22.39 | 8.89 | 0.73 | 維修 | 6.89 | 64.66 | 11.67 | 4.71 | 1.17 | 68338.16 |
| 14:00 | 1.47 | 72.63 | 28.56 | 8.91 | 維修 | 維修 | 6.78 | 61.89 | 15.79 | 4.73 | 維修 | 71831.80 |
| 15:00 | 1.65 | 73.52 | 30.18 | 8.34 | 0.71 | 67643.89 | 7.22 | 63.35 | 49.46 | 4.90 | 1.19 | 66930.41 |
| 16:00 | 2.24 | 74.20 | 20.81 | 8.92 | 0.71 | 67785.51 | 7.48 | 58.85 | 44.14 | 4.16 | 1.21 | 71156.53 |
| 17:00 | 2.24 | 87.43 | 19.22 | 9.78 | 0.72 | 65476.03 | 7.57 | 66.71 | 18.50 | 3.02 | 1.20 | 67644.39 |
| 18:00 | 1.52 | 79.56 | 18.77 | 8.86 | 0.72 | 67650.00 | 7.52 | 62.66 | 16.35 | 3.43 | 1.20 | 70788.69 |
| 19:00 | 2.97 | 78.82 | 21.12 | 8.57 | 0.72 | 65691.40 | 7.62 | 63.05 | 64.56 | 3.69 | 1.23 | 68563.54 |
| 20:00 | 3.51 | 74.88 | 24.09 | 9.22 | 0.71 | 67023.56 | 7.87 | 73.84 | 39.90 | 4.17 | 1.23 | 66758.44 |
| 21:00 | 5.03 | 78.87 | 22.39 | 12.61 | 0.71 | 64790.13 | 7.90 | 63.23 | 19.22 | 4.10 | 1.20 | 69336.08 |
| 22:00 | 1.99 | 84.81 | 18.17 | 11.24 | 0.71 | 65728.26 | 7.76 | 70.23 | 14.80 | 3.01 | 1.20 | 68753.40 |
| 23:00 | 2.12 | 88.25 | 21.66 | 10.61 | 0.72 | 66156.53 | 8.01 | 80.24 | 13.07 | 2.67 | 1.20 | 65755.56 |