

連續自動監測紀錄日報彙總表

1100303		煙道排放口編號 P001					煙道排放口編號 P002					
監測項目 時間	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
	ppm	ppm	ppm	ppm	%	Nm3/hr	ppm	ppm	ppm	ppm	%	Nm3/hr
00:00	3.72	62.56	5.82	15.23	1.09	77015.21	3.84	69.95	7.52	14.22	1.02	74342.12
01:00	3.52	67.71	5.75	15.24	1.09	75885.98	4.28	51.69	14.85	15.32	1.02	81441.18
02:00	4.59	65.55	8.11	17.37	1.09	74165.42	5.56	59.22	12.15	16.77	1.00	78313.83
03:00	3.73	69.92	5.87	15.19	1.09	73757.03	3.48	57.71	11.01	16.40	1.00	78116.46
04:00	3.44	65.45	4.62	13.88	1.08	74263.73	4.42	57.79	7.93	16.05	1.00	78519.62
05:00	3.76	70.03	5.42	13.81	1.08	73477.14	3.32	58.40	10.32	14.62	1.01	77831.32
06:00	3.88	66.81	5.10	14.35	1.08	72970.23	3.33	60.16	7.53	12.58	1.01	76865.49
07:00	3.81	73.43	5.44	14.10	1.08	70180.91	4.66	62.39	7.47	16.84	1.00	77402.76
08:00	5.26	61.69	4.34	19.89	1.08	75792.47	6.83	57.79	9.73	18.64	0.99	77396.17
09:00	3.59	60.14	2.77	14.97	1.09	73987.78	6.17	71.17	6.59	13.69	0.99	72285.69
10:00	4.09	70.17	6.29	16.74	1.10	72458.71	5.00	52.96	9.53	15.75	0.98	76338.45
11:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
12:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
13:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
14:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
15:00	4.41	68.65	3.56	17.94	1.11	75868.28	5.20	60.66	11.78	16.70	1.01	74285.93
16:00	3.88	67.82	4.36	17.38	1.10	72595.20	5.87	62.73	12.49	19.73	1.01	76917.66
17:00	3.02	67.99	4.11	15.04	1.10	74015.17	5.14	61.73	8.16	17.24	1.01	77109.74
18:00	3.65	67.81	4.27	16.77	1.10	73205.69	3.75	71.46	5.75	15.37	1.02	72906.77
19:00	3.45	69.15	4.20	16.72	1.11	73016.83	3.50	50.80	17.42	16.07	1.02	80283.82
20:00	3.87	67.11	4.54	17.44	1.11	71744.27	4.20	60.76	8.73	17.32	1.02	74789.34
21:00	4.24	68.96	9.80	17.41	1.11	71696.53	4.33	63.95	6.20	17.24	1.02	77172.14
22:00	3.76	69.47	9.42	16.03	1.11	72983.13	3.84	63.89	7.82	17.39	1.01	78797.70
23:00	4.29	73.00	8.73	15.40	1.12	68770.13	2.88	69.70	7.78	15.43	1.02	74110.98