

連續自動監測紀錄日報彙總表

1060815		煙道排放口編號 P001					煙道排放口編號 P002				
時間	監測項目	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC
		二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率	二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率
		ppm	ppm	ppm	ppm	%	ppm	ppm	ppm	ppm	%
00:00		10.59	72.54	14.54	6.45	1.10	7.46	54.95	15.89	0.96	1.03
01:00		9.32	49.79	47.66	5.41	1.11	7.30	52.54	31.97	0.84	1.02
02:00		9.00	46.09	59.73	5.56	1.11	7.51	55.01	46.00	0.53	1.01
03:00		9.78	41.58	37.93	6.97	1.10	7.38	49.52	24.66	1.07	1.01
04:00		8.62	39.56	30.05	6.51	1.11	7.56	58.95	15.86	0.50	1.02
05:00		8.46	45.47	34.19	5.23	1.11	7.47	54.90	35.00	0.38	1.03
06:00		8.13	41.40	34.54	5.14	1.12	7.69	60.75	19.77	0.44	1.03
07:00		9.48	43.94	28.94	6.54	1.16	8.45	60.58	63.95	0.32	1.05
08:00		13.38	67.64	36.09	8.76	1.13	8.46	58.75	32.21	1.29	1.04
09:00		11.87	61.62	18.56	12.52	1.14	9.58	58.13	37.22	3.10	1.04
10:00		12.75	63.55	31.74	9.84	1.15	9.64	58.00	19.28	4.97	1.04
11:00		12.48	66.97	41.26	9.30	1.14	10.94	61.36	29.52	9.56	1.04
12:00		13.47	68.15	38.03	10.94	1.13	10.82	68.29	34.03	8.48	1.03
13:00		15.62	68.73	30.92	12.12	1.15	12.72	59.40	30.47	9.35	1.03
14:00		15.19	69.09	49.39	12.49	1.13	13.91	65.55	39.05	13.02	1.03
15:00		12.98	65.28	32.55	9.66	1.14	10.47	64.32	40.21	6.12	1.03
16:00		12.87	70.20	14.74	8.53	1.12	9.77	59.56	20.27	5.54	1.02
17:00		12.34	80.71	8.64	7.33	1.12	9.39	84.78	13.78	5.57	0.99
18:00		11.33	61.04	46.81	7.09	1.12	8.57	68.82	16.41	3.00	1.00
19:00		11.83	62.93	46.36	7.97	1.12	8.85	58.88	16.75	3.29	1.00
20:00		14.48	66.03	28.91	12.51	1.12	8.03	68.14	10.25	2.82	1.02
21:00		13.86	67.73	32.65	13.87	1.11	7.66	61.46	14.60	2.36	1.01
22:00		10.79	68.34	17.74	9.94	1.12	8.13	58.22	14.00	1.64	1.01
23:00		10.19	70.56	33.07	8.05	1.11	7.48	66.66	10.56	0.67	1.01