

連續自動監測紀錄日報彙總表

1060917		煙道排放口編號 P001					煙道排放口編號 P002				
時間	監測項目	SO ₂	NO _x	CO	HCL	OPAC	SO ₂	NO _x	CO	HCL	OPAC
		二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率	二氧化硫	氮氧化物	一氧化碳	鹽酸	不透光率
		ppm	ppm	ppm	ppm	%	ppm	ppm	ppm	ppm	%
00:00		2.00	67.82	5.02	7.19	0.98	7.31	55.54	10.46	2.42	1.08
01:00		2.08	53.38	25.91	6.48	0.98	7.50	56.47	9.28	2.10	1.08
02:00		1.78	65.68	6.28	6.56	0.99	7.90	68.96	9.21	2.39	1.08
03:00		1.81	77.34	4.22	7.88	0.98	8.08	72.05	10.15	1.97	1.07
04:00		1.62	72.52	4.20	8.16	0.97	8.49	77.46	9.16	2.35	1.08
05:00		1.58	73.54	4.16	7.49	0.97	7.82	72.73	7.17	2.44	1.07
06:00		1.62	61.53	6.85	7.06	0.99	7.85	75.38	6.94	2.26	1.08
07:00		2.03	67.18	13.25	15.75	1.01	7.73	72.36	7.23	2.56	1.09
08:00		2.49	69.48	36.55	10.50	1.03	7.88	69.17	8.38	7.93	1.09
09:00		4.26	50.06	42.49	8.13	1.06	7.98	48.19	25.12	6.41	1.08
10:00		4.27	50.25	20.67	7.75	1.08	8.80	47.75	25.89	6.31	1.09
11:00		4.13	46.23	21.47	8.21	1.06	9.14	46.79	49.85	6.28	1.09
12:00		4.90	55.12	21.50	9.28	1.05	9.07	51.51	35.40	6.46	1.09
13:00		4.00	61.29	14.81	8.34	1.07	9.08	51.69	43.07	6.51	1.09
14:00		5.11	45.26	32.15	7.17	1.07	9.25	57.92	36.89	7.14	1.10
15:00		4.33	47.42	29.43	6.92	1.07	8.98	45.89	33.52	6.66	1.09
16:00		5.69	40.58	37.21	6.63	1.06	9.10	55.04	44.01	7.16	1.09
17:00		3.82	67.23	9.96	6.76	1.05	8.51	55.93	19.11	6.21	1.09
18:00		6.59	42.47	63.10	6.55	1.05	8.14	61.97	12.44	4.75	1.09
19:00		3.56	48.50	41.22	5.39	1.08	8.01	56.32	16.61	3.39	1.09
20:00		2.94	55.94	18.59	5.87	1.06	7.82	58.92	27.66	2.90	1.09
21:00		2.50	49.18	19.29	5.46	1.04	7.77	64.00	22.68	2.29	1.08
22:00		2.39	40.27	26.03	6.01	1.02	7.59	64.94	37.27	1.88	1.08
23:00		2.20	50.63	19.78	5.98	1.00	7.62	62.77	37.04	2.23	1.08