

連續自動監測紀錄日報彙總表

1090408	煙道排放口編號 P001						煙道排放口編號 P002					
監測 項目  時間	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流率
	ppm	ppm	ppm	ppm	%	Nm3/hr	ppm	ppm	ppm	ppm	%	Nm3/hr
00:00	4.91	67.46	10.71	14.17	1.04	77987.38	4.37	66.68	12.33	12.28	1.08	80030.03
01:00	4.56	66.54	5.63	14.17	1.04	79104.61	4.94	66.87	12.65	14.56	1.09	80341.32
02:00	5.18	65.55	10.04	11.72	1.05	68412.67	3.72	60.34	9.82	12.89	1.09	72833.09
03:00	4.34	68.00	7.66	12.89	1.05	76960.43	3.67	63.64	8.39	14.61	1.10	81420.25
04:00	4.37	64.84	6.04	15.13	1.05	81024.82	3.57	70.78	12.65	13.91	1.10	80577.17
05:00	4.21	62.68	4.74	13.89	1.05	79239.34	3.82	61.90	11.74	14.75	1.11	81141.86
06:00	4.79	62.15	7.31	14.06	1.06	81657.61	4.05	63.53	12.98	14.19	1.11	83822.95
07:00	4.97	64.19	5.30	14.38	1.05	79543.24	3.86	62.99	10.06	13.25	1.12	81907.35
08:00	4.83	60.33	6.96	13.80	1.05	83160.58	4.11	67.69	11.36	13.33	1.12	78429.74
09:00	4.56	58.82	4.88	9.75	1.04	80892.73	4.03	68.59	11.71	11.20	1.13	78911.32
10:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
11:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	無效
12:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
13:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
14:00	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護	維護
15:00	4.82	62.16	3.51	13.65	1.04	82348.90	3.96	67.35	10.22	13.01	1.12	79742.46
16:00	4.78	66.12	4.57	13.70	1.04	83581.00	4.17	66.03	6.47	14.01	1.10	82601.51
17:00	5.19	60.69	7.31	13.79	1.04	84018.65	4.79	44.09	8.44	12.58	1.10	81729.77
18:00	5.10	61.13	12.42	14.04	1.04	79823.67	6.70	55.54	9.49	14.78	1.10	86930.66
19:00	4.82	65.19	20.91	13.71	1.04	80973.15	6.23	54.97	7.50	14.08	1.10	80565.82
20:00	4.77	65.57	8.41	13.89	1.04	80959.12	7.33	69.33	7.24	13.20	1.11	84885.92
21:00	4.82	62.34	10.29	14.29	1.04	81396.38	4.93	62.78	6.23	14.74	1.10	81035.20
22:00	5.08	64.84	9.14	13.33	1.04	79115.98	4.16	61.20	5.56	13.14	1.10	79956.78
23:00	5.41	63.28	10.26	14.57	1.04	80855.89	4.29	63.56	8.21	13.82	1.10	78328.28