

連續自動監測紀錄日報彙總表

1101123	煙道排放口編號 P001						煙道排放口編號 P002					
監測 項目  時間	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS	SO <sub>2</sub>	NO <sub>x</sub>	CO	HCL	OPAC	MASS
	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率	二氧化 硫	氮氧化 物	一氧化 碳	鹽酸	不透光 率	排放流 率
	ppm	ppm	ppm	ppm	%	Nm <sup>3</sup> /hr	ppm	ppm	ppm	ppm	%	Nm <sup>3</sup> /hr
00:00	2.44	63.81	6.47	12.62	1.05	85307.35	5.22	67.14	5.88	12.19	1.11	83810.58
01:00	3.10	61.03	9.66	11.72	1.05	84599.24	9.32	66.61	14.84	13.01	1.10	85274.20
02:00	3.76	66.33	11.41	13.31	1.04	84209.23	5.99	65.01	7.07	11.87	1.10	83194.21
03:00	3.43	66.72	8.25	12.32	1.04	84170.01	4.58	66.62	8.21	11.01	1.11	82322.62
04:00	3.07	66.11	7.91	10.57	1.04	84230.72	6.33	66.88	10.52	11.02	1.11	82833.27
05:00	3.65	64.78	7.76	11.76	1.04	84461.08	4.96	69.26	12.12	10.27	1.11	81965.69
06:00	2.98	70.72	7.41	11.13	1.04	85564.96	5.67	69.19	11.69	12.28	1.11	82944.84
07:00	3.20	62.20	8.88	11.89	1.04	85619.94	6.57	66.10	11.59	12.25	1.11	81531.36
08:00	3.46	65.34	14.43	11.90	1.03	86768.22	7.06	68.39	10.32	12.86	1.10	82949.68
09:00	無效	無效	無效	無效	1.02	維護	6.23	71.40	10.91	12.35	1.11	80187.95
10:00	無效	無效	無效	無效	1.03	無效	無效	無效	無效	無效	1.13	維護
11:00	3.57	66.75	6.21	12.19	1.02	82717.61	無效	無效	無效	無效	1.13	81643.82
12:00	3.65	67.00	6.07	12.31	1.03	83089.92	6.15	67.25	13.08	12.64	1.12	83698.38
13:00	3.94	67.75	5.85	12.37	1.03	83290.92	5.50	67.40	11.98	12.31	1.11	79743.73
14:00	4.25	61.06	10.10	12.80	1.04	84050.39	4.75	65.53	11.69	11.77	1.11	81513.57
15:00	3.45	68.10	9.61	12.76	1.04	82649.27	4.38	66.78	9.79	11.67	1.11	81375.24
16:00	2.98	69.23	5.26	12.82	1.04	83772.87	4.35	67.87	10.33	11.74	1.12	82557.09
17:00	2.79	69.68	7.08	12.58	1.04	83952.25	4.91	70.78	10.84	12.75	1.13	85383.17
18:00	3.33	60.03	5.71	12.96	1.04	87299.45	5.48	65.77	17.72	12.50	1.13	83521.71
19:00	2.91	66.95	6.66	11.43	1.04	84220.63	4.40	66.87	10.74	7.71	1.12	81123.58
20:00	2.49	66.86	5.71	12.56	1.04	83456.83	4.84	67.25	4.16	11.89	1.12	83139.88
21:00	2.48	64.35	6.40	11.45	1.04	87175.13	5.20	68.55	7.26	11.54	1.12	82766.85
22:00	2.38	65.63	6.46	12.67	1.04	84801.46	4.00	71.71	7.20	10.12	1.11	80547.87
23:00	3.66	61.50	7.86	11.59	1.04	87003.52	2.78	69.59	18.60	10.94	1.12	82427.68